Mississippi Department of Environmental Quality
Office of Pollution Control

I-sys 2000 Master Site Detail Report

Site Name: Hercules Inc

PHYSICAL ADDRESS	
LINE 1:	613 West 7th Street
LINE 2:	
LINE 3:	
MUNICIPALITY:	Hattiesburg
STATE CODE:	MS
ZIP CODE:	39401-

MAILING ADDRESS	
LINE 1:	613 West 7th Street
LINE 2:	
LINE 3:	
MUNICIPALITY:	Hattiesburg
STATE CODE:	MS
ZIP CODE:	39401-

OTHER INFORMATION	
MASTER ID:	002022
COUNTY:	Forrest
REGION	SRO
SIC 1:	2822
AIR TYPE:	TITLE V
HW TYPE:	LARGE QUANTITY
SOLID TYPE:	
WATER TYPE:	INDUSTRIAL
BRANCH:	Chemical
ECED CONTACT:	Yassin, Mohammad
BASIN:	

AIR PROGRAMS	☑ SIP	☐ PSD	☐ NSPS	☐ NESHAPS	☑ MACT

Mississippi Department of Environmental Quality
Office of Pollution Control

Pemits


PROGRAM	PERMIT TYPE	PERMIT #	MDEQ PERMIT CONTACT	ACTIVE
HAZ. WASTE	EPA ID	MSD008182081		NO
AIR	TITLE V	080000001	Ketchum, Brian	YES
AIR	SOP	080000001	Ketchum, Brian	NO
WATER	NPDES - MAJOR	MS0001830	Cook, Charles	NO
WATER	NPDES - MAJOR	MS0001830	Cook, Charles	NO
WATER	NPDES - MAJOR	MS0001830	Beasley, Jerry	YES
WATER	PRE-TREATMENT	MSP091286	Tomkins, Tracy	YES
GENERAL	SARA TITLE III	MSR110153	Lavallee, Louis	YES
AIR	TITLE V	0800-00001	Glenn, Montie	NO

Compliance Actions

MEDIA	ACTIVITY TYPE	SCHEDULED	COMPLETED	INSPECTED B
WATER	CEI - NA	3/17/99	3/17/99	Yassin, Mohammad
WATER	CMI - PRETREATMENT	11/1/99		Sharp, Loyd
WATER	CMI - NPDES	4/1/00		Sharp, Loyd
WATER	CMI - NPDES	11/1/99		Sharp, Loyd
WATER	CEI - NA	9/30/00		Yassin, Mohammad
HAZ WASTE	Compliance Evaluation Inspection	9/30/00		Yassin, Mohammad
AIR	State Compliance Inspection	9/30/00		Yassin, Mohammad
HAZ WASTE	Compliance Evaluation Inspection	6/30/99	6/30/99	Yassin, Mohammad
AIR	State Compliance Inspection	6/29/99	6/29/99	Yassin, Mohammad
WATER	CEI - NA	6/30/99	6/30/99	Yassin, Mohammad

REPORT OF
PARTICULATE EMISSIONS TESTS
FOR
HERCULES, INC.
BOILERS 1,2,3, AND 4

Hattiesburg, Mississippi
May, 1985



Performed By:
Environmental Monitoring Laboratories
Ridgeland, Mississippi

ENVIRONMENTAL MONITORING LABORATORIES, INC.

P.O. Box 655 * 224-B Hwy 51 North
Ridgeland, Mississippi 39157

(601) 856-3092

May 31, 1985

Subject: Hercules Inc.
P.O. Box 1937
Hattiesburg, Mississippi

On April 30, May 1, and 27, 1984, Environmental Monitoring Laboratories conducted air emissions tests for Hercules, Inc. in Hattiesburg, Mississippi. The tests were performed to determine particulate emissions from four woodwaste boilers in accordance with requirements of the Mississippi Bureau of Pollution Control.

Unless other regulations or conditions apply the allowable particulate emissions from woodwaste boilers is 0.30 grains per dry standard cubic foot.

Results of these tests are:

Boiler No. 1.....	0.03 grains/dscf	tested 5-01-85
Boiler No. 2.....	0.07	tested 5-27-85
Boiler No. 3.....	0.06	tested 4-30, 5-01-85
Boiler No. 4.....	0.09	tested 4-30-85

The testing project was coordinated by Mr. Charles Jordon of Hercules, Inc. Mr. Don Watts and Mr. Jesse Thompson of the Mississippi Bureau of Pollution Control were present to observe the tests. Danny Russell of Environmental Monitoring Laboratories was responsible for the collection and analysis of the samples.

Following is a report of the tests. Contents are:

1.0	Test Results	page 1
2.0	Source Description	3
3.0	Test Procedures	3
4.0	Data Reduction	4
5.0	Nomenclature	13
6.0	Calibration	14
7.0	Appendices:	15
	a. Sampling and Analytical Data	
	b. Calibration Data	

HERCULES

65×10^6 Btu/hr gas-fired boiler
i.e. 65,000 ft/hr @ 24 hr/day, 365 day/yr

Part -	5 lb/10^6 ft^3	65,000 ft^3/hr	= 0.325 lb/hr	⇒ 1.4	TPY
SO_2 -	0.6 lb/10^6 ft^3		= 0.039	⇒ 0.17	
NO_x -	140 lb/10^6 ft^3		= 9.1	⇒ 39.86	
CO -	35 lb/10^6 ft^3		= 2.28	⇒ 9.96	
VOC -	2.8 lb/10^6 ft^3		= 0.18	⇒ 0.80	

EMISSIONS REDUCTIONS - PER BOILER

Part - Obtain from test reports

SO_2 - 0.15 lb/ton

NO_x - 2.8 lb/ton

CO - 10 lb/ton

VOC - 1.4 lb/ton

TOTAL EMISSIONS REDUCTIONS

Part -
SO_2 -
NO_x -
CO -
VOC -

NET EMISSIONS CHANGE

Part -
SO_2 -
NO_x -
CO -
VOC -

No. 6 S = 2.9

~~Part 125(S)+.~~

Part $10(S)+3 \;\frac{lb}{10^3 gal} \left| \frac{438\ gal}{hr} \right. = 14.02 \Rightarrow 61.4$

SO_2 $157(S)\ \frac{lb}{10^3 gal} \left| 438 \right. \Rightarrow 199\ \#/hr \Rightarrow 873.47\ TPY$

NO_x 55 $\Rightarrow$ 24.1 $\Rightarrow$ 105.5

CO 5 $\Rightarrow$ 2.2 $\Rightarrow$ 9.6

VOC 1 0.4 $\Rightarrow$ 1.9

Currently ~~allowed~~ permitted 705.2 #/hr SO_2 if 100% oil used

$$157\ (2.9)\ \frac{lb}{10^3 gal} \left| \frac{X\ gal}{yr} \right| \frac{T}{2000\ lb} \Bigg| = \frac{59.4}{40}\ TPY$$

39.9
+19.4
59.3
59.4

$$\frac{59.4}{40}(10^3)(2000) = X$$

$$X = 2609255\ gal/yr$$

~~175,108 gal/yr~~

19.4
40
59.4

HERCULES - CURRENT EMISSIONS (FROM EM. INV)

	Em. Pt 009 (Boilers 1+2)		Em Pt 010 (Boilers 3+4)	
	#/hr	TPY	#/hr	TPY
Part	37.2	163	57.9	253.6
SO_2	2.2	9.7	2.2	9.7
NO_x	41.4	181.5	41.4	181.5
CO	59.2	259.3	59.2	259.3
VOC	25.2	110.2	25.2	110.2

NET Em. CHANGE (TPY)

Part 1.4 − 163 − 253.6 = −415.2

SO_2 0.17 − 9.7 − 9.7 = −19.23

NO_x 39.86 − 181.5 − 181.5 = −323.14

CO 9.96 − 259.3 − 259.3 = −508.64

VOC 0.8 − 110.2 − 110.2 = −219.6

Therefore, there will be net emissions decreases for all pollutants upon ~~conversion~~ replacement of old boiler

1.0 Tests Results: The following tables list the measured flow parameters and test results.

1.1 Boiler No. 1

5/1/85

Run. No.		1	2	3	avg.
Date		~~05-09-84~~	~~05-09-84~~	~~05-09-84~~	------
Time start		1144	1312	1434	------
Time end		1245	1413	1537	------
PARTICULATE EMISSIONS	#/hr.	10.9	7.4	7.9	8.7
PARTICULATE EMISSIONS	gr./dscf	0.03	0.02	0.02	0.03
ALLOWABLE EMISSIONS	gr./dscf	0.30	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	69402	67455	65705	67521
VOLUMETRIC FLOWRATE	dscfm	40637	39629	39921	40062
VELOCITY	ft./sec.	54.2	52.7	51.3	52.3
STACK TEMPERATURE	deg F	364	359	387	370
MOISTURE	%	9.3	9.5	7.3	8.7
SAMPLE RATE	%isokinetic	98	99	96	98

1.2 Boiler No. 2

Run. No.		1	2	3	avg.
Date		05-27-85	05-27-85	05-27-85	------
Time start		0823	0957	1145	------
Time end		0925	1059	1247	------
PARTICULATE EMISSIONS	#/hr.	32.6	26.5	26.5	28.5
PARTICULATE EMISSIONS	gr./dscf	0.08	0.07	0.07	0.07
ALLOWABLE EMISSIONS	gr./dscf	0.30	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	80009	78993	80030	79677
VOLUMETRIC FLOWRATE	dscfm	45554	44734	47275	45854
VELOCITY	ft./sec.	62.5	61.7	62.5	62.2
STACK TEMPERATURE	deg F	387	382	370	380
MOISTURE	%	9.4	10.4	7.9	9.2
SAMPLE RATE	%isokinetic	101	99	97	99

1.3 Boiler No. 3

Run. No.		1	2	3	avg.
Date		04-30-85	05-01-85	05-01-85	------
Time start		1438	0853	1007	------
Time end		1543	0954	1108	------
PARTICULATE EMISSIONS	#/hr.	20.8	30.2	16.2	22.4
PARTICULATE EMISSIONS	gr./dscf	0.05	0.08	0.04	0.06
ALLOWABLE EMISSIONS	gr./dscf	03.0	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	79754	77646	79188	78863
VOLUMETRIC FLOWRATE	dscfm	45095	45118	44737	44983
VELOCITY	ft./sec.	62.3	60.6	61.8	61.6
STACK TEMPERATURE	deg F	384	370	377	377
MOISTURE	%	10.5	9.4	11.1	10.3
SAMPLE RATE	%isokinetic	98	98	99	98

1.4 Boiler No. 4

Run. No.		1	2	3	avg.
Date		04-30-85	04-30-85	04-30-85	------
Time start		1005	1128	1249	------
Time end		1109	1231	1352	------
PARTICULATE EMISSIONS	#/hr.	29.1	50.5	26.8	35.5
PARTICULATE EMISSIONS	gr./dscf	0.07	0.13	0.07	0.09
ALLOWABLE EMISSIONS	gr./dscf	0.30	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	80778	79961	77569	79436
VOLUMETRIC FLOWRATE	dscfm	48126	44910	42868	45302
VELOCITY	ft./sec.	63.1	62.4	60.6	62.0
STACK TEMPERATURE	deg F	373	387	399	386
MOISTURE	%	6.8	10.5	10.8	9.4
SAMPLE RATE	%isokinetic	96	100	101	99

2.0 Source Description

2.1 Hercules operates four identical woodwaste boilers. The boilers are capable of using woodwaste fuel and/or gas. Woodwaste is the primary fuel and gas is used only during wood fuel shortages. Woodwaste fuel is obtained from various sources and may differ in quality. Two masonry stacks serve the boilers--No. 1 and No. 2 share one stack and No. 3 and No. 4 share the other.

2.2 Each boiler was operated normally during the tests on an all woodwaste condition.

3.0 Test Procedures

Test procedures used are those described in the Code of Federal Regulations, Title 40, Part 60, Appendix A. Specifically, Method 1 was used to determine the number of sample points, Method 3 to determine excess air and molecular weight of stack gas, and Method 5 to determine flow rates, moisture content, and particulate emissions. The sampling train used is identical to that described in method 5.

There is no access for collecting samples in the masonry stacks. Testing ports are provided in each boiler's breeching in a rectangular vertical section. The placement of the ports does not meet the minimum distance requirements of Method 1, and tapering duct sections and fans proceed and precede the test port sections. Flow conditions at the sample locations however are favorable and cyclonic flow is not excessive. Method 1 rules specify the use of 24 sample points when minimum distance criteria are met. Although minimum distance criteria are not met, 24 sample points were used for these tests. There were no other significant departures from the standard procedures.

4.0 Data Reduction

Hercules - Boiler No. 1
Particulate Emissions Test, May 1, 1985

Collected test data		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.228	.228	.228
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.16	30.16	30.16
7. Pg	: in. H2O	-.42	-.42	-.42
8. Vm	: cf (dry gas)	33.018	32.722	32.205
9. sqr(DP),avg	: in.H2O^.5	.7673	.7461	.7335
10. DH	: in. H2O	1.1396	1.0879	1.1063
11. ts	: degrees F	363.58	359.04	351.00
12. tm	: degrees F	96.46	100.38	100.31
13. Vlc	: ml	69	69.5	51.5
14. CO2	: percent	4.00	3.00	3.00
15. O2	: percent	17.00	18.00	18.00
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	64	44	46

Hercules - Boiler No. 1
Particulate Emissions Test, May 1, 1985

Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.24	30.24	30.24	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.13	30.13	30.13	N/A
3. An : sq ft ((Dn/24)^2)(3.1416)	2.835e-4	2.835e-4	2.835e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	31.66835	31.16099	30.67386	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	3.24783	3.271365	2.424105	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.0930179	.0950085	.0732403	.0870889
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.32	29.2	29.2	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.27	28.14	28.38	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	54.19	52.66	51.30	52.72
10. Q : cfm Vs As(60 sec/min)	69402	67455	65705	67521
11. Qstd : dscfm Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	40637	39629	39921	40062
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	97.80	98.68	96.42	97.63
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0020209	.0014120	.0014996	.0016442
14. E : pounds/hr (Cs Qstd)(60 min/hr)/454 gm/#	10.85	7.40	7.91	8.72
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.03	.02	.02	.03
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	284.85	405.41	405.41	365.22

Hercules - Boiler No. 2
Particulate Emissions Test, May 27, 1985

Collected test data		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.228	.228	.228
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.18	30.18	30.18
7. Pg	: in. H2O	-.41	-.41	-.41
8. Vm	: cf (dry gas)	37.705	36.686	38.378
9. sqr(DP),avg	: in.H2O^.5	.8773	.8649	.8854
10. DH	: in. H2O	1.5229	1.435	1.5092
11. ts	: degrees F	386.67	382.00	369.96
12. tm	: degrees F	88.33	94.58	98.63
13. Vlc	: ml	81	87	66.5
14. CO2	: percent	7.00	5.50	4.50
15. O2	: percent	13.50	16.00	17.00
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	199	158.2	155.5

Hercules - Boiler No. 2
Particulate Emissions Test, May 27, 1985

Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.29	30.29	30.29	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.15	30.15	30.15	N/A
3. An : sq ft ((Dn/24)^2)(3.1416)	2.835e-4	2.835e-4	2.835e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	36.75843	35.35440	36.72346	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	3.81267	4.09509	3.130155	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.0939750	.1038059	.0785413	.0921074
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.66	29.52	29.4	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.56	28.32	28.50	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	62.47	61.67	62.48	62.21
10. Q : cfm Vs As(60 sec/min)	80009	78993	80030	79677
11. Qstd : dscfm Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	45554	44734	47275	45854
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	101.26	99.18	97.48	99.31
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0054137	.0044747	.0042344	.0047076
14. E : pounds/hr (Cs Qstd)(60 min/hr)/454 gm/#	32.59	26.45	26.46	28.50
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.08	.07	.07	.07
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	120.71	209.75	278.69	203.05

Hercules - Boiler No. 3
Particulate Emissions Test, April 30 - May 1, 1985

Collected test data		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.228	.228	.228
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.24	30.16	30.16
7. Pg	: in. H2O	-.56	-.29	-.29
8. Vm	: cf (dry gas)	37.035	36.047	36.561
9. sqr(DP),avg	: in.H2O^.5	.8735	.8526	.8653
10. DH	: in. H2O	1.4958	1.4408	1.475
11. ts	: degrees F	383.50	369.63	376.67
12. tm	: degrees F	105.33	88.52	92.69
13. Vlc	: ml	87.5	77	94
14. CO2	: percent	6.00	2.50	4.00
15. O2	: percent	15.00	18.00	16.50
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	122.3	178	96.9

Hercules - Boiler No. 3
Particulate Emissions Test, April 30 - May 1, 1985

Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.35	30.27	30.27	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.20	30.14	30.14	N/A
3. An : sq ft ((Dn/24)^2)(3.1416)	2.835e-4	2.835e-4	2.835e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	35.08659	35.09968	35.33451	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	4.118625	3.62439	4.42458	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.1050530	.0935953	.1112847	.1033110
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.56	29.12	29.3	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.35	28.08	28.04	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	62.27	60.62	61.83	61.57
10. Q : cfm Vs As(60 sec/min)	79754	77646	79188	78863
11. Qstd : dscfm Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	45095	45118	44737	44983
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	97.64	97.63	99.12	98.13
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0034857	.0050713	.0027424	.0037664
14. E : pounds/hr (Cs Qstd)(60 min/hr)/454 gm/#	20.77	30.24	16.21	22.41
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.05	.08	.04	.06
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	166.22	417.83	250.00	278.02

Hercules - Boiler No. 4
Particulate Emissions Test, April 30, 1985

Collected test data		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.228	.228	.228
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.24	30.24	30.24
7. Pg	: in. H2O	-.81	-.81	-.81
8. Vm	: cf (dry gas)	38.267	37.628	36.466
9. sqr(DP),avg	: in.H2O^.5	.8916	.8731	.8426
10. DH	: in. H2O	1.7608	1.4217	1.3458
11. ts	: degrees F	373.33	387.83	398.92
12. tm	: degrees F	95.94	103.40	105.50
13. Vlc	: ml	57	90	89.5
14. CO2	: percent	3.50	6.00	7.00
15. O2	: percent	16.50	15.00	14.00
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	168.5	304.4	163.2

Hercules - Boiler No. 4
Particulate Emissions Test, April 30, 1985

Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.37	30.34	30.34	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.18	30.18	30.18	N/A
3. An : sq ft ((Dn/24)^2)(3.1416)	2.835e-4	2.835e-4	2.835e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	36.88978	35.76409	34.52459	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	2.68299	4.2363	4.212765	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.0677989	.1059065	.1087520	.0941525
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.22	29.56	29.68	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.46	28.34	28.41	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	63.07	62.43	60.56	62.02
10. Q : cfm Vs As(60 sec/min)	80778	79961	77569	79436
11. Qstd : dscfm Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	48126	44910	42868	45302
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	96.19	99.94	101.07	99.07
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0045677	.0085113	.0047271	.0059354
14. E : pounds/hr (Cs Qstd)(60 min/hr)/454 gm/#	29.05	50.52	26.78	35.45
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.07	.13	.07	.09
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	255.10	166.22	132.68	184.67

5.0 NOMENCLATURE

SYMBOL	UNITS	DESCRIPTION
An	ft^2	Nozzle area
As	ft^2	Stack area
Bws	dimensionless	Proportion of water vapor
CO2	percent	Carbon dioxide content by volume
CO	percent	Carbon monoxide content by volume
Cp	dimensionless	Pitot correction factor
Cs	grams/dscf	Particulate concentration
C's	grains/dscf	Particulate concentration
C,50	gr/dscf@50% xsair	Particulate emissions corrected to 50% excess air
Dn	inches	Nozzle diameter
delta H	in. H_2O	Pressure drop across meter orifice (also DH)
delta P	in. H_2O	Stack velocity pressure head (also DP)
E	#/hr	Particulate emission rate
F	dscf	Volume of flue gas per 10^6 BTU
I	percent	Percent isokinetic sampling
Kp	consistent	Pitot tube constant = 85.49
Mn	milligrams	Particulate sample weight
Md	#/# mole	Dry molecular wt. of stack gas
Ms	#/# mole	Wet molecular wt. of stack gas
N2	percent	Nitrogen content by volume
O2	percent	Oxygen content by volume
Pbar	in. Hg	Barometric pressure
Pg	in. H_2O	Static pressure
Pm	in. Hg	Meter pressure = Pbar+(delta H/13.6)
Ps	in. Hg	Stack pressure = Pbar+(Pg/13.6)
Pstd	in. Hg	Standard pressure = 29.92
Q	ft^3/min	Volumetric flow rate at stack conditions
Qstd	dscf/min	Volumetric flow rate at dry, std. conditions
Theta	minutes	Sampling time per run
tm	^oF	Meter temperature (Tm denotes ^oR)
ts	^oF	Stack temperature (Ts denotes ^oR)
Tstd	^oR	Standard temperature = 528^o
Vlc	ml	Volume of water collected
Vm	ft^3	Volume of dry gas sampled
Vmstd	dscf	Sample volume at standard conditions
Vwstd	scf	Sample volume of water vapor
Y	dimensionless	Meter correction factor
Xsair	percent	Excess air

6.0 Calibrations:

Measurement devices used by Environmental Monitoring Laboratories and subject to changes in measurement precision are initially calibrated prior to use. Those instruments for which calibration factors are subject to change or for which calibration checks are required, are calibrated following each field use or as otherwise directed and noted. Calibration procedures for specific equipment are as follows.

Dry Gas Meter:
Dry gas meters are periodically removed from the sampling consoles and cleaned and repaired (new gaskets etc. as required). Following the overhaul of a meter, the measuring precision is checked by the Bell Prover Method and adjusted when necessary to read to within 2% of 100% accuracy. This service is provided by Big Three Meter Company in Jackson, Mississippi. Overhaul service or any six month period is followed by a five point calibration described in APTD-0576 using either a wet test meter or calibrated dry gas meter (used exclusively for calibrations) as a standard reference. Following field use, a gas meter calibration is checked in one of two ways. [1] Three calibration checks at intermediate orifice settings are performed or [2] orifice meter coefficients are used.

If a meter coefficient obtained from pre-test and post-test checks differs by more than 5%, the coefficient (Y) giving the lower sample volume is used in the calculations.

Orifice:
The orifice coefficient is initially determined and is rechecked following a major gas meter repair and calibration.

Nozzles:
Nozzles are checked before each field use with a precision (.001 in.) dial caliper. Three measurements on different axes are made; an average of those three readings is used in calculations. If the tolerance among measurements exceeds 0.004 inches (highest to lowest reading) the nozzle is repaired and recalibrated or discarded.

Pitot Tubes:
Pitot tubes meeting EPA geometry standards are assigned a coefficient of 0.84. Pitot tubes are visually inspected for damage before, during and after use. Those pitot tubes not meeting the geometry standards are assigned a coefficient from the manufacturer's calibration which it retains unless damaged. All pitot tubes used by Environmental Monitoring Laboratories are manufactured by NAPP, Inc.

Temperature Measuring Instruments:
Most temperature measurements are made with a type K thermocouple and an Omega digital thermocouple thermometer which has an initial calibration traceable to NBS. Other measurements are made using bimetallic dial thermometers. The thermocouples and dial thermometers are checked following or during a test series against an ASTM mercury in glass thermometer.

Barometer:
Aneroid field barometers are checked against and adjusted to readings from a mercury barometer or readings obtained from local weather authorities.

Differential Pressure Gauges:
Velocity head (delta P) and orifice pressure differential (delta H) measurements are made using water manometers of the appropriate range unless otherwise noted in the test data. Manometers do not require calibration.


7.0 Appendices
- a. Test Data
- b. Calibration Data

STACK CONFIGURATION / SAMPLE AND VELOCITY POINTS

Plant Name Hercules Source Boilers 1, 2, 3, 4

Data For: Sample Point Plots Date

Sketch of stack



%Diameter

	4	6	8	10	12	14	16
1	6.7	4.4	3.2	2.6	2.1	1.8	1.6
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9
3	75.0	29.6	19.4	14.6	11.8	9.9	8.5
4	93.3	70.4	32.3	22.6	17.7	14.6	12.5
5		85.4	67.7	34.2	25.0	20.1	16.9
6		95.6	80.6	65.8	35.6	26.9	22.0
7			89.5	77.4	64.4	36.6	28.3
8			96.8	85.4	75.0	63.4	37.5
9				91.8	82.3	73.1	62.5
10				97.4	88.2	79.9	71.7
11					93.3	85.4	78.0
12					97.9	90.1	83.1
13						94.3	87.5
14						98.2	91.5
15							95.1
16							98.4

$D_e = 2LW/(L+W)$

Stack ~~diameter~~ D_e =

Distance from ports to disturbance:

distance to upstream disturbance

distance to downstream disturbance


upstream diameters

downstream diameters

Minimum No. points required 24

No. points selected 24

Nipple length



Velocity profile / Sample point layout

pitot I.D.

pitot Cp

Point No.	"from wall	delta P 1	2	3	4
1	7.8				
2	14.5				
3	24.2				
4	33.8				
5	43.5				
6	53.2				
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					

Notes:

DAW 5/1/8

Plant Hercules
Sampling Location Boiler No. 1
Test For Particulate
Test Operators Russell / Little

RUN No. 1
Date ~~4-30-85~~ 5-1-85
Time start 1144 end 1245

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Expite		Remarks:
Sample Box	No. 1	Minutes/Pt.	2.5	CO_2	4		
Probe/Pitot	5'ss			O_2	17		
Pitot Cp	.84	NOMOGRAPH		CO	–		
Nozzle Dia.	.228	ΔH@	1.88	Time	1222		
Filter No.		Meter Temp.	92				
		% H_2O	10	Condensate:			
Amb. Temp. °F	80	C-Factor	.98	tare	200	fin 260	
Bar. Press. "Hg	30.	Stack Temp.	400	Silica gel:			
Static Press. "H_2O	-.42	Ref. ΔP	1.05	tare	691.0	fin 700.0	

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	111.770	~~0.38~~ .08	~~0.63~~ .11	357	87	87	225	65	1
2	2	230	112.5	0.13	0.21	366	90	88	225	55	1
3	3	500	113.1	0.20	0.33	368	90	88	225	55	1
4	4	730	114.0	0.03	0.05	368	92	89	225	55	1
5	5	1030	114.4	0.39	0.65	366	93	89	225	55	1
6	6	1230	115.6	0.98	1.70	369	96	89	225	55	2
7											
8	1	15/0	117.187	0.98	1.70	367	98	89	225	55	2
9	2	230	119.1	0.65	1.10	366	101	90	225	55	1
10	3	500	120.4	0.54	0.92	365	100	91	225	55	1
11	4	730	122.0	0.51	0.85	367	102	91	225	55	1
12	5	1000	123.2	0.69	1.20	367	101	91	225	55	
13	6	1230	124.6	1.45	2.50	367	104	92	225	55	2
14											
15	1	30/0	126.708	0.85	1.45	363	104	92	225	55	2
16	2	230	128.4	0.79	1.35	364	106	92	235	55	2
17	3	500	130.0	0.67	1.15	363	105	93	235	60	2
18	4	730	131.2	0.70	1.20	362	104	93	235	60	2
19	5	1000	132.8	0.91	1.55	361	106	94	250	60	2
20	6	1230	134.5	1.25	2.20	360	107	94	250	60	3
21											
22	1	45/0	136.494	0.05	0.08	359	106	96	250	60	1
23	2	230	136.9	0.66	1.10	359	105	96	250	60	2
24	3	500	138.3	0.66	1.10	362	105	95	250	60	2
25	4	730	139.8	0.78	1.35	362	107	95	250	60	2
26	5	1000	141.3	0.87	1.50	359	107	96	250	65	2
27	6	1230	143.0	1.15	2.00	359	108	96	250	65	3
28	end	60	144.788								
29											
30											
31			leak check .044 → .052 = .008 cfm @ 5" Hg								
32											
33											
34			33.018	.7673	1.1396	363.58		96.46			
35											

DAW 5/1?

Plant Hercules
Sampling Location Boiler No. 1
Test For Particulate
Test Operators Russell / Little

RUN No. 2
Date 4-30-85 5-1-85
Time start 1312 end 1413

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:
Sample Box	No. 2	Minutes/Pt.	2.5	CO_2	2.0	
Probe/Pitot	S'ss	NOMOGRAPH		O_2	18.0	
Pitot Cp	.84	ΔH@	1.88	CO	—	
Nozzle Dia.	.228	Meter Temp.	100	Time	1404	
Filter No.		% H_2O	10	Condensate:		
Amb. Temp. °F	78	C-Factor	1.0	tare 200	fin 263	
Bar. Press. "Hg	30.16	Stack Temp.	370	Silica gel:		
Static Press. "H_2O	-.42	Ref. ΔP	1.0	tare 671.5	fin 678.0	24-25 K #/L

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	A 1	0	145.716	0.07	0.11	354	91	91	225	60	1
2	2	230	146.2	0.03	0.05	352	94	92	225	55	1
3	3	500	146.5	0.20	0.33	354	94	92	225	55	1
4	4	730	147.6	0.31	0.52	356	99	92	225	55	1
5	5	1000	148.4	0.38	0.65	358	98	93	240	55	1
6	6	1230	149.6	0.60	1.05	358	101	94	240	55	2
7											
8	1	15/0	150.964	0.99	1.75	364	101	94	250	55	3
9	2	230	152.8	0.67	1.15	361	105	95	250	55	3
10	3	500	154.4	0.50	0.86	360	105	94	250	55	2
11	4	730	155.6	0.35	0.60	362	106	95	250	55	1
12	5	1000	156.7	0.69	1.20	364	105	95	250	55	2
13	6	1230	158.3	1.25	2.20	364	108	95	250	55	5
14											
15	1	30/0	160.327	0.82	1.45	360	109	96	260	55	3
16	2	230	161.9	0.79	1.40	365	110	98	260	55	3
17	3	500	163.8	0.55	0.95	363	110	97	275	55	3
18	4	730	165.1	0.65	1.15	358	110	97	260	55	3
19	5	1000	166.7	0.88	1.55	359	109	97	260	55	3
20	6	1230	168.4	1.45	2.60	353	111	98	225	55	6
21											
22	1	45/0	170.261	0.09	0.16	354	110	97	235	55	1
23	2	230	170.9	0.56	0.98	357	107	97	245	55	2
24	3	500	172.3	0.62	1.10	360	109	100	245	55	2
25	4	730	173.4	0.71	1.25	362	109	99	225	55	3
26	5	1000	175.2	0.75	1.30	360	110	98	225	55	3
27	6	1230	176.6	0.97	1.75	360	113	98	225	55	4
28	end	60	178.438								
29											
30			leak check:	.083 → .092 ÷ .009		cfm @	6.14				
31											
32											
33											
34			32.722	.7461	1.0879	359.04			100.38		
35											

Plant Hercules
Sampling Location Boiler No. 1
Test For Particulate
Test Operators Russell / Little

RUN No. 3
Date ~~5-20-85~~ 5-1-85
Time start 1434 end 1537

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		Remarks:
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	2.0		
Probe/Pitot	5'SS	NOMOGRAPH		O_2	18		
Pitot Cp	.84	ΔH@	1.88	CO	—		
Nozzle Dia.	.228	Meter Temp.	100	Time	1515		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	86	C-Factor	1.0	tare 200 ml	fin 243 ml		
Bar. Press. "Hg	30.16	Stack Temp.	370	Silica gel:			
Static Press. "H_2O	-.42	Ref. ΔP	1.0	tare 698.0 g	fin 706.5 g		Excess Cleaning

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	A 1	0	178.706	0.08	0.13	356	95	93	225	70	1
2	2	230	179.2	0.02	0.03	353	95	93	225	60	1
3	3	500	179.4	0.08	0.13	353	96	94	225	55	1
4	4	730	179.7	0.11	0.18	355	97	93	225	55	1
5	5	1000	180.1	0.20	0.34	355	98	94	225	55	1
6	6	1230	181.0	0.34	0.58	352	99	94	225	55	1
7											
8	1	1510	182.123	1.00	1.80	359	101	95	225	55	1
9	2	230	183.9	0.66	1.15	354	104	94	235	60	1
10	3	500	185.6	0.52	0.90	355	105	94	235	60	1
11	4	730	186.9	0.52	0.90	352	105	95	235	60	1
12	5	1000	188.1	0.69	1.20	351	107	95	235	60	1
13	6	1230	189.9	0.90	2.55	351	107	95	235	60	2
14											
15	1	1510	192.000	0.90	1.60	348	109	95	235	60	1
16	2	230	193.8	0.90	1.60	348	109	95	250	55	1
17	3	500	195.7	0.35	0.60	350	110	98	250	55	1
18	4	730	196.7	0.68	1.20	351	109	96	250	55	1
19	5	1000	198.2	0.96	1.75	351	109	96	250	55	1
20	6	1230	200.0	1.45	2.65	347	112	97	250	60	2
21											
22	1	1510	202.190	0.10	0.16	346	110	98	250	55	1
23	2	230	202.8	0.79	1.40	347	108	97	250	55	1
24	3	500	204.5	0.70	1.25	348	109	97	250	55	1
25	4	730	205.9	0.79	1.40	347	108	97	250	55	1
26	5	1000	207.5	0.73	1.30	347	111	98	250	55	1
27	6	1230	209.1	0.97	1.75	348	110	99	250	55	2
28	end	60	210.911								
29											
30			Orifice check: .048 → .071 = .023 in @ 85"								
31											
32											
33											
34			32.705	.7335	1.1063	351.00		100.31			
35											

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules - Boiler No. 1

DATE TAKEN: 5-1-85 DATE ANALYZED: 5-3-85

SAMPLES DELIVERED BY: DGR RECEIVED BY: DGR

ANALYZED BY: DGR

Filter treatment: Oven dried 2hr @ 105°C, desiccated >24hrs, weighed to constant wt.

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1394	1395	1396
Tare wt., g	.5628	.5518	.5530
Final wt., g	.6075	.5806	.5840
Net gain, g	.0447	.0288	.0310

Probe wash treatment: Acetone evaporated over low heat, residue desiccated >24hrs, weighed to constant wt.

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	H1R1	H1R2	H1R3	—
Volume intact?	✓	✓	✓	—
Volume, ml	175	170	145	200
Tare wt., g	(2) 112.7432	(3) 104.7719	(5) 109.7088	
Final wt., g	112.7626	104.7872	109.7235	
Net gain, g	.0194	.0153	.0151	0.0001
Less blank, g	−.0001	−.0001	−.0001	

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	64.0	44.0	46.0

DAU 5-27-8

Plant Hercules
Sampling Location Boiler No. 2
Test For Particulates
Test Operators Russell / Little

RUN No. 1
Date 5-27-85
Time start 0823 end 0925

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		
Sample Box	No1	Minutes/Pt.	2.5	CO_2	7.0		
Probe/Pitot	5'SS	NOMOGRAPH		O_2	13.5		
Pitot Cp	.84	ΔH@	1.88	CO			
Nozzle Dia.	.228	Meter Temp.	87	Time	0850		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	72	C-Factor	.99	tare 200 ml	fin 274 ml		
Bar. Press. "Hg	30.18	Stack Temp.	400	Silica gel:			
Static Press. "H_2O	-.41	Ref. Δ P	1.05	tare 663.5 g	fin 670.5 g		

Remarks:
30,000 #/hr
@ 0500 - 30000
dropped to 0 at end of Run

Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head Δ P, in. H_2O	Orifice Δ H in. H_2O	Stack Temp °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
1	1 0	041.161	0.39	0.66	364	73	72	230	65	1
2	2 30	042.3	0.10	0.16	383	77	72	225	50	1
3	5 00	043.0	0.10	0.16	383	78	73	225	50	1
4	7 30	043.8	0.08	0.13	386	82	75	225	50	1
5	10 00	044.2	0.08	0.13	384	82	75	225	50	1
6	12 30	044.8	0.04	0.06	385	84	76	225	50	1
7										
1	15 0	045.101	1.00	1.75	394	85	77	240	55	3
2	2 30	046.8	1.00	1.75	398	90	79	240	55	3
3	5 00	049.1	0.89	1.45	401	93	79	240	55	2
4	7 30	050.3	0.65	1.10	399	96	81	240	55	2
5	10 00	052.0	0.93	1.25	399	97	82	240	65	3
6	12 30	053.5	1.30	2.30	397	98	82	240	55	4
7										
1	30 0	055.216	0.87	1.55	387	100	83	250	55	3
2	2 30	056.9	1.10	1.90	399	100	84	250	55	4
3	5 00	059.0	1.40	2.50	392	101	85	250	55	5
4	7 30	060.8	1.30	2.30	386	103	85	250	55	5
5	10 00	063.0	1.35	2.40	380	105	85	250	55	6
6	12 30	064.9	1.70	3.00	377	106	86	250	55	7
7										
1	45 0	067.278	0.93	1.60	379	104	87	250	55	5
2	2 30	069.1	1.10	1.90	391	108	87	250	55	5
3	5 00	070.9	1.35	2.40	398	105	87	250	60	7
4	7 30	073.0	1.50	2.65	386	105	87	250	60	8
5	10 00	075.5	0.92	1.55	388	107	87	250	60	5
6	12 30	077.2	1.10	1.90	342	106	88	250	60	6
end	15 60	078.866								
		Leak check: .073 → .083 = .010 cfm @ 8" Hg								
		37.705	.8773	1.5229	38667		88.33			

Draw
5/28/85

Plant Hercules
Sampling Location Boiler No. 2
Test For Particulate
Test Operators Reuse / Little BPC - Dan Watts

RUN No. 2
Date 5-27-85
Time start 0957 end 1059

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		Remarks:
Sample Box	No. 1	Minutes/Pt.	2.5	CO_2	5.5		Blr. 2 brought back upto: 33 to 36 M#/hr
Probe/Pitot	5'ss	NOMOGRAPH		O_2	16.0		
Pitot Cp	.84	ΔH@	1.89	CO	—		
Nozzle Dia.	.228	Meter Temp.	95	Time	1048		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	83	C-Factor	1.0	tare 200	fin 280		
Bar. Press. "Hg	30.18	Stack Temp.	405 420	Silica gel:			
Static Press. "H_2O	-.41	Ref. ΔP	1.05	tare 710.0g	fin 717g		

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
1	1	0	079.192	0.44	0.75	367	84	84	250	70	2
2	2	2 30	080.4	0.21	0.35	398	84	84	250	55	1
3	3	5 00	081.3	0.16	0.26	412	89	85	250	55	1
4	4	7 30	082.0	0.07	0.11	410	91	86	250	50	1
5	5	10 00	082.5	0.07	0.11	395	91	86	265	55	1
6	6	12 30	082.9	0.10	0.16	386	93	90	260	55	1
7											
8	1	15/0	083.499	1.10	1.90	387	91	86	250	55	2
9	2	2 30	085.3	0.78	1.30	395	97	87	270	55	3
10	3	5 00	087.1	0.77	1.30	390	99	88	260	60	3
11	4	7 30	088.5	0.68	1.15	380	101	88	260	55	3
12	5	10 00	089.9	0.83	1.40	372	101	89	260	55	3
13	6	12 30	091.5	1.50	2.60	374	102	90	250	55	3
14											
15	1	30/0	092.977	0.96	1.65	370	104	90	225	55	4
16	2	2 30	095.7	1.00	1.75	375	103	90	245	55	4
17	3	5 00	097.5	1.40	2.40	378	105	91	260	55	7
18	4	7 30	099.5	1.35	2.35	378	107	91	260	55	7
19	5	10 00	101.3	1.15	1.95	372	109	91	250	55	6
20	6	12 30	103.4	1.55	2.70	380	108	92	250	55	8
21											
22	1	45/0	105.356	0.87	1.50	379	106	92	250	55	5
23	2	2 30	107.0	1.00	1.70	378	106	92	260	55	5
24	3	5 00	108.9	1.10	1.90	375	106	93	260	55	5
25	4	7 30	110.8	1.20	2.05	373	107	93	260	55	5
26	5	10 00	112.5	0.85	1.45	373	107	93	260	55	5
27	6	12 30	114.4	0.96	1.65	371	106	92	250	55	5
28	end	60/15	115.878								
29											
30			Leak check: .063 → .069 = .006 cfm @ 8" Hg								
31											
32											
33											
34			36.186	.4649	1.4350	582.90		94.58			
35											

Plant Hercules
Sampling Location Boiler No. 2
Test For Particulate
Test Operators Russell / Little

RUN No. 3
Date 5-27-85
Time start 1145 and 1247

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	4.5		
Probe/Pitot	5'SS	NOMOGRAPH		O_2	17		
Pitot Cp	.84	ΔH@	1.88	CO	—		
Nozzle Dia.	.288	Meter Temp.	98	Time	1219		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	87	C-Factor	1	tare 200	fin 260		
Bar. Press. "Hg	30.18	Stack Temp.	400	Silica gel:			
Static Press. "H_2O	-.41	Ref. ΔP	1.05	tare 724.0 g	fin 730.5 g		

Remarks:

	Port Point	El. Time, Min.	DGM Reading, Ft^3	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	117.654	0.44	0.75	361	88	87	250	65	1
2	2	230	118.9	0.15	0.24	362	90	87	225	55	1
3	3	500	119.7	0.13	0.22	368	92	88	225	55	1
4	4	730	120.2	0.13	0.22	371	92	87	225	55	1
5	5	1000	121.0	0.05	0.07	368	94	89	225	55	1
6	6	1230	121.6	0.11	0.17	360	94	89	225	55	1
7											
8	1	15/0	122.158	1.15	2.00	362	95	91	235	55	1
9	2	230	124.3	1.15	2.00	368	102	91	235	55	1
10	3	500	126.2	0.88	1.50	368	105	91	235	55	1
11	4	730	127.7	0.70	1.20	363	107	91	235	55	1
12	5	1000	129.4	0.90	1.50	360	108	92	235	55	2
13	6	1230	131.2	1.55	2.70	360	109	93	235	55	2
14											
15	1	30/0	133.174	0.97	1.65	369	109	93	235	60	1
16	2	230	134.9	1.10	1.90	374	109	93	235	60	1
17	3	500	136.7	1.40	2.40	372	111	93	235	60	2
18	4	730	138.9	1.25	2.15	375	112	94	235	60	2
19	5	1000	140.9	1.25	2.15	375	113	95	235	60	2
20	6	1230	143.0	1.45	2.50	366	113	96	240	55	2
21											
22	1	45/0	145.000	0.92	1.55	366	111	95	240	55	2
23	2	230	146.7	1.10	1.90	370	110	95	240	55	2
24	3	500	148.7	1.25	2.15	372	112	97	240	55	2
25	4	730	150.7	1.30	2.25	363	113	96	240	55	2
26	5	1000	152.6	0.85	1.45	366	115	97	240	55	2
27	6	1230	154.6	0.93	1.60	364	113	97	240	55	2
28	end	15/60	156.032								
29											
30			Pitot check	.074 →	.076 = .002	ok		4" H2O			
31											
32											
33											
34											
35			58.378	0.8854	1.5092	369.56		98.63			

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules - Boiler No. 2

DATE TAKEN: 5-27-85 DATE ANALYZED: 5-30-85

SAMPLES DELIVERED BY: DGR RECEIVED BY: DGR

ANALYZED BY: DGR

Filter treatment: Filters oven dried 2 hours at 105° C, desiccated at least 24 hours, weighed to constant weight

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1449	1499	1447
Tare wt., g	.5202	.5193	.5174
5-30-85 (1700)	.7047	.6139	.6199
5-31-85 (1145)	.7047	.6140	.6199
Final wt., g	.7047	.6140	.6199
Net gain, g	.1845	.0947	.1025

Probe wash treatment: Transferred to tared beaker, acetone evaporated over low heat, desiccated at least 24 hours, weighed to constant weight.

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	H 1	H 2	H 3	—
Volume intact?	✓	✓	✓	—
Volume, ml	205	190	205	
Tare wt., g	(11) 103.2179	(12) 109.5887	(13) 108.4845	(2) 112.7429
5-30-85 (1700)	103.2322	109.6521	108.5376	112.7429
5-31-85 (1145)	103.2329	109.6522	108.5375	112.7429
Final wt., g	103.2324	109.6522	108.5375	112.7429
Net gain, g	.0145	.0635	.0530	0.0000
Less blank, g	0	0	0	—

PARTICULATE	Run 1	Run 2	Run 3
filter+probe	199.0	158.2	155.5

DAW 5/1/85

Plant Hercules
Sampling Location Boiler No. 3
Test For Particulate
Test Operators Russell / Little

RUN No. 1
Date 4-30-85
Time start 1438 end 1543

Meter Box	PAC	No. Sample Pts.	24	Gas Analysis	Pyrite	Remarks:	
Sample Box	No. 1	Minutes/Pt.	2.5	CO_2	6		
Probe/Pitot	S'ss	NOMOGRAPH		O_2	15		
Pitot Cp	.84	ΔH@	1.88	CO	–		
Nozzle Dia.	.228	Meter Temp.	107	Time	1519		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	87	C-Factor	1.05	tare 200 ml	fin 280 ml		
Bar. Press. "Hg	30.24	Stack Temp.	400	Silica gel:			
Static Press. "H_2O	-.56	Ref. Δ P	1.05	tare 688.5 g	fin 696.0	30,000 # steam	

	Port Point	El. Time, Min.	DGM Reading, $Ft.^3$	Velocity Head Δ P, in. H_2O	Orifice Δ H in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
1	A 1	0	000.926	0.09	0.14	377	95	95	250	70	1
2	2	230	001.5	0.12	0.20	378	99	95	250	60	1
3	3	500	002.1	0.17	0.28	376	98	96	250	55	1
4	4	730	002.8	0.17	0.28	374	100	95	250	55	1
5	5	1000	003.6	0.19	0.31	372	101	97	250	55	1
6	6	1230	004.4	0.15	0.24	365	103	97	250	55	1
7											
8	1	1510	005.044	0.95	1.65	385	104	98	280	60	1
9	2	2 30	006.8	0.87	1.50	386	107	98	270	60	2
10	3	500	008.6	0.45	0.75	381	110	98	250	55	1
11	4	730	009.9	0.66	1.10	374	110	99	250	55	1
12	5	1000	011.2	1.00	1.75	376	113	100	240	60	2
13	6	1230	013.1	1.85	3.30	375	114	100	250	60	3
14											
15	1	30/0	015.838	0.90	1.55	391	114	102	265	60	2
16	2	230	017.0	0.94	1.60	399	114	101	265	60	2
17	3	500	019.0	1.50	2.60	394	116	101	250	60	3
18	4	730	020.7	1.60	2.80	378	116	102	250	60	3
19	5	1000	023.3	1.20	2.00	375	119	102	250	60	2
20	6	1230	025.2	1.40	2.45	380	121	103	235	60	3
21											
22	1	45/0	027.073	0.90	1.55	402	117	102	235	60	2
23	2	230	028.8	0.96	1.65	407	115	103	235	60	2
24	3	500	030.6	1.65	2.90	401	118	104	270	60	3
25	4	730	032.8	1.50	2.60	390	118	103	260	60	3
26	5	1000	034.9	0.79	1.20	384	119	104	250	60	2
27	6	1230	036.6	0.82	1.40	385	117	104	250	60	2
28	end		~~038.~~								
29			037.961								
30			leak check: .088 →	.091 =	.003 @ 6 "Hg						
31											
32											
33											
34			37.035	.8735	1.4958	383.5		105.23			
35											

DAW 5/1/85

Plant Hercules
Sampling Location Boiler No. 3
Test For Particulate
Test Operators Russell / Little

RUN No. 2
Date 5-1-85
Time start 0853 end 0954

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:
Sample Box	No. 2	Minutes/Pt.	2.5	CO_2	2.5	
Probe/Pitot	5'ss	NOMOGRAPH		O_2	18.0	
Pitot Cp	.84	ΔH@	1.84	CO		
Nozzle Dia.	.228	Meter Temp.	92	Time		
Filter No.		% H_2O	11	Condensate:		
Amb. Temp. °F	72	C-Factor	.98	tare 200 ml	fin 265	
Bar. Press. "Hg	20.16	Stack Temp.	390	Silica gel:		
Static Press. "H_2O	-.29	Ref. ΔP	1.05	tare 774.8	fin 790	

	Port	Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. In. Hg
1	A	1	0	038.339	0.10	0.16	361	78	77	225	60	1
2		2	2 30	038.9	0.13	0.21	349	81	77	225	50	1
3		3	5 00	039.6	0.19	0.31	357	81	78	225	50	1
4		4	7 30	040.4	0.10	0.16	358	83	78	225	50	1
5		5	10 00	041.0	0.09	0.14	357	84	79	225	50	1
6		6	12 30	041.5	0.15	0.24	354	85	79	225	55	1
7												
8	B	1	15 0	042.200	1.10	1.85	368	86	80	250	55	4
9		2	2 30	044.0	0.93	1.60	366	91	81	250	55	4
10		3	5 00	045.7	1.00	1.75	363	92	81	250	55	4
11		4	7 30	047.5	0.69	1.20	359	94	81	250	55	3
12		5	10 00	049.0	0.84	1.45	354	95	84	250	55	3
13		6	12 30	050.6	1.85	3.30	358	95	82	235	50	8
14												
15	C	1	30 0	052.802	0.89	1.50	379	98	84	240	55	4
16		2	2 30	054.6	0.95	1.65	398	99	84	240	55	4
17		3	5 00	056.1	0.76	1.30	402	99	85	250	55	3
18		4	7 30	057.7	1.50	2.60	386	100	85	250	55	7
19		5	10 00	060.0	1.20	2.05	369	102	86	260	55	6
20		6	12 30	061.9	1.45	2.50	372	104	87	260	55	7
21												
22	D	1	45 0	063.911	0.40	0.66	384	100	87	250	55	2
23		2	2 30	065.1	0.94	1.60	377	99	87	245	55	5
24		3	5 00	066.6	1.65	2.95	371	101	87	240	55	8
25		4	7 30	069.0	1.50	2.60	375	105	89	240	55	8
26		5	10 00	071.2	0.80	1.40	379	105	88	240	55	5
27		6	12 30	072.9	0.82	1.40	385	105	91	240	55	5
28	end		60	074.386								
29												
30												
31				leak check .042 → .053 = .011 cfm @ 10" Hg								
32												
33												
34				36.047	.8526	1.4408	369.63		98.52			
35												

DAW 5/1/85

Plant Hercules
Sampling Location Boiler No. 3
Test For Particulate
Test Operators Russell / Little

RUN No. 3
Date 5-1-85
Time start 1007 end 1108

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	4		
Probe/Pitot	.895'ss	NOMOGRAPH		O_2	16.5		
Pitot Cp	.84	ΔH@	1.88	CO	-		
Nozzle Dia.	.228	Meter Temp.	92	Time	1041		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	75	C-Factor	.98	tare 200	fin 283		
Bar. Press. "Hg	30.16	Stack Temp.	400	Silica gel:			
Static Press. "H_2O	-.29	Ref. ΔP	1.05	tare 689.5	fin 700.5		

	Port Point	El. Time, Min.	DGM Reading, $Ft.^3$	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
1	A 1	0	074.782	0.10	0.16	362	86	85	225	65	1
2	2	230	075.4	0.12	0.18	375	88	85	225	55	1
3	3	500	076.1	0.15	0.22	376	87	85	225	55	1
4	4	730	076.6	0.08	0.13	374	88	85	235	55	1
5	5	1000	077.1	0.20	0.37	369	89	85	225	55	1
6	6	1230	077.9	0.16	0.26	368	91	86	225	55	1
7											
8	1	15/0	078.582	1.00	1.75	385	91	85	225	55	1
9	2	230	080.5	0.98	1.70	386	95	86	225	55	1
10	3	500	082.4	1.20	2.10	376	99	88	235	55	1
11	4	730	084.2	0.84	1.45	363	101	86	225	55	1
12	5	1000	086.8	0.90	1.55	359	101	87	235	55	1
13	6	1230	087.2	1.70	3.00	354	102	88	240	50	2
14											
15	1	30/0	089.792	0.84	1.45	378	102	87	240	55	1
16	2	230	091.4	0.89	1.55	385	101	87	250	55	1
17	3	500	093.1	1.60	2.80	377	102	88	250	55	2
18	4	730	095.4	1.45	2.50	377	104	87	250	55	2
19	5	1000	097.2	1.20	2.05	370	106	88	250	55	1
20	6	1230	099.2	1.30	2.25	371	105	88	250	55	2
21											
22	1	45/0	101.298	0.40	0.67	383	104	88	250	55	1
23	2	230	102.5	0.94	1.60	397	100	88	250	55	1
24	3	500	104.0	1.40	2.45	398	102	90	250	50	2
25	4	730	106.0	1.40	2.45	399	105	89	250	50	2
26	5	1000	108.0	0.77	1.35	384	105	89	250	50	2
27	6	1230	109.7	0.85	1.45	373	105	90	250	50	1
28	end	60	111.343								
29											
30			Leak check	.006 →	.011 =	.005 cfm	@ 5"	Hg			
31											
32											
33											
34			36.561	0.8453	1.4750	376.67		92.69			
35											

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules - Boiler No. 3

DATE TAKEN: 4-30 & 5-1, 85 DATE ANALYZED: 5-3-85

SAMPLES DELIVERED BY: DGR RECEIVED BY: DGR

ANALYZED BY: DGR

Filter treatment: Oven dried @ 105°C 2 hrs, desiccated >24 hrs, weighed to constant wt.

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1377	1393	1392
Tare wt., g	.5498	.5550	.5774
Final wt., g	.6233	.6626	.6296
Net gain, g	.0735	.1076	.0522

Probe wash treatment: Acetone Evaporated over low heat, residue desiccated >24 hrs, weighed to constant wt.

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	H3R1	H3R2	H3R3	—
Volume intact?	✓	✓	✓	—
Volume, ml	145	165	175	
Tare wt., g	(6) 114.8362	(7) 110.1024	(8) 111.5629	
Final wt., g	114.8851	110.1729	111.6077	
Net gain, g	.0489	.0705	.0448	.0001
Less blank, g	-.0001	-.0001	-.0001	

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	122.3	178.0	96.9

Plant Hercules, Inc
Sampling Location Boiler No. 4
Test For Particulate
Test Operators Russell / Little BPC - Jesse Thompson

RUN No. 1
Date 4-30-85
Time start 1005 end 1109

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 1	Minutes/Pt.	2.5	CO_2	2.5		
Probe/Pitot	5'ss	NOMOGRAPH		O_2	16.5		
Pitot Cp	.84	ΔH@	1.88	CO			
Nozzle Dia.	.228	Meter Temp.	97	Time	1038		
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	80	C-Factor	98	tare 200 ml	fin 250 ml		
Bar. Press. "Hg	30.24	Stack Temp.	360	Silica gel:			
Static Press. "H_2O	-.81	Ref. Δ P	1.0	tare 642 g	fin 649.0 g		

	Port	Point	El. Time, Min.	DGM Reading, $Ft.^3$	Velocity Head Δ P, in. H_2O	Orifice Δ H in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	A	1	0	887.507	0.20	0.35	333	84	84	235	65	1
2		2	230	888.4	0.20	0.35	342	86	84	235	60	1
3		3	500	889.3	0.18	0.31	351	87	84	250	55	1
4		4	730	890.1	0.24	0.42	359	90	84	250	55	1
5		5	1000	891.0	0.28	0.50	360	91	85	250	55	1
6		6	1230	891.9	0.19	0.33	360	93	86	250	55	1
7												
8	B	1	1500	892.734	1.35	2.30	358	94	87	250	55	3
9		2	230	895.1	0.96	1.75	366	99	87	250	55	3
10		3	500	896.7	0.89	1.60	365	102	88	250	55	3
11		4	730	898.4	1.00	1.85	370	103	88	240	55	3
12		5	1000	900.1	0.81	1.45	370	105	90	250	55	3
13		6	1230	901.7	1.80	3.40	366	106	91	250	55	5
14												
15	C	1	1500	903.810	1.05	1.90	369	107	92	250	55	3
16		2	230	905.7	1.05	1.90	384	107	92	250	55	3
17		3	500	907.5	1.35	2.50	390	108	92	250	55	5
18		4	730	909.6	1.35	2.50	392	111	94	250	55	5
19		5	1000	911.7	1.20	2.10	392	111	94	260	60	4
20		6	1230	913.9	1.90	2.45	398	112	95	260	60	5
21												
22	D	1	1500	915.755	0.65	1.10	390.	104	93	260	60	3
23		2	230	917.2	0.85	1.45	392	105	95	260	60	4
24		3	500	918.8	1.20	2.10	392	106	95	260	60	5
25		4	730	920.8	1.25	2.20	391	107	96	260	60	5
26		5	1000	922.7	0.64	1.10	386	109	96	250	60	4
27		6	1230	924.3	0.82	1.40	384	110	96	250	60	4
28	end		60	925.774								
29												
30				leak check	.045 → .050 = .005 cfm							
31												
32												
33				38.267	.8914	1.7608	373.33					
34									98.99			
35								101.54				

Environmental Monitoring Laboratories

Plant Hercules
Sampling Location Boiler No. 4
Test For Particulate
Test Operators Russell / Little

RUN No. 2
Date 4-30-85
Time start 1128 end 1231

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	6.0
Probe/Pitot	S.S.S	NOMOGRAPH		O_2	15.0
Pitot Cp	.84	ΔH@	1.88	CO	
Nozzle Dia.	.228	Meter Temp.	97	Time	
Filter No.		% H_2O	10		
Amb. Temp. °F	82	C-Factor	.98	Condensate:	
Bar. Press. "Hg	30.24	Stack Temp.	400	tare 200 fin 283	
Static Press. "H_2O	-.81	Ref. ΔP	1.05	Silica gel:	
				tare 665.5 g fin 672.0 g	

Remarks:

	Port Point	Elapsed Time, Min.	DGM Reading, Ft^3	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	A 1	0	926.031	0.21	0.35	338	95	93	225	70	1
2	2	230	927.0	0.19	0.32	349	96	94	225	60	1
3	5	500	927.9	0.25	0.41	356	98	94	225	55	1
4	7	730	928.7	0.27	0.44	366	101	95	225	55	1
5	10	1000	929.7	0.17	0.30	371	100	94	225	55	1
6	12	1230	930.5	0.47	0.79	373	102	96	225	55	1
7											
8	B 1	15/0	931.592	1.40	2.45	380	102	96	240	55	2
9	2	230	934.1	0.88	1.50	390	107	98	240	55	1
10	5	500	935.9	0.99	1.70	389	110	97	240	55	2
11	7	730	937.1	0.92	1.60	390	112	97	240	55	2
12	10	1000	939.0	0.80	1.40	393	111	98	240	50	1
13	12	1230	940.6	1.40	2.45	394	112	98	250	55	3
14											
15	C 1	30/0	942.540	0.93	1.60	395	112	97	250	60	2
16	2	230	944.4	0.97	1.70	399	113	98	250	60	2
17	5	500	946.2	1.25	2.15	401	113	99	250	60	3
18	7	730	948.2	1.25	2.15	401	115	100	250	60	3
19	10	1000	950.2	1.30	2.25	403	116	100	250	60	4
20	12	1230	952.2	1.45	2.50	403	116	100	250	60	5
21											
22	D 1	45/0	954.134	0.58	0.96	400	114	100	250	60	3
23	2	230	955.5	0.69	1.20	400	113	100	250	60	3
24	5	500	957.0	1.05	1.85	403	113	101	250	60	5
25	7	730	958.9	1.05	1.85	405	116	102	250	60	5
26	10	1000	961.0	0.66	1.10	405	114	101	250	60	4
27	12	1230	962.4	0.65	1.10	404	113	101	250	60	4
28	end	60	963.659								
29											
30											
31			Leak check: .012 → .015 = .003 cfm @ 6" Hg								
32											
33											
34			37.628	.8736	1.4217	387.80					
35										103.40	

Plant Hercules
Sampling Location Boiler No. 4
Test For Particulate
Test Operators Russell / Little

RUN No. 3
Date 4-30-85
Time start 1249 end 1352

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		Remarks:
Sample Box	No. 2	Minutes/Pt.	2.5	CO_2	7.0		
Probe/Pitot	5' SS			O_2	14.0		
Pitot Cp	.84	NOMOGRAPH		CO	—		
Nozzle Dia.	.228	ΔH@	1.88	Time	1325		
Filter No.		Meter Temp.	106				
		% H_2O	10	Condensate:			
Amb. Temp. °F	84	C-Factor	.99	tare 200	fin 282		
Bar. Press. "Hg	30.24	Stack Temp.	406	Silica gel:			
Static Press. "H_2O	-.81	Ref. ΔP	1.05	tare 649.5	fin 657.0		

	Port	Point	El. Time, Min.	DGM Reading, Ft^3	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	A	1	0	964.202	0.25	0.41	384	99	98	225	70	1
2		2	230	965.2	0.16	0.26	385	101	99	225	60	1
3		3	500	966.0	0.28	0.46	384	102	99	225	60	1
4		4	730	966.8	0.30	0.50	384	103	99	280	55	1
5		5	1000	967.9	0.11	0.17	386	105	100	275	55	1
6		6	1230	968.5	0.14	0.23	388	105	100	250	55	1
7												
8	B	1	1510	969.162	1.20	2.10	395	104	100	250	55	5
9		2	230	971.0	0.79	1.40	398	107	100	250	55	3
10		3	500	972.8	1.30	2.25	399	111	100	240	55	5
11		4	730	974.7	0.77	1.30	401	112	100	230	55	3
12		5	1000	976.3	0.65	1.10	401	113	101	250	55	3
13		6	1230	977.9	1.35 1.35	2.35	404	114	101	250	55	6
14												
15	C	1	1510	979.714	0.87	1.50	406	112	100	250	55	4
16		2	230	981.4	0.91	1.60	406	113	102	250	55	5
17		3	500	983.1	0.55	0.93	409	113	101	250	55	4
18		4	730	984.6	1.25	2.35	410	114	102	250	55	7
19		5	1000	986.5	1.30	2.25	413	115	102	250	55	8
20		6	1230	988.4	1.55	2.70	411	117	102	255	55	10
21												
22	D	1	1510	990.511	0.55	0.94	404	113	102	275	55	5
23		2	230	991.9	0.78	1.35	402	112	102	265	55	6
24		3	500	993.6	0.97	1.60	402	113	102	265	55	7
25		4	730	995.2	1.25	2.20	402	114	102	260	55	9
26		5	1000	997.3	0.65	1.10	401	116	104	250	60	6
27		6	1230	999.0	0.74	1.25	399	115	103	250	60	6
28	end		60/15	000.668								
29												
30												
31				Leak Check:	.067 →	.078 →	.01 after @ 11" Hg					
32												
33												
34				36.466	.8426	1.3458						
35												

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules - Boiler No. 4

DATE TAKEN: 4-30-85 DATE ANALYZED: ~~DeR~~ 5-3-85

SAMPLES DELIVERED BY: DeR RECEIVED BY: DeR

ANALYZED BY: DeR

Filter treatment: Oven dried at 105°C 2hrs, desiccated >24hrs
Weighed to constant wt.

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1374	1376	1375
Tare wt., g	.5537	.5714	.5518
Final wt., g	0.6807	0.7753	0.6600
Net gain, g	.1270	.2039	.1082

Probe wash treatment: Acetone evaporated over low heat, residue desiccated >24hrs

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	H4R1	H4R2	H4R3	—
Volume intact?	✓	✓	✓	—
Volume, ml	180	190	170	200
Tare wt., g	(12) 109.5867	(13) 108.4835	(14) 104.5659	(15) 105.7694
Final wt., g	109.6283	108.5841	104.6210	105.7695
Net gain, g	.0416	.1006	.0051	.0001
Less blank, g	-.0001	-.0001	-.0001	—

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	168.5	364.4	163.2

DRY GAS METER CALIBRATION

Meter I.D. RAC-591349 Date 2-20-85

Calibration Method DGM/OGA Bell Prove By DGR

Calibration Meter I.D. 651729 y=1.000

Barometric Pressure 30.17

Previous use: Initial Calibration following overhaul on 2-19-85

Vac in. Hg	DH in. H_2O	Time min.	Calibrating Meter Vi cf	Calibrating Meter Vf cf	Calibrating Meter Temp °F	Field Meter Vi cf	Field Meter Vf cf	Field Meter Temp °F in	Field Meter Temp °F out	Y
1	0.75	15.0	713.456	720.556	66	060.002	067.241	68 · 91	67 · 68	.9920
1	1.00	15+	720.556	729.280	66	067.241	076.199	90 · 108	68 · 73	1.0061
1	1.50	15.0	729.280	738.973	67	076.199	086.127	104 · 118	73 · 78	1.0242
1	2.00	15.0	738.973	749.801	68	086.127	097.471	112 · 107	77 · 78	.9958
1	2.50	15.0	749.801	762.243	69	097.471	110.407	106 · 109	78 · 78	1.0069
								·	Avg	1.0046
								·	·Y=	1.00
								·	·	

$$Y = [(Vcal)(Pbar)(Tdgm)]/[(Vdgm)(Pm)(Tcal)]$$

Where:

Y = Meter correction factor

Vcal = Volume of gas through calibrating meter, $ft.^3$

Vdgm = Volume of gas through field dry gas meter, $ft.^3$

Pbar = Barometric pressure, in. Hg

Pm = Meter pressure, (Pbar+DH/13.6), in. Hg

Tdgm = Average Dry gas meter temp., ^oR

Tcal = Temperature of gas through calibrating meter, ^oR

DRY GAS METER CALIBRATION

Meter I.D. RAC 591349 Date 5-7-85

Calibration Method Dgm/Dgm By DGR

Calibration Meter I.D. 651729 $\gamma = 1.00$

Barometric Pressure 30.03

Previous use: 4-30, 5-1, 85 - Hancock Bro. 4,3,+1

Vac in. Hg	DH in. H_2O	Time min.	Calibrating Meter Vi cf	Calibrating Meter Vf cf	Calibrating Meter Temp °F	Field Meter Vi cf	Field Meter Vf cf	Field Meter Temp °F in	Field Meter Temp °F out	Y
5	2.75	15.0	029.845	043.266	73	211.220	224.767	73 · 104	73 · 77	1.0002
4	2.00	16.5	043.266	055.621	72	224.767	237.459	101 · 111	77 · 82	1.0065
2	1.00	16.0	055.621	064.466	73	237.459	246.661	107 · 107	82 · 85	.9989
								·	·	
								·	Avg.	1.0019
								·	· $\gamma =$	1.00
								·	·	
								·	·	

$$Y = [(Vcal)(Pbar)(Tdgm)]/[(Vdgm)(Pm)(Tcal)]$$

Where:

Y = Meter correction factor

Vcal = Volume of gas through calibrating meter, $ft.^3$

Vdgm = Volume of gas through field dry gas meter, $ft.^3$

Pbar = Barometric pressure, in. Hg

Pm = Meter pressure, {Pbar+DH/13.6}, in. Hg

Tdgm = Average Dry gas meter temp., ^oR

Tcal = Temperature of gas through calibrating meter, ^oR

THERMOMETER/THERMOCOUPLE CALIBRATION

Date: 6-3-85 By: D&R

Reference Thermometer ASTM Hg/glass 20-760°F

Last Service Hercules 5-27-85

Field Thermometer	Temp. Source	Reference Temperature	Field Therm. Temperature	% error, absolute
5' T'couple Omega 650	Tube Furnace	386	390	<1
Meter In Omega 650	Room	76	76	—
Meter Out Omega 650	Room	76	76	—
Impinger out Bimetal-dial	Room	76	70	<1
Sample Box Bimetal-dial	Tube Furnace	238	230	<1

THERMOMETER/THERMOCOUPLE CALIBRATION

Date: 5-3-85 By: DGR

Reference Thermometer ASTM Hg/glass 20 - 760°F

Last Service Hanlon Bldg 2

Field Thermometer	Temp. Source	Reference Temperature	Field Therm. Temperature	% error, absolute
5' T'couple Omega 650	Tube Furnace	390	393	< 1
Meter In Omega 650	Room	72	72	—
Meter Out Omega 650	Room	72	72	—
Impinger out Bimetal-dial	Room	72	65	1%
Sample Box Bimetal-dial	Tube Furnace	262	255	1

DRY GAS METER CALIBRATION

Meter I.D. RAC Date 6-3-85

Calibration Method DGM/DGM By DGR

Calibration Meter I.D. 651729, ~1.00

Barometric Pressure 30.00

Previous use: Hercules 5-27-85

Vac in. Hg	DH in. H_2O	Time min.	Calibrating Meter Vi cf	Calibrating Meter Vf cf	Calibrating Meter Temp °F	Field Meter Vi cf	Field Meter Vf cf	Field Meter Temp °F in	Field Meter Temp °F out	Y
4	2.0	21.0	126.302	142.017	71	280.296	296.194	71 · 96	71 · 75	.9971
3	1.5	15.0	142.017	151.756	70	296.194	306.204	95 · 98	75 · 78	.9995
2	1.0	16.0	151.756	160.503	70	306.204	315.289	97 · 97	75 · 81	.9940
								·	Avg =	.9969
								·	Y =	1.00
								·	·	
								·	·	

$$Y = [(Vcal)(Pbar)(Tdgm)]/[(Vdgm)(Pm)(Tcal)]$$

Where:

Y = Meter correction factor

Vcal = Volume of gas through calibrating meter, $ft.^3$

Vdgm = Volume of gas through field dry gas meter, $ft.^3$

Pbar = Barometric pressure, in. Hg

Pm = Meter pressure, {Pbar+DH/13.6}, in. Hg

Tdgm = Average Dry gas meter temp., ^oR

Tcal = Temperature of gas through calibrating meter, ^oR

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Pollution Control
P. O. Box 10385
Jackson, Mississippi 39209
(601) 961-5171

MEMORANDUM

TO: File

FROM: Don Watts

SUBJECT: Hercules, Inc. Woodwaste Boilers Stack Test Review
110-0800-00001
Forrest County

DATE: June 26, 1984

On May 8-9, 1984, and May 22, 1984, stack sampling was performed at Hercules, Inc., Hattiesburg, by EML, Inc. The purpose of the tests was to demonstrate compliance as specified in the Permit to Operate.

On May 8-9, 1984, I observed the stack sampling. On May 22, 1984, Jesse Thompson observed the testing. No problems were noted with the sampling that would affect the acceptability of the test.

I have reviewed the test report and determined that the tests are acceptable. Calculations of the particulate emissions for Boiler #1 have been verified. The numbers for all four boilers, which are identical in size, design, and mode of operation, are similar. Therefore, calculations were not done for the other three boilers.

The test report shows the boilers to be well in compliance. Emissions data is summarized below.

	Allowable	Boiler 1	Boiler 2	Boiler 3	Boiler 4
Particulate*	0.30	0.06	0.07	0.07	0.06

*All values are in grains/dscf

DW:cl

P_{std} = 29.92 in Hg.
T_{std} = 68°F = 528°R

HERCULES, INC.
110-0800-00001

Boiler #1
5/9/84 Test

Particulate Test Calculation Review (Method 5)

			RUN 1	RUN 2	RUN 3
T_s	:	Avg. stack temp: °R	845.875	856.46	866.29
T_m	:	Avg. meter temp; °R	551.25	558.44	562.58
ΔH	:	Avg. orifice pressure drop; in. H_2O	1.21	1.1025	1.1533
Y	:	Dry gas meter calibration factor; dimensionless	1.00	1.00	1.00
P_{bar}	:	Barometric pressure; in. Hg	30.29	30.29	30.29
V_m	:	Sample volume (volume metered) at meter conditions; ft^3	36.215	34.68	35.948
V_{mstd}	:	Dry gas volume, corrected to std. conditions; dscf $= V_m Y (T_{std}/T_m)[(P_{bar} + (\Delta H/13.6))/P_{std}]$ (correct for leak if leak rate exceeds allowable) See Meth. 5, 6.3, if applicable	35.22	33.28	34.25
V_{lc}	:	Vol. of water collected; ml	95.5	90.0	96.5
V_{wstd}	:	Vol. of water vapor at std. conditions; scf $= (V_{lc})(.00267)(T_{std}/P_{std})$	4.50	4.24	4.55
B_{ws}	:	Moisture content; dimensionless $(V_{wstd}) / (V_{mstd} + V_{wstd})$	0.113	0.113	0.117
$1 - B_{ws}$	:	Dry gas fraction	0.887	0.887	0.883
C_p	:	Pitot tube coefficient; dimensionless check for proper design or calibration (see 4.1.3 Meth. 2)	0.84	0.84	0.84
$(\sqrt{\Delta P})$ avg:		Average square root of ΔP $(\Sigma\sqrt{\Delta P})/n$ [where n = no. of points]	0.833	0.814	0.831
P_s	:	Stack pressure; in. Hg $= P_{bar}$ + static pressure (in. Hg)	30.24	30.24	30.24
M_d	:	Dry molecular wt. of stack gas; lb/lb mole $= 29.0$ or $(\%\ CO_2)(.44) + (\%\ O_2)(.32) + (\%\ N_2 + CO)(.28)$	29.74	29.92	29.60
M_s	:	Wet molecular wt. of stack gas; lb/lb mole $= (M_d)(1 - B_{ws}) + (18 B_{ws})$	28.413	28.573	28.243
V_s	:	Avg. stack gas velocity; ft/sec. $= (85.49)(C_p)(\sqrt{\Delta P})$ avg. $\sqrt{T_s/(P_s M_s)}$	59.35	58.20	60.10
Q_s	:	Volumetric flow rate; dscf/hr $3600\ (1 - B_{ws})(V_s)(A)(T_{std}/T_s)(P_s/P_{std})$	2552,326	2,471,937	2,512,290
W_a	:	Acetone wash blank; mg See Meth. 5 6.6 and 6.7 if applicable	0	0	0
M_n	:	Particulate sample wt.; mg filter, wash, blank correction	117.8	119.1	177.0
C_s	:	Particulate concentration; grains/dscf $= (0.0154\ gr/mg)(M_n/V_{mstd})$	0.0515	0.0551	0.080
Conversion to appropriate units: $\frac{gr}{dscf} \left\| \frac{\#}{7000\ g} \right\| Q_s \frac{dscf}{hr} \left\| = \#/hr \right.$			18.78	19.46	28.56
I	:	Isokimetic variation: $= \frac{100\ T_s\ [(.002669)(V_{lc}) + (V_m/T_m)(P_{bar} + \Delta H/13.6)]}{60\ \Theta\ V_s\ P_s\ A_n}$	104.86	102.29	103.59

RECEIVED
MAY 29 REC'D
DEPT ... RESOURCE
BUREAU OF POLLUTION CONTROL

REPORT OF PARTICULATE EMISSIONS TESTS FOR HERCULES, INC. BOILERS 1,2,3, AND 4

Hattiesburg, Mississippi
May, 1984

DATA CODED

Performed By:
Environmental Monitoring Laboratories
Ridgeland, Mississippi

ENVIRONMENTAL MONITORING LABORATORIES, INC.

P.O. Box 655 • 224-B Highway 51 North
Ridgeland, Mississippi 39157

(601) 856-3092

May 25, 1984

Subject: Hercules Inc.
P.O. Box 1937
Hattiesburg, Mississippi

On May 8,9 and 22, 1984, Environmental Monitoring Laboratories conducted air emissions tests for Hercules, Inc. in Hattiesburg, Mississippi. The tests were performed to determine particulate emissions from four woodwaste boilers in accordance with requirements of the Mississippi Bureau of Pollution Control.

Unless other regulations or conditions apply the allowable particulate emissions from woodwaste boilers is 0.30 grains per dry standard cubic foot.

Results of these tests are:

Boiler No. 1.....	0.06 grains/dscf	tested 5-09-84
Boiler No. 2.....	0.07	tested 5-22-84
Boiler No. 3.....	0.07	tested 5-08-84
Boiler No. 4.....	0.06	tested 5-08,09-84

The testing project was coordinated by Mr. Larry Polk of Hercules, Inc. Mr. Don Watts and Mr. Jesse Thompson of the Mississippi Bureau of Pollution Control were present to observe the tests. Danny Russell of Environmental Monitoring Laboratories was responsible for the collection and analysis of the samples.

Following is a report of the tests. Contents are:

1.0	Test Results	page 1
2.0	Source Description	3
3.0	Test Procedures	3
4.0	Data Reduction	4
5.0	Nomenclature	13
6.0	Calibration	14
7.0	Appendices:	15
	a. Sampling and Analytical Data	
	b. Calibration Data	

1.0 Tests Results: The following tables list the measured flow parameters and test results.

1.1 Boiler No. 1

Run. No.		1	2	3	avg.
Date		05-09-84	05-09-84	05-09-84	------
Time start		1127	1307	1426	------
Time end		1228	1408	1428	------
PARTICULATE EMISSIONS	#/hr.	18.8	19.5	28.8	22.4
PARTICULATE EMISSIONS	gr./dscf	0.05	0.06	0.08	0.06
ALLOWABLE EMISSIONS	gr./dscf	0.30	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	75990	74569	77821	76127
VOLUMETRIC FLOWRATE	dscfm	42511	41215	42170	41966
VELOCITY	ft./sec.	59.3	58.2	60.8	59.4
STACK TEMPERATURE	^{o}F	386	406	396	396
MOISTURE	%	11	11	12	12
SAMPLE RATE	%isokinetic	105	102	103	103

1.2 Boiler No. 2

Run. No.		1	2	3	avg.
Date		05-22-84	05-22-84	05-22-84	------
Time start		0856	1029	1153	------
Time end		0957	1130	1254	------
PARTICULATE EMISSIONS	#/hr.	27.1	25.7	28.4	27.0
PARTICULATE EMISSIONS	gr./dscf	0.07	0.07	0.08	0.07
ALLOWABLE EMISSIONS	gr./dscf	0.30	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	77318	75704	76260	76427
VOLUMETRIC FLOWRATE	dscfm	43125	42770	43717	42871
VELOCITY	ft./sec.	60.4	59.1	59.5	59.7
STACK TEMPERATURE	^{o}F	384	379	383	382
MOISTURE	%	11	11	11	11
SAMPLE RATE	%isokinetic	101	101	101	101

1.3 Boiler No. 3

Run. No.		1	2	3	avg.
Date		05-08-84	05-08-84	05-08-84	------
Time start		0934	1107	1341	------
Time end		1036	1210	1450	------
PARTICULATE EMISSIONS	#/hr.	28.6	24.2	32.7	28.5
PARTICULATE EMISSIONS	gr./dscf	0.07	0.06	0.08	0.07
ALLOWABLE EMISSIONS	gr./dscf	03.0	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	77749	78580	77328	77886
VOLUMETRIC FLOWRATE	dscfm	45320	45544	46142	45669
VELOCITY	ft./sec.	60.7	61.4	60.4	60.8
STACK TEMPERATURE	^{o}F	358	367	360	362
MOISTURE	%	11	10	8	10
SAMPLE RATE	%isokinetic	105	103	101	103

1.4 Boiler No. 4

Run. No.		1	2	3	avg.
Date		05-08-84	05-09-84	05-09-84	------
Time start		1550	0744	0949	------
Time end		1632	0847	1051	------
PARTICULATE EMISSIONS	#/hr.	40.9	20.6	19.9	27.1
PARTICULATE EMISSIONS	gr./dscf	0.09	0.05	0.05	0.06
ALLOWABLE EMISSIONS	gr./dscf	0.30	0.30	0.30	0.30
VOLUMETRIC FLOWRATE	acfm	81756	79988	77672	79805
VOLUMETRIC FLOWRATE	dscfm	50928	48824	49208	49654
VELOCITY	ft./sec.	63.8	62.5	60.6	62.3
STACK TEMPERATURE	^{o}F	347	354	339	347
MOISTURE	%	6	7	5	6
SAMPLE RATE	%isokinetic	100	101	99	100

2.0 Source Description

2.1 Hercules operates four identical woodwaste boilers. The boilers are capable of using woodwaste fuel and/or gas. Woodwaste is the primary fuel and gas is used only during wood fuel shortages. Woodwaste fuel is obtained from various sources and may differ in quality. Two masonry stacks serve the boilers--No. 1 and No. 2 share one stack and No. 3 and No. 4 share the other.

2.2 Each boiler was operated normally during the tests on an all woodwaste condition. Fuel was usually green pine chips. During the third run for Boiler No. 2 fuel was switched from green pine chips to hardwood.

Copies of boiler log sheets and visible emissions records supplied by Hercules are included in the appendix.

3.0 Test Procedures

Test procedures used are those described in the Code of Federal Regulations, Title 40, Part 60, Appendix A. Specifically, Method 1 was used to determine the number of sample points, Method 3 to determine excess air and molecular weight of stack gas, and Method 5 to determine flow rates, moisture content, and particulate emissions. The sampling train used is identical to that described in method 5.

There is no access for collecting samples in the masonry stacks. Testing ports are provided in each boiler's breeching in a rectangular vertical section. The placement of the ports does not meet the minimum distance requirements of Method 1, and tapering duct sections and fans proceed and precede the test port sections. Flow conditions at the sample locations however are favorable and cyclonic flow is not excessive. Previous tests were performed using 48 sample points since that was the minimum number required. Amended rules specify the use of 24 sample points when minimum distance criteria are met. Although minimum distance criteria are not met, 24 sample points were used for these tests. There were no other significant departures from the standard procedures.

4.0 Data Reduction

4.1 Hercules, Boiler No. 1
Particulate Emissions Test, May 9, 1984

4.1.1 Collected test data

		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.227	.227	.227
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.29	30.29	30.29
7. Pg	: in. H2O	-.71	-.7	-.7
8. Vm	: cf	36.215	34.68	35.948
9. sqr(DP),avg	: in.H2O^.5	.8326	.8143	.8395
10. DH	: in. H2O	1.2083	1.1013	1.1533
11. ts	: degrees F	385.88	396.46	406.29
12. tm	: degrees F	91.25	98.44	102.58
13. Vlc	: ml	95.5	90	99.5
14. CO2	: percent	7.50	9.00	6.50
15. O2	: percent	13.50	12.00	14.00
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	117.8	119.1	177

Hercules Boiler No. 1
Particulate Emissions Test, May 9, 1984

4.1.2 Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.38	30.37	30.37	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.24	30.24	30.24	N/A
3. An : sq ft ((Dn/24)**2)(3.1416)	2.810e-4	2.810e-4	2.810e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	35.21952	33.28386	34.25123	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	4.495185	4.2363	4.683465	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.1131869	.1129073	.1202903	.1154615
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.74	29.92	29.6	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.41	28.57	28.20	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	59.33	58.22	60.76	59.44
10. Q : cf/h Vs As(3600sec/hr)	4559419	4474139	4669283	4567614
11. Qstd : dscfh Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	2550676	2472888	2530226	2517930
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	104.89	102.24	102.83	103.32
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0033447	.0035783	.0051677	.0040302
14. E : pounds/hr (Cs Qstd)/454	18.79	19.49	28.80	22.36
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.05	.06	.08	.06
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	119.30	88.18	134.36	113.95

4.2 Hercules, Boiler No. 2
Particulate Emissions Test, May 22, 1984

4.2.1 Collected test data

		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.228	.228	.228
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	.99	.99	.99
6. Pbar	: in. Hg	30.20	30.20	30.20
7. Pg	: in. H2O	-.8	-.7	-.7
8. Vm	: cf	35.571	35.716	35.915
9. sqr(DP),avg	: in.H2O^.5	.8453	.8306	.8351
10. DH	: in. H2O	1.1358	1.1297	1.1196
11. ts	: degrees F	384.21	378.71	382.96
12. tm	: degrees F	79.81	87.81	90.10
13. Vlc	: ml	96	90	93
14. CO2	: percent	7.00	6.50	7.00
15. O2	: percent	13.50	14.00	14.00
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	165.6	156.7	173.6

Hercules, Boiler No. 2
Particulate Emissions Test, May 22, 1984

4.2.2 Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.28	30.28	30.28	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.14	30.15	30.15	N/A
3. An : sq ft ((Dn/24)**2)(3.1416)	2.835e-4	2.835e-4	2.835e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	34.86334	34.49374	34.54069	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	4.51872	4.2363	4.37751	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.1147406	.1093802	.1124798	.1122002
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.66	29.6	29.68	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.32	28.33	28.37	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	60.37	59.11	59.54	59.67
10. Q : cf/h Vs As(3600sec/hr)	4639077	4542248	4575583	4585636
11. Qstd : dscfh Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	2587523	2566196	2563045	2572254
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	101.45	101.21	101.47	101.38
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0047500	.0045429	.0050260	.0047729
14. E : pounds/hr (Cs Qstd)/454	27.07	25.68	28.37	27.04
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.07	.07	.08	.07
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	120.71	134.36	132.68	129.25

4.3 Hercules, Boiler No. 3
Particulate Emissions Test, May 8, 1984

4.3.1 Collected test data

		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.226	.226	.226
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.24	30.24	30.24
7. Pg	: in. H2O	0	0	0
8. Vm	: cf	37.948	38.198	37.621
9. sqr(DP),avg	: in.H2O^.5	.8652	.8713	.8655
10. DH	: in. H2O	1.3804	1.4158	1.3842
11. ts	: degrees F	358.33	367.46	360.33
12. tm	: degrees F	85.25	93.50	91.52
13. Vlc	: ml	94	88.5	70
14. CO2	: percent	6.50	7.00	7.50
15. O2	: percent	13.50	13.00	13.00
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	177.7	148.7	195.7

Hercules, Boiler No. 3
Particulate Emissions Test, May 8, 1984

4.3.2 Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.34	30.34	30.34	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.24	30.24	30.24	N/A
3. An : sq ft ((Dn/24)**2)(3.1416)	2.786e-4	2.786e-4	2.786e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	37.26513	36.95470	36.52435	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	4.42458	4.165695	3.2949	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.1061312	.1013048	.0827464	.0967275
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.58	29.64	29.72	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.35	28.46	28.75	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	60.70	61.35	60.37	60.81
10. Q : cf/h Vs As(3600sec/hr)	4664919	4714820	4639684	4673141
11. Qstd : dscfh Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	2719215	2732654	2768492	2740120
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	105.02	103.64	101.10	103.25
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0047685	.0040238	.0053581	.0047168
14. E : pounds/hr (Cs Qstd)/454	28.56	24.22	32.67	28.48
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.07	.06	.08	.07
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	122.15	110.02	108.80	113.66

4.4 Hercules, Boiler No. 4
Particulate Emissions Test, May 8 9, 1984

4.4.1 Collected test data

		RUN 1	RUN 2	RUN 3
1. As	: sq ft	21.34722	21.34722	21.34722
2. Dn	: in.	.226	.226	.226
3. Cp	: dimensionless	.84	.84	.84
4. Theta	: minutes	60	60	60
5. Y	: dimensionless	1.00	1.00	1.00
6. Pbar	: in. Hg	30.24	30.29	30.29
7. Pg	: in. H2O	-.78	-.75	-.7
8. Vm	: cf	40.917	38.593	38.472
9. sqr(DP),avg	: in.H2O^.5	.9208	.8947	.8793
10. DH	: in. H2O	1.4229	1.3567	1.3354
11. ts	: degrees F	347.42	354.33	338.75
12. tm	: degrees F	89.23	73.54	82.87
13. Vlc	: ml	50	60.5	44
14. CO2	: percent	4.00	4.00	3.50
15. O2	: percent	17.50	16.00	16.50
16. CO	: percent	.00	.00	.00
17. Mn	: milligrams	242.3	123.9	116.1

Hercules, Boiler No. 4
Particulate Emissions Test, May 8 9, 1984

4.4.2 Calculations:	RUN 1	RUN 2	RUN 3	AVG.
1. Pm : in.Hg (DH/13.6)+Pbar	30.34	30.39	30.39	N/A
2. Ps : in. Hg (Pg/13.6)+Pbar	30.18	30.23	30.24	N/A
3. An : sq ft ((Dn/24)**2)(3.1416)	2.786e-4	2.786e-4	2.786e-4	N/A
4. Vmstd: dscf Vm Y(Pm/Pstd)(Tstd/Tm)	39.89364	38.79191	38.00372	N/A
5. Vwstd: scf (.04707cf/ml)(Vlc)	2.3535	2.847735	2.07108	N/A
6. Bws : dimensionless Vwstd/(Vwstd+Vmstd)	.0557079	.0683900	.0516804	.0585928
7. Md : mol.wt. dry basis .44 CO2+.32 O2+.28(CO+N2)	29.34	29.28	29.22	N/A
8. Ms : mol.wt. wet basis Md(1-Bws)+18 Bws	28.71	28.51	28.64	N/A
9. Vs : ft/sec Kp Cp (sqrDP)sqr(Ts/(Ps Ms))	63.83	62.45	60.64	62.31
10. Q : cf/h Vs As(3600sec/hr)	4905365	4799263	4660290	4788306
11. Qstd : dscfh Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	3055680	2929466	2952500	2979215
12. I : percent [(100 Ts)(.002669 Vlc+(Vm Pm/Tm)]/ (60 Theta Vs Ps An)	100.05	101.48	98.64	100.05
13. Cs : grams/dscf (Mn/1000)/Vmstd	.0060737	.0031940	.0030550	.0041075
14. E : pounds/hr (Cs Qstd)/454	40.88	20.61	19.87	27.12
15. C's : grains/dscf (Cs)(15.43 grains/gram)	.09	.05	.05	.06
16. Xsair: percent 100[(O2-.5CO)/(.264 N2-(O2-.5CO))]	327.96	221.24	255.10	268.10

5.0 NOMENCLATURE

SYMBOL	UNITS	DESCRIPTION
An	ft^2	Nozzle area
As	ft^2	Stack area
Bws	dimensionless	Proportion of water vapor
CO2	percent	Carbon dioxide content by volume
CO	percent	Carbon monoxide content by volume
Cp	dimensionless	Pitot correction factor
Cs	grams/dscf	Particulate concentration
C's	grains/dscf	Particulate concentration
C,50	gr/dscf@50% xsair	Particulate emissions corrected to 50% excess air
Dn	inches	Nozzle diameter
delta H	in. H_2O	Pressure drop across meter orifice (also DH)
delta P	in. H_2O	Stack velocity pressure head (also DP)
E	#/hr	Particulate emission rate
F	dscf	Volume of flue gas per 10^6 BTU
I	percent	Percent isokinetic sampling
Kp	consistent	Pitot tube constant = 85.49
Mn	milligrams	Particulate sample weight
Md	#/# mole	Dry molecular wt. of stack gas
Ms	#/# mole	Wet molecular wt. of stack gas
N2	percent	Nitrogen content by volume
O2	percent	Oxygen content by volume
Pbar	in. Hg	Barometric pressure
Pg	in. H_2O	Static pressure
Pm	in. Hg	Meter pressure = Pbar+(delta H/13.6)
Ps	in. Hg	Stack pressure = Pbar+(Pg/13.6)
Pstd	in. Hg	Standard pressure = 29.92
Q	ft^3/hr	Volumetric flow rate at stack conditions
Qstd	dscf/hr	Volumetric flow rate at dry, std. conditions
Theta	minutes	Sampling time per run
tm	^0F	Meter temperature (Tm denotes ^0R)
ts	^0F	Stack temperature (Ts denotes ^0R)
Tstd	^0R	Standard temperature = 528^0
Vlc	ml	Volume of water collected
Vm	ft^3	Volume of dry gas sampled
Vmstd	dscf	Sample volume at standard conditions
Vwstd	scf	Sample volume of water vapor
Y	dimensionless	Meter correction factor
Xsair	percent	Excess air

6.0 Calibrations:

Measurement devices used by Environmental Monitoring Laboratories and subject to changes in measurement precision are initially calibrated prior to use. Those instruments for which calibration factors are subject to change or for which calibration checks are required, are calibrated following each field use or as otherwise directed and noted. Calibration procedures for specific equipment are as follows.

Dry Gas Meter:
Dry gas meters are periodically removed from the sampling consoles and cleaned and repaired (new gaskets etc. as required). Following the overhaul of a meter, the measuring precision is checked by the Bell Prover Method and adjusted when necessary to read to within 2% of 100% accuracy. This service is provided by Big Three Meter Company in Jackson, Mississippi. Overhaul service or any six month period is followed by a five point calibration described in APTD-0576 using either a wet test meter or calibrated dry gas meter (used exclusively for calibrations) as a standard reference. Following field use, a gas meter calibration is checked in one of two ways. [1] Three calibration checks at intermediate orifice settings are performed or [2] orifice meter coefficients are used.

If a meter coefficient obtained from pre-test and post-test checks differs by more than 5%, the coefficient (Y) giving the lower sample volume is used in the calculations.

Orifice:
The orifice coefficient is initially determined and is rechecked following a major gas meter repair and calibration.

Nozzles:
Nozzles are checked before each field use with a precision (.001 in.) dial caliper. Three measurements on different axes are made; an average of those three readings is used in calculations. If the tolerance among measurements exceeds 0.004 inches (highest to lowest reading) the nozzle is repaired and recalibrated or discarded.

Pitot Tubes:
Pitot tubes meeting EPA geometry standards are assigned a coefficient of 0.84. Pitot tubes are visually inspected for damage before, during and after use. Those pitot tubes not meeting the geometry standards are assigned a coefficient from the manufacturer's calibration which it retains unless damaged. All pitot tubes used by Environmental Monitoring Laboratories are manufactured by NAPP, Inc.

Temperature Measuring Instruments:
Most temperature measurements are made with a type K thermocouple and an Omega digital thermocouple thermometer which has an initial calibration traceable to NBS. Other measurements are made using bimetallic dial thermometers. The thermocouples and dial thermometers are checked following or during a test series against an ASTM mercury in glass thermometer.

Barometer:
Aneroid field barometers are checked against and adjusted to readings from a mercury barometer or readings obtained from local weather authorities.

Differential Pressure Gauges:
Velocity head (delta P) and orifice pressure differential (delta H) measurements are made using water manometers of the appropriate range unless otherwise noted in the test data. Manometers do not require calibration.


APPENDIX
a. Test Data
b. Calibration Data
c. Boiler Operation Data

STACK CONFIGURATION / SAMPLE AND VELOCITY POINTS

Plant Name Hercules Source Boilers 1, 2, 3, 4

Data For: Sample Point Plots Date

Sketch of stack



%Diameter

	4	6	8	10	12	14	16
1	6.7	4.4	3.2	2.6	2.1	1.8	1.6
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9
3	75.0	29.6	19.4	14.6	11.8	9.9	8.5
4	93.3	70.4	32.3	22.6	17.7	14.6	12.5
5		85.4	67.7	34.2	25.0	20.1	16.9
6		95.6	80.6	65.8	35.6	26.9	22.0
7			89.5	77.4	64.4	36.6	28.3
8			96.8	85.4	75.0	63.4	37.5
9				91.8	82.3	73.1	62.5
10				97.4	88.2	79.9	71.7
11					93.3	85.4	78.0
12					97.9	90.1	83.1
13						94.3	87.5
14						98.2	91.5
15							95.1
16							98.4

$D_e = 2LW/(L+W)$

Stack ~~diameter~~ D_e =

Distance from ports to disturbance:

distance to upstream disturbance

distance to downstream disturbance


upstream diameters

downstream diameters

Minimum No. points required 24

No. points selected 24

Nipple length



Velocity profile / Sample point layout

pitot I.D.

pitot Cp

Point No.	"from wall	delta P 1	2	3	4
1	4.8				
2	14.5				
3	24.2				
4	33.8				
5	43.5				
6	53.2				
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					

Notes:

1,056

DAW

Plant Hercules
Sampling Location Boiler No.1
Test For Particulate
Test Operators Russell

RUN No. 1
Date 5-9-84
Time start 1127 end 1228

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No1	Minutes/Pt.	2.5	CO_2	7.5	Nozzle	
Probe/Pitot	5.5	NOMOGRAPH		O_2	13.5	⌀ .267	
Pitot Cp	.84	ΔH@	1.61	CO	-	⌀ .267	
Nozzle Dia.	.[illegible].227	Meter Temp.	90	Time		⌀ .267	
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	78	C-Factor	0.87	tare 200ml	fin 289		
Bar. Press. "Hg	30.29	Stack Temp.	385	Silica gel:			
Static Press. "H_2O	-0.71	Ref. ΔP	1.2	tare 700	fin 706.5		

Port	Point	El. Time, Min.	DGM Reading, $Ft.^3$	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
* 1	1	0	895.545	0.09	0.13	376	81	81	230	65	1
* 2	2	230	896.1	0.09	0.13	376	82	81	230	60	1
3	3	500	896.7	0.09	0.13	377	82	79	230	60	1
	4	730	897.4	0.35	0.54	380	86	81	230	60	1
	5	1000	899.5	0.05	0.08	379	86	81	230	60	1
	6	1230	898.7	0.11	0.18	379	89	81	260	55	1
									250		
2	1	15/0	899.743	0.73	1.15	379	89	83	250	55	1
	2	230	901.4	0.49	0.76	380	92	84	250	55	1
	3	500	902.6	0.70	1.10	383	93	85	250	55	1
	4	730	904.2	0.73	1.15	388	95	86	250	55	1
	5	1000	905.7	0.99	1.50	394	97	85	230	55	1
	6	1230	907.5	1.45	2.25	393	102	86	230	55	1
3	1	30/0	909.556	0.96	1.45	385	101	87	240	55	1
	2	230	911.3	1.10	1.65	393	101	87	240	55	1
	3	500	913.2	1.50	2.30	390	103	88	250	55	3
	4	730	915.4	1.35	2.05	391	104	88	250	55	3
	5	1000	917.4	1.25	1.90	390	105	89	250	55	2
	6	1230	919.5	1.50	2.30	393	105	90	250	55	3
4	1	45/0	921.496	0.77	1.15	383	102	89	250	55	2
	2	230	923.1	0.89	1.35	389	104	90	250	55	2
	3	500	924.9	0.90	1.35	389	103	90	250	55	2
	4	730	926.8	1.10	1.65	396	106	90	250	55	3
	5	1000	928.6	0.75	1.10	391	104	91	275	55	3
	6	1230	930.1	1.10	1.65	393	104	92	260	55	3
END		60/5	931.760								
			Leak check: 0.005 cfm @		6" Hg						
			36.215	0.8326	1.2083	385.8	96.5				

A1.25

.003

Plant Hercules
Sampling Location Boiler No. 1
Test For Particulate
Test Operators Russell / Little

RUN No. 2
Date 5-9-84
Time start 1307 end 1408

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 2	Minutes/Pt.	2.5	CO_2	9.0		
Probe/Pitot	S'S	NOMOGRAPH		O_2	12.0		
Pitot Cp	.84	ΔH@	1.61	CO	—		
Nozzle Dia.	.227	Meter Temp.	98	Time			
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	83	C-Factor	.88	tare 200 ml	fin 283		
Bar. Press. "Hg	30.29	Stack Temp.	390	Silica gel:			
Static Press. "H_2O	-.70	Ref. ΔP	1.2	tare 636 g	fin 643 g		

	Port	Point	El. Time, Min.	DGM Reading, $Ft.^3$	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac In. Hg
1	1	1	0	932.024	0.09	0.12	367	90	90	250	70	1
2		2	230	932.5	0.09	0.12	380	91	90	250	70	1
3		3	500	933.1	0.09	0.12	383	93	90	260	65	1
4		4	730	933.7	0.19	0.27	383	95	92	260	65	1
5		5	1000	934.4	.25 0.25	0.35	398	96	91	260	65	1
6		6	1230	935.1	0.18	0.25	387	96	91	260	65	1
7												
8	2	1	15/0	936.000	0.75	1.10	389	98	91	250	60	2
9		2	230	937.5	0.45	0.65	383	100	91	250	55	1
10		3	500	938.9	0.45	0.65	386	102	92	250	55	1
11		4	730	940.1	0.94	1.40	393	103	92	260	55	2
12		5	1000	941.8	0.95	1.40	399	107	93	270	55	2
13		6	1230	943.8	1.2 1.20	1.70	403	109	93	260	55	3
14												
15	3	1	30/0	945.304	0.94	1.40	404	107	94	260	55	2
16		2	230	947.0	1.20	1.70	407	108	95	250	55	3
17		3	500	949.1	0.90	1.35	407	110	96	250	55	2
18		4	730	950.6	1.40	2.20	407	111	95	250	55	4
19		5	1000	952.8	1.30	1.95	408	111	96	260	55	4
20		6	1230	954.7	1.50	2.30	405	111	94	250	55	4
21												
22	4	1	45/0	956.884	0.72	1.05	400	109	94	250	55	2
23		2	230	958.6	0.59	0.85	403	108	95	250	55	2
24		3	500	959.9	0.95	1.40	403	107	96	250	55	3
25		4	730	961.6	1.0 1.05	1.70	404	108	96	250	55	2
26		5	1000	963.5	0.75	1.10	410	108	96	250	55	3
27		6	1230	965.1	0.89	1.30	410	108	96	250	55	3
28	END		60/15	966.704								
29												
30												
31				Leak check: 0.006 cfm @ 6" Hg								
32												
33								107.58	93.29			
34				34.680	0.8143	1.1013	396.46					
35												

G 8.44

Plant Hercules
Sampling Location Boiler No. 1
Test For Particulate
Test Operators Russell/Little

RUN No. 3
Date 5-9-84
Time start 1426 end 1428

Meter Box	PAC-1	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	6.5		
Probe/Pitot	S'S	NOMOGRAPH		O_2	13.0		
Pitot Cp	.84	ΔH@	1.61	CO	—		
Nozzle Dia.	.227	Meter Temp.	105	Time			
Filter No.		% H_2O	12	Condensate:			
Amb. Temp. °F	85	C-Factor	.85	tare 200 ml	fin 290		
Bar. Press. "Hg	30.29	Stack Temp.	410	Silica gel:			
Static Press. "H_2O	-.7	Ref. Δ P	1.2	tare 709.5g	fin 716.0		

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head Δ P, in. H_2O	Orifice Δ H in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	966.963	0.10	0.14	392	96	96	225	70	1
2	2	230	967.6	0.10	0.14	398	97	97	225	65	1
3	5	00	968.1	0.10	0.14	390	98	96	225	65	1
4	7	30	968.8	0.27	0.39	395	100	97	225	60	1
5	10	00	969.8	0.15	0.21	398	102	98	230	60	1
6	12	30	970.5	0.16	0.22	401	104	99	230	60	1
7											
2	1	15/0	971.145	0.76	1.10	403	105	98	230	60	1
8	2	230	972.8	0.46	0.65	400	105	99	230	60	1
9	3	500	974.1	0.70	1.05	404	107	99	230	60	1
10	4	730	975.7	1.05 1.05	1.55	408	108	99	240	50	2
11	5	1000	977.4	1.10	1.65	415	109	99	240	50	2
12	6	1230	979.2	1.20	1.80	415	110	99	240	50	2
13											
3	1	30/0	981.095	1.05	1.55	416	111	99	240	50	2
14	2	230	983.1	1.10	1.65	416	112	100	250	50	3
15	3	500	984.8	0.77	1.10	415	111	99	250	50	2
16	4	730	986.4	1.40	2.10	414	111	99	250	50	3
17	5	1000	988.4	1.20 ✓	1.80	415	113	100	250	50	3
18	6	1230	990.4	1.50	2.30	413	113	100	250	50	4
19											
4	1	45/0	992.707	0.64	0.94	406	111	99	250	50	2
20	2	230	994.2	0.92	1.35	405	109	97	250	50	3
21	3	500	995.9	0.91	1.35	406	109	98	250	50	3
22	4	730	997.6	1.1 1.1	1.65	408	109	98	250	50	3
23	5	1000	999.7	0.73	1.05	407	109	97	250	55	3
24	6	1230	1001.2	1.20	1.80	409	108	97	250	55	4
25	END	60/15	1002.911								
26											
27											
28											
29											
30			Leak Check: 0.005 cfm @ 6" Hg								
31											
32											
33											
34				0.8395	1.1533	406.29	106.88	98.29			
35								102.58			

Environmental Monitoring Laboratories

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules, Boiler No. 1

DATE TAKEN: May 9, 1984 DATE ANALYZED: May 10, 11, 1984

SAMPLES DELIVERED BY: D6R RECEIVED BY: D6R

ANALYZED BY: D6R

Filter treatment: 205°C ove, 2 hrs, cooled in desiccator weighed to constant wt.

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1084	1085	1086
Tare wt., g	0.5209	0.5223	0.5325
Final wt., g	0.5880	0.5856	0.6345
Net gain, g	0.0671	0.0633	0.1020

Probe wash treatment: Acetone evaporated down [illegible]

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	HBI-1	HBI-2	HBI-3	—
Volume intact?	✓	✓	✓	—
Volume, ml	205	155	210	200
Tare wt., g	(10) 105.6956	(11) 103.2247	(12) 109.5915	
Final wt., g	105.7463	103.2805	109.6665	
Net gain, g	0.0507	0.0558	0.0750	0.0000
Less blank, g	0.0000	0.0000	0.0000	

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	117.8	119.1	177.0

Plant Hercules
Sampling Location No. 2 Boiler
Test For Particulate
Test Operators Russell Hercules/Lacey Polk

RUN No. 1
Date 5-22-84
Time start 0856 end 0957

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No 1	Minutes/Pt.	2.5	CO_2	7.0	.227 Θ	
Probe/Pitot	S'ss	NOMOGRAPH		O_2	13.5	.229 Θ	
Pitot Cp	.84	ΔH@	1.61	CO	-	.228 Θ	
Nozzle Dia.	.228	Meter Temp.	82	Time			
Filter No.		% H_2O	10				
Amb. Temp. °F	67	C-Factor	0.83	Condensate: tare 200 gm fin 287			
Bar. Press. "Hg	30.20	Stack Temp.	380	Silica gel: tare 713.5 fin 722.5			
Static Press. "H_2O	-.80	Ref. Δ P	1.25				

5-22-84

Port	Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head Δ P, in. H_2O	Orifice Δ H in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac. in. Hg
1	1	0	223.132	0.77	1.10	378	69	68	225	55	1
	2	2 30	224.9	0.85	1.20	382	73	69	225	55	1
	3	5 00	226.3	0.20	1.75	388	75	69	225	55	2
	4	7 30	228.2	1.40	2.05	386	79	69	225	55	2
	5	10 00	230.2	0.78	1.10	383	82	69	225	55	1
	6	12 30	231.8	1.00	1.45	379	83	70	225	55	1
2	1	15/0	232.392	0.82	1.20	378	85	71	225	55	1
	2	2 30	235.2	0.93	1.35	389	85	71	225	55	1
	3	5 00	236.6	0.86	1.25	389	86	72	225	55	1
	4	7 30	238.3	1.25	1.85	382	88	72	225	55	2
	5	10 00	240.2	1.25	1.85	382	90	73	225	55	2
	6	12 30	242.2	1.35	2.00	381	92	74	225	55	2
3	1	30/0	244.142	0.98	1.45	387	92	75	225	55	1
	2	2 30	245.9	0.91	1.30	392	91	75	225	55	1
	3	5 00	247.6	0.72	1.05	392	92	76	225	55	1
	4	7 30	249.1	0.70	1.00	388	91	77	225	55	1
	5	10 00	250.4	0.97	1.40	379	92	77	225	55	2
	6	12 30	252.3	0.80	1.15	378	92	77	225	55	1
4	1	45/0	253.811	0.50	0.71	375	90	77	230	55	1
	2	2 30	255.2	0.15	0.20	387	89	78	240	60	1
	3	5 00	255.9	0.15	0.20	388	87	77	240	60	1
	4	7 30	256.7	0.21	0.29	384	87	78	240	60	1
	5	10 00	257.8	0.21	0.29	385	86	78	240	60	1
	6	12 30	258.4	0.05	0.07	385	85	78	240	60	1
END		60/0	258.703								

Leak check: 0.004 cfm @ 5" Hg

	35.571	0.8453	1.1358	384.21	85.89	-3.75	79.81

Environmental Monitoring Laboratories

Plant Hercules
Sampling Location No. 2 Boiler
Test For Particulate
Test Operators Russell

RUN No. 2
Date 5-22-84
Time start 1029 end 1130

GFW 5-22-84

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No	Minutes/Pt.	2.5	CO_2	6.5		
Probe/Pitot	S'SS	NOMOGRAPH		O_2	14.0		
Pitot Cp	.84	ΔH@	1.61	CO	—		
Nozzle Dia.	.228	Meter Temp.	86	Time			
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	70	C-Factor	0.83	tare 200 ml	fin 279		
Bar. Press. "Hg	30.20	Stack Temp.	390	Silica gel:			
Static Press. "H_2O	-.70	Ref. ΔP	1.25	tare ~~380~~ 692.0	fin 703		

Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	0	259.132	0.68	0.97	378	74	74	230	55	1
2	230	260.7	0.89	1.30	380	78	75	230	55	2
3	500	263.0	1.30	1.90	380	85	76	230	55	2
4	730	264.4	1.35	2.00	375	87	77	235	50	3
5	1000	266.5	0.80	1.15	372	91	78	235	50	2
6	1230	268.0	1.20	1.75	371	92	78	235	50	3
1	15/0	269.793	0.85	1.25	376	93	80	250	60	3
2	230	271.6	0.96	1.40	385	94	79	250	60	3
3	500	273.3	1.00	1.45	384	95	80	250	60	3
4	730	275.1	1.20	1.75	380	96	81	250	60	3
5	1000	276.9	1.26	1.80	376	98	81	250	60	3
6	1230	279.0	1.35	2.00	377	99	82	250	60	4
1	30/0	280.900	0.95	1.45	381	98	82	250	60	4
2	230	283.0	0.98	1.30	384	98	84	250	60	4
3	500	284.8	0.77	1.10	381	99	85	250	60	2
4	730	286.0	0.57	0.80	380	98	84	250	60	1
5	1000	287.5	0.97	1.40	380	99	85	250	60	1
6	1230	289.3	0.84	1.20	381	101	86	250	60	2
1	45/0	290.846	0.34	0.48	373	99	86	250	60	1
2	230	292.0	0.10	0.14	380	97	87	250	60	1
3	500	292.6	0.12	0.15	380	99	87	250	60	1
4	730	293.1	0.12	0.15	379	94	87	250	60	1
5	1000	293.9	0.12	0.15	379	93	86	250	60	1
6	1230	294.5	0.05	0.07	377	92	86	250	60	1
END	60/15	294.848								
		Leak check: 0.007 cfm @ 6" Hg								
						93.71	81.92			
		315.716	0.8306	1.1247	378.71					

87.81

Plant Hercules
Sampling Location No. 2 Boiler
Test For Particulate
Test Operators Russell / Little BPC - Jesse Thompson

RUN No. 3
Date 5-22-84
Time start 1153 end 1254

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	7.0		
Probe/Pitot	S'ss	NOMOGRAPH		O_2	14.0		
Pitot Cp	.84	ΔH@	1.61	CO	—		
Nozzle Dia.	.228	Meter Temp.	85	Time			
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	70	C-Factor	.83	tare 200ml fin 279			
Bar. Press. "Hg	30.20	Stack Temp.	390	Silica gel:			
Static Press. "H_2O	-.70	Ref. ΔP	1.25	tare 756.0g fin 768.0			

5-22-84

Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	0	295.059	0.70	1.00	370	78	79	325	60	1
2	230	296.4	0.96	1.40	379	82	80	225	55	1
3	500	298.0	1.35	2.00	382	87	80	225	55	2
4	730	300.0	1.45	2.10	375	93	82	225	55	2
5	1000	302.1	0.80	1.15	373	95	84	225	55	1
6	1230	303.7	0.98	1.40	375	98	82	225	55	1
1	15/0	305.485	0.86	1.25	383	97	84	225	65	1
2	230	307.1	0.97	1.40	393	98	85	230	60	1
3	500	308.8	0.90	1.30	390	99	86	230	66	1
4	730	310.7	1.10	1.60	390	99	86	230	60	2
5	1000	312.4	1.20	1.80	384	101	86	230	60	2
6	1230	314.3	1.40	2.05	379	102	87	230	60	2
1	30/0	316.391	0.97	1.40	378	103	86	230	60	1
2	230	318.1	0.89	1.25	364	99	87	230	60	1
3	500	319.8	0.71	1.00	389	97	87	230	60	1
4	730	321.5	0.56	0.80	387	97	87	250	55	1
5	1000	322.8	0.95	1.40	388	97	88	250	55	1
6	1230	324.6	.76 0.86	1.10	385	97	87	250	55	1
1	45/0	326.229	0.38	0.54	377	95	87	250	55	1
2	230	327.5	0.14	0.19	383	94	87	250	55	1
3	500	328.3	0.14	0.19	387	94	87	250	55	1
4	730	329.1	0.14	0.19	386	93	87	250	55	1
5	1000	329.5	0.21	0.29	387	93	87	250	55	1
6	1230	330.1	0.05	0.07	387	94	87	254	55	1
	60/15	330.974								

new fuel

leak check 0.003 @ 5" Hg

95.02 90.10

35.1915	0.8351	1,1196	382.96			

Environmental Monitoring Laboratories

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules Boiler No. 2

DATE TAKEN: 5-22-84 DATE ANALYZED: 5-24-84

SAMPLES DELIVERED BY: DGR RECEIVED BY: DGR

ANALYZED BY: DGR

Filter treatment: _____

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1090	1091	1092
Tare wt., g	0.5353	0.5321	0.5287
Final wt., g	0.6209	0.6153	0.6248
Net gain, g	0.0856	0.0832	0.0961

Probe wash treatment: _____

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	Herc 2R1	Herc 2R2	Herc 2R3	—
Volume intact?	✓	✓	✓	—
Volume, ml	190	190	180	200
Tare wt., g	112.7415	105.6946	103.2235	
Final wt., g	112.8215	105.7681	103.3010	
Net gain, g	0.0800	0.0735	0.0775	0.0000
Less blank, g	—	—	—	—

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	165.6	156.7	173.6

Plant Hercules
Sampling Location Boiler No. 3
Test For Particulate
Test Operators Russell

RUN No. 1
Date 5-8-84
Time start 0934 end 1036

Meter Box	PAC	No. Sample Pts.	24	Gas Analysis	Fyrite		
Sample Box	No. 1	Minutes/Pt.	2.5	CO_2	6.5		
Probe/Pitot	5'SS	NOMOGRAPH		O_2	12.5		
Pitot Cp	.84	ΔH@	1.61	CO	—		
Nozzle Dia.	.226	Meter Temp.	85	Time			
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	68	C-Factor	.89	tare 200	fin 282		
Bar. Press. "Hg	30.24	Stack Temp.	360	Silica gel:			
Static Press. "H_2O	neg.	Ref. ΔP	1.1	tare 7400	fin 7520		

Remarks:
.225
.227
.227

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	660.593	0.12	0.18	301	69	68	250	50	1
2	2	2 30	661.3	0.09	0.13	347	71	68	250	50	1
3	3	5 00	661.8	0.12	0.18	361	72	68	250	50	1
4	4	7 30	662.5	0.06	0.09	358	73	67	250	50	1
5	5	10 00	663.1	0.13	0.20	347	79	70	250	55	1
6	6	12 30	663.6	0.13	0.20	347	80	69	250	55	1
7											
2	1	15 00	664.262	0.97	1.60	363	82	71	250	55	2
8	2	2 30	666.2	0.88	1.45	365	91	71	250	55	2
9	3	5 00	667.7	0.88	1.45	367	99	73	250	50	2
10	4	7 30	669.5	0.53	0.85	357	104	74	250	50	2
11	5	10 00	670.9	0.85	1.40	354	107	77	250	50	1
12	6	12 30	672.6	0.99	1.60	352	111	78	250	50	1
13											
3	1	30 00	674.402	0.89	1.45	373	105	79	250	50	1
14	2	2 30	676.1	1.00	1.65	377	103	79	250	50	2
15	3	5 00	678.0	1.70	2.80	374	102	79	250	50	3
16	4	7 30	680.5	1.70	2.80	364	104	78	250	50	3
17	5	10 00	682.8	1.45	2.20	354	106	80	250	50	3
18	6	12 30	685.0	1.70	2.80	355	106	80	250	50	3
19											
4	1	45 00	687.381	0.88	1.45	373	104	81	250	50	2
20	2	2 30	689.1	0.60	0.95	373	100	80	250	50	1
21	3	5 00	690.7	0.60	1.70	375	100	80	250	50	3
22	4	7 30	692.6	1.80	3.00	362	103	81	250	60	4
23	5	10 00	695.1	0.86	1.40	352	104	81	250	65	2
24	6	12 30	696.8	0.99	1.60	349	103	81	250	65	2
25	END	60 15	698.541								
26											
27			Leak check 0.005 cfm @ 5" Hg								
28											
29											
30							94.92	79.58			
31											
32			37.948	.8652	1.3804	358.33		85.25			

Environmental Monitoring Laboratories

Plant Hercules
Sampling Location Boiler No. 3
Test For Particulate
Test Operators Russell

RUN No. 2
Date 5-8-84
Time start 1107 end 1210

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		Remarks:
Sample Box	No. 2	Minutes/Pt.	2.5	CO_2	8.0		
Probe/Pitot	5'SS	NOMOGRAPH		O_2	13.0		
Pitot Cp	.84	ΔH@	1.61	CO	–		
Nozzle Dia.	.226	Meter Temp.	90	Time			
Filter No.		% H_2O	9	Condensate:			
Amb. Temp. °F	62	C-Factor	.89	tare	2.00	fin 280	
Bar. Press. "Hg	30.24	Stack Temp.	325	Silica gel:			
Static Press. "H_2O	neg	Ref. ΔP	1.15	tare	699.0	fin 707.5	

Port	Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	698.791	0.11	0.16	354	82	78	225	55	1
	2	230	699.4	0.10	0.15	354	84	80	225	50	1
	3	500	700.0	0.13	0.19	360	87	82	225	50	1
	4	730	700.8	0.05	0.09	358	88	82	225	50	1
	5	1000	701.2	0.18	0.17	353	88	82	225	50	1
	6	1230	701.9	0.13	0.19	355	91	82	225	50	1
2	1	1510	702.509	0.92	1.45	378	93	82	225	50	2
	2	230	704.3	0.84	1.30	382	98	83	225	50	2
	3	500	706.2	0.81	1.30	377	103	84	225	50	2
	4	730	708.0	0.80	1.25	368	106	84	225	50	2
	5	1000	709.5	1.7 ΔP 0.20	1.90	362	108	85	225	50	2
	6	1230	711.3	1.50	2.40	363	113	87	225	50	2
3	1	2010	713.131	0.85	1.35	382	111	86	225	50	2
	2	230	714.8	0.99	1.60	389	109	87	225	50	2
	3	500	716.6	1.7 ΔP 1.70	2.80	384	109	87	225	45	4
	4	730	719.0	1.60	2.60	373	112	87	225	45	4
	5	1000	721.0	1.50	2.40	364	113	88	225	45	4
	6	1230	723.8	1.35	2.20	362	114	88	225	50	3
4	1	4510	725.700	0.59	0.91	378	108	87	250	50	2
	2	230	727.1	0.69	1.05	376	105	88	250	50	2
	3	500	728.6	1.75 ΔP 0.75	2.90	376	106	87	250	50	2
	4	730	731.0	1.70	2.80	361	108	87	250	50	2
	5	1003	733.5	0.88	1.40	354	109	87	250	50	3
	6	1230	735.3	0.87	1.40	356	107	86	250	50	2
END			736.989								
							102.17	84.83			
			38.198	0.8713	1.4159	367.46					

Leak check 0.002 @ 5" Hg

93.50

Environmental Monitoring Laboratories

Plant Hercules
Sampling Location Baila No. 3
Test For Particulate
Test Operators Rinson

RUN No. 3
Date 5-8-84
Time start 1341 end 1450

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite		Remarks:
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	7.5		
Probe/Pitot	5'SS			O_2	13.0		40-50K #
Pitot Cp	.84	NOMOGRAPH		CO	—		57cm/hr.
Nozzle Dia.	.226	ΔH@	1.61	Time			
Filter No.		Meter Temp.	95				
		% H_2O	11	Condensate:			
Amb. Temp. °F	65	C-Factor	.85	tare 200 ml	fin 260 ml		
Bar. Press. "Hg	30.24	Stack Temp.	375	Silica gel:			
Static Press. "H_2O	neg.	Ref. ΔP	1.2	tare 755.0 g	fin 765.0 g		

	Port	Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	1	0	737.115	0.11	0.15	359	79	75	250	60	1
2		2	2 30	737.8	0.11	0.15	361	81	79	250	50	1
3		3	5 00	738.4	0.09	0.13	359	84	79	250	50	1
4		4	7 30	739.0	0.05	0.07	351	83	79	250	50	1
5		5	10 00	739.4	0.07	0.10	345	85	79	250	50	1
6		6	12 30	739.9	0.05	0.07	344	85	80	250	50	1
7												
8	2	1	15/0	740.308	0.95	1.45	362	88	82	250	50	1
9		2	2 30	742.2	0.84	1.30	368	95	83	250	50	1
10		3	5 00	743.9	0.93	1.45	366	99	83	250	50	1
11		4	7 30	745.5	0.73	1.15	356	94	84	230	50	1
12		5	10 00	747.1	1.20	1.90	348	96	84	230	50	1
13		6	12 30	748.9	1.40	2.20	351	100	85	240	50	1
14												
15	3	1	30/0	751.022	0.93	1.45	367	101	84	240	50	1
16		2	2 30	752.8	0.99	1.60	375	100	87	240	50	1
17		3	5 00	754.5	1.3 0.30	2.10	371	102	87	240	50	1
18		4	7 30	757.0	1.60	2.60	357	106	88	240	50	1
19		5	10 00	758.8	1.50	2.40	354	108	89	240	50	2
20		6	12 30	761.0	1.50	2.40	355	110	89	250	55	2
21												
22	4	1	45/0	763.158	0.66	1.05	374	109	90	250	55	2
23		2	2 30	764.8	0.92	1.45	375	108	90	250	55	1
24		3	5 00	766.4	1.70 0.75	2.90	374	109	90	250	55	3
25		4	7 30	768.8	1.65	2.70	363	112	91	250	55	3
26		5	10 00	771.2	0.84	1.30	360	113	91	250	55	2
27		6	12 30	773.1	1.00	1.60	358	113	91	250	55	2
28	END		60/15	774.736								

lost over.

Leak check 0.005 cfm @ 6" Hg

				37.621	0.8655	13.842	360.33	97.92	85.13			

91.52

Environmental Monitoring Laboratories

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules, Boiler No. 3

DATE TAKEN: May 8, 1984 DATE ANALYZED: May 10, 11, 1984

SAMPLES DELIVERED BY: DGR RECEIVED BY: DGR

ANALYZED BY: DGR

Filter treatment: 205°C oven 2 hrs, desiccated, weighed to constant wt.

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1076	1077	1078
Tare wt., g	0.5646	0.5540	0.5645
Final wt., g	0.6391	0.6300	0.6493
Net gain, g	0.0745	0.0760	0.0848

Probe wash treatment: acetone evaporated over low heat, cooled, weighed to constant wt

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	HB3-1	HB3-2	HB3-3	—
Volume intact?	✓	✓	✓	—
Volume, ml	150	210	250	
Tare wt., g	(2) 112.7439	(3) 104.7714	(5) 109.7096	
Final wt., g	112.8471	104.8441	109.8205	
Net gain, g	0.1032	0.0727	0.1109	
Less blank, g	0.0000	0.0000		

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	177.7	148.7	195.7

Plant Hercules
Sampling Location Boiler No. 4
Test For Particulate
Test Operators R. Rowell

RUN No. 1
Date 5-8-84
Time start 1530 end 1632

Meter Box	RAC 1	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 1	Minutes/Pt.	2.5	CO_2	4.0		
Probe/Pitot	S.S	NOMOGRAPH		O_2	17.5		
Pitot Cp	.84	ΔH@	1.61	CO	-		
Nozzle Dia.	.226	Meter Temp.	90	Time			
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	68	C-Factor	.85	tare 200 ml	fin 240		
Bar. Press. "Hg	30.24	Stack Temp.	345	Silica gel:			
Static Press. "H_2O	-0.78	Ref. ΔP	1.20	tare 752.0 g	fin 762.0 g		

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	775.029	0.80	1.30	336	77	79	225	60	1
	2	2 30	776.7	0.87	1.35	334	82	81	225	60	1
	3	5 00	778.5	1.20	1.85	342	86	80	225	60	2
	4	7 30	780.6	1.10	1.70	345	92	81	225	50	2
	5	10 00	782.4	0.64	0.97	345	95	81	230	50	1
	6	12 30	784.0	0.83	1.25	344	96	81	230	50	1
2	1	15/0	785.661	1.10	1.70	344	98	80	230	50	2
	2	2 30	787.7	1.30	2.00	345	100	82	240	50	2
	3	5 00	789.7	1.80	2.90	346	103	84	240	50	3
	4	7 30	792.1	1.25	1.95	351	102	83	240	50	2
	5	10 00	794.4	1.20	1.90	354	100	86	240	50	2
	6	12 30	796.3	1.40	2.20	358	100	84	240	50	3
3	1	30/0	798.377	1.00	1.55	349	99	84	245	55	2
	2	2 30	800.2	0.97	1.50	345	98	84	250	55	2
	3	5 00	802.1	1.25	1.95	352	100	84	250	55	3
	4	7 30	804.2	0.87	1.35	352	98	84	250	55	2
	5	10 00	805.8	0.77	1.20	354	98	85	250	55	2
	6	12 30	807.5	1.80	2.90	356	96	85	250	55	4
4	1	45/0	809.862	0.14	0.20	319	95	83	250	55	4
	2	2 30	810.7	0.13	0.18	336	94	84	250	55	1
	3	5 00	811.2	0.32	0.48	348	94	83	250	60	1
	4	7 30	812.4	0.45	0.68	361	96	84	250	65	1
	5	10 00	813.5	0.45	0.68	361	96	85	250	65	1
	6	12 30	815.0	0.35	0.51	361	96	85	250	65	1
		60/15	815.946								

Leak check: 0.003 cfm @ 5" Hg

			40.917	.9208	1.4229	347.42		89.23			

Environmental Monitoring Laboratories

DAH
5/9/84

Plant Hercules
Sampling Location Boiler No. 4
Test For Particulate
Test Operators Rucco II / Little

RUN No. 2
Date 5-9-84
Time start 0744 end 0847

Meter Box	RAC	No. Sample Pts.	24	Gas Analysis	Fyrite	Remarks:	
Sample Box	No. 2	Minutes/Pt.	2.5	CO_2	4.0		
Probe/Pitot	S's	NOMOGRAPH		O_2	16.0		
Pitot Cp	.84	ΔH@	1.61	CO			
Nozzle Dia.	.236	Meter Temp.	75	Time			
Filter No.		% H_2O	10	Condensate:			
Amb. Temp. °F	54	C-Factor	.86	tare 200 fin 250			
Bar. Press. "Hg	30.29	Stack Temp.	360	Silica gel:			
Static Press. "H_2O	-.75	Ref. Δ P	1.20	tare 707.5 fin 718			

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head Δ P, in. H_2O	Orifice Δ H in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	816.111	0.72	1.10	351	56	54	225	45	1
2	2	230	817.7	0.77	1.20	344	59	54	225	45	1
3	5	00	819.1	1.00	1.55	354	63	55	225	45	2
4	7	30	820.9	1.00	1.55	357	69	55	225	45	2
5	10	00	822.6	0.58	0.90	358	73	58	225	45	1
6	12	30	824.1	0.79	1.20	355	77	59	225	45	2
7											
8	2 1	15/0	825.600	0.97	1.50	354	78	60	245	45	2
9	2	230	827.7	1.20	1.90	354	84	62	245	45	3
10	3	500	829.3	1.75	2.70	354	87	62	245	45	4
11	4	730	831.5	1.20	1.85	357	91	64	255	50	3
12	5	1000	833.6	1.15	1.80	365	93	65	260	50	3
13	6	1230	835.4	1.20	1.85	365	92	67	250	50	3
14											
15	3 1	30/0	837.345	1.20	1.85	360	90	68	250	50	3
16	2	230	839.5	0.94	1.45	352	87	69	250	50	2
17	3	500	841.2	1.7 DAH 0.70	2.70	357	87	70	250	50	4
18	4	730	843.6	0.85	1.30	357	89	70	250	50	2
19	5	1000	845.2	0.84	1.30	360	89	71	250	60	2
20	6	1230	847.0	1.70	2.70	365	88	71	250	60	4
21											
22	4 1	45/0	849.130	0.15	0.22	331	87	72	250	60	1
23	2	230	849.9	0.15	0.22	336	85	72	260	60	1
24	3	500	850.6	0.34	0.50	347	82	73	260	60	1
25	4	730	851.7	0.32	0.48	356	84	73	260	60	1
26	5	1000	852.8	0.30	0.45	357	84	73	260	60	1
27	6	1230	853.8	0.20	0.29	358	85	74	250	60	1
28	END	60/15	854.704								
29											
30			Leak Check:	0.002	cfm @	6"Hg					
31											
32											
33											
34							81.33	65.46			
35			38.593	0.8947	1.3567	354.32					

72.54

Plant: Hercules
Sampling Location: Boiler No. 4
Test For: Particulate
Test Operators: Russell / Little

RUN No. 3
Date 5-9-84
Time start 0949 end 1051

Meter Box	RAC-1	No. Sample Pts.	24	Gas Analysis	Fyrite		Remarks:
Sample Box	No. 3	Minutes/Pt.	2.5	CO_2	3.5		
Probe/Pitot	S'SS	NOMOGRAPH		O_2	16.5		
Pitot Cp	.84	ΔH@	1.61	CO			
Nozzle Dia.	.226	Meter Temp.	80	Time			
Filter No.		% H_2O	10	Condensate: tare 200 ml fin 236 ml			
Amb. Temp. °F	68	C-Factor	.86	Silica gel: tare 765.0 g fin 773.0 g			
Bar. Press. "Hg	30.29	Stack Temp.	360				
Static Press. "H_2O	-.70	Ref. ΔP	1.2				

	Port Point	El. Time, Min.	DGM Reading, Ft.³	Velocity Head ΔP, in. H_2O	Orifice ΔH in. H_2O	Stack Temp. °F	Meter Temp., °F In	Meter Temp., °F Out	Oven Temp. °F	Imp. Temp. °F	Vac in. Hg
1	1	0	856.654	0.67	1.00	341	72	70	225	55	1
2	2	230	858.2	0.80	1.20	337	75	71	225	50	1
3	3	500	859.9	0.99	1.50	334	78	72	225	50	1
4	4	730	861.7	0.99	1.50	336	81	72	225	50	1
5	5	1000	863.5	0.65	1.00	338	83	73	225	50	1
6	6	1230	865.1	0.74	1.15	338	84	73	225	50	1
7											
8	1	1510	866.440	1.10	1.70	337	84	73	235	55	1
9	2	230	868.6	1.20	1.90	339	87	74	235	55	1
10	3	500	870.4	1.65	2.60	338	89	76	240	55	2
11	4	730	872.5	1.10	1.70	347	92	75	240	55	1
12	5	1000	874.6	1.25	1.95	353	93	77	245	55	1
13	6	1230	876.6	1.30	2.00	354	93	77	245	55	2
14											
15	1	1510	878.381	1.15	1.80	351	93	78	250	55	2
16	2	230	880.5	0.88	1.35	335	94	78	250	55	1
17	3	500	882.2	1.65	2.60	337	93	79	250	55	2
18	4	730	884.7	0.93	1.40	337	95	79	250	50	1
19	5	1000	886.3	0.97	1.50	339	95	80	250	50	1
20	6	1230	888.1	1.70	2.70	341	95	80	250	55	2
21											
22	1	1510	890.401	0.15	0.22	321	97	81	250	55	1
23	2	230	891.1	0.10	0.14	329	92	82	250	55	1
24	3	500	891.9	0.30	0.45	340	91	83	250	55	1
25	4	730	892.8	0.16	0.23	339	91	83	250	55	1
26	5	1000	893.6	0.17	0.24	339	90	83	250	55	1
27	6	1230	894.5	0.15	0.22	336	89	83	250	55	1
28	END	1510	895.126								
29											
30			Leak check 0.006 @ 6" Hg								
31											
32											
33							88	77			
34											
35			38.472	0.8793	1.3354	338.75		82.87			

PARTICULATE CATCH ANALYSIS:

SAMPLES: Hercules, Boiler No. 4

DATE TAKEN: May 8, 9, 1984 DATE ANALYZED: May 10, 11, 1984

SAMPLES DELIVERED BY: DGR RECEIVED BY: DGR

ANALYZED BY: DGR

Filter treatment: 205°C over 2hrs, cooled in desiccator, weighed to constant wt.

FILTERS:	RUN 1	Run 2	Run 3
Filter No.	1079	1082	1083
Tare wt., g	0.5690	0.5227	0.5258
Final wt., g	0.6941	0.6012	0.5645
Net gain, g	0.1251	0.0785	0.0387

Probe wash treatment: Acetone evaporated over boiling water bath

PROBE WASH:	Run 1	Run 2	Run 3	Blank
Container ID	HB4-1	HB4-2	HB4-3	—
Volume intact?	✓	✓	✓	—
Volume, ml	210	160	205	200
Tare wt., g	(6) 114.8371	(7) 110.1026	(8) 111.5628	
Final wt., g	114.9543	110.1480	111.6402	
Net gain, g	0.1172	0.0454	0.0774	0.0000
Less blank, g	0.0000	0.0000	0.0000	—

PARTICULATE COLLECTED:	Run 1	Run 2	Run 3
Net gains less blank, mg	242.3	123.9	116.1

DRY GAS METER CALIBRATION

Meter I.D. 591349 RAC Date 4-16-84

Calibration Method DGM-OGA Bell Prover By DGR

Calibration Meter I.D. 651729 y = 1.00

Barometric Pressure 29.81

Previous use: Initial calibration following overhaul on 4-16-84

Vac in. Hg	DH in. H_2O	Time min.	Calibrating Meter Vi cf	Calibrating Meter Vf cf	Calibrating Meter Temp °F	Field Meter Vi cf	Field Meter Vf cf	Field Meter Temp °F In	Field Meter Temp °F out	Y
1	0.5	15	429.267	435.799	68	636.855	643.534	84 · 96	71 · 71	.9999
1	0.75	15	435.799	443.676	68	643.534	651.653	93 · 106	71 · 74	1.0014
1	1.00	15	443.676	452.711	67	651.653	660.899	70 · 97	70 · 70	0.9928
1	1.50	15	452.711	463.338	67	660.899	671.806	98 · 113	70 · 73	1.0103
1	2.80	15	463.338	477.931	68	671.806	686.806	111 · 124	73 · 78	1.0183
								·	Avg =	1.0045
								·	± Y =	1.00
								·	·	

$$Y = [(Vcal)(Pbar)(Tdgm)]/[(Vdgm)(Pm)(Tcal)]$$

Where:

Y = Meter correction factor

Vcal = Volume of gas through calibrating meter, $ft.^3$

Vdgm = Volume of gas through field dry gas meter, $ft.^3$

Pbar = Barometric pressure, in. Hg

Pm = Meter pressure, {Pbar+DH/13.6}, in. Hg

Tdgm = Average Dry gas meter temp., ^oR

Tcal = Temperature of gas through calibrating meter, ^oR

DRY GAS METER CALIBRATION

Meter I.D. RAC 1 591349 Date 9-10-84

Calibration Method DGm/DGm By DGR

Calibration Meter I.D. 651729

Barometric Pressure 30.07

Previous use: Hercules Boiler 3, 4, 1 .. May 8 & 9, 1984

Vac in. Hg	DH in. H_2O	Time min.	Calibrating Meter Vi cf	Calibrating Meter Vf cf	Calibrating Meter Temp °F	Field Meter Vi cf	Field Meter Vf cf	Field Meter Temp °F in	Field Meter Temp °F out	Y
3	0.75	15	655.395	663.202	74	004.816	012.983	95·113	92·91	.9966
3	1.20	15	663.202	672.444	74	012.983	022.653	113·105	91·85	1.0004
3	1.80	17	672.444	685.453	70	022.653	036.148	105·109	83·82	1.0046
								·	Adj=	1.0005
								·	·Y=	1.00
								·	·	
								·	·	
								·	·	

$$Y = [(Vcal)(Pbar)(Tdgm)]/[(Vdgm)(Pm)(Tcal)]$$

Where:

Y = Meter correction factor

Vcal = Volume of gas through calibrating meter, $ft.^3$

Vdgm = Volume of gas through field dry gas meter, $ft.^3$

Pbar = Barometric pressure, in. Hg

Pm = Meter pressure, {Pbar+DH/13.6}, in. Hg

Tdgm = Average Dry gas meter temp., ^oR

Tcal = Temperature of gas through calibrating meter, ^oR

DRY GAS METER CALIBRATION

Meter I.D. SS 1349 Date 5-22-84

Calibration Method D6m - D6m By DGR

Calibration Meter I.D. 651729 D.6M 1.00

Barometric Pressure 30.20

Previous use: Hercules Boiler No. 2 5-22-84

Vac in. Hg	DH in. H_2O	Time min.	Calibrating Meter Vi cf	Calibrating Meter Vf cf	Calibrating Meter Temp °F	Field Meter Vi cf	Field Meter Vf cf	Field Meter Temp °F in	Field Meter Temp °F out	Y
2	1.0	16	685.455	694.977	71	334.049	344.068	99·104	94·85	.9918
2	1.7	15	694.977	706.258	71	344.068	355.794	100·106	81·79	.9951
2	0.9	15	706.258	714.674	70	355.794	364.563	104·109	78·79	.9983
								·	Avg	.9951
								·	Y=	1.004
								·	·	
								·	·	
								·	·	

$$Y = [(Vcal)(Pbar)(Tdgm)]/[(Vdgm)(Pm)(Tcal)]$$

Where:

Y = Meter correction factor

Vcal = Volume of gas through calibrating meter, $ft.^3$

Vdgm = Volume of gas through field dry gas meter, $ft.^3$

Pbar = Barometric pressure, in. Hg

Pm = Meter pressure, {Pbar+DH/13.6}, in. Hg

Tdgm = Average Dry gas meter temp., ^oR

Tcal = Temperature of gas through calibrating meter, ^oR

THERMOMETER CALIBRATION

Date: 5-22-84 By: DER

Calibrating Themometer ASTM mercury in glass 20-760°F

Field Thermometer I.D.		Temp. Source	Mercury Therm. °F	Field Therm. °F	Accuracy	Avg.
5' T'couple w/Omega Digital	1	Table	366	362	100	
	2	Furnace				
	3					
	4					
Meter in T'couple Omega	1	Room	74	74	100	
	2					
	3					
	4					
Met out T'couple Omega	1	Room	74	74	100	
	2					
	3					
	4					
Sample Box Dial Metallic	1	Sample Box	230	225	99	
	2					
	3					
	4					
Impinger outlet Dial Bimetallic	1	Room	74	70	99	
	2					
	3					
	4					
	1					
	2					
	3					
	4					

Visible Emissions Evaluation Record

Plant Name: Hercules Inc.

Address: West 7th St.

City: Hattiesburg Miss

Emission Point: 010

Date: 5-22-84

Is emission point operation normal ? _____

V. E. Observer: Bobbie Draughn

Certification Expiration: 10-19-84


Set No.	Time Start	Time End	Opacity Sum	Opacity Average
1	9 33 Am	9 39 Am	250	10.4
2	9 39 Am	9 45 Am	210	8.8
3	9 45 Am	9 51 Am	275	11.5

Overall Average: 10.2

	Initial	Final
Distance to discharge	2 Lengths	
Direction to discharge	N	
Height of observation point	Ground	
Height of discharge	225 ft.	
Plume color	Gray	
Plume background	Gray Sky	
Water vapor in plume ?		
Wind direction (from)	SE	
Wind speed	10 mph	
Ambient temperature	66°	
Discharge temperature		
Sky conditions	Cloudy	

Min.	Seconds 0	15	30	45
0	10	15	15	10
1	10	10	10	10
2	10	10	10	10
3	10	10	10	10
4	10	10	10	10
5	10	10	10	10
0	10	10	10	10
1	10	10	10	10
2	10	10	5	5
3	10	10	10	10
4	5	5	10	10
5	5	10	5	10
0	10	10	15	15
1	20	20	25	25
2	10	10	15	15
3	10	10	10	10
4	10	5	5	5
5	5	5	5	5

Diagram Of Observation/Discharge Point



Remarks: _____

Received By: _____

Visible Emissions Evaluation Record

Plant Name: Hercules Inc.

Address: West 7th St.

City: Hattiesburg Miss.

Emission Point: 009

Date: 5-22-84

Is emission point operation normal ? _____

V. E. Observer: Bobbie Draughn

Certification Expiration: 10-19-84


Set No.	Time		Opacity	
	Start	End	Sum	Average
1	9^33 Am	9^39 Am	355	14.8
2	9^39 Am	9^45 Am	475	19.8
3	9^45 Am	9^51 Am	430	17.9

Overall Average: 17.5

	Initial	Final
Distance to discharge	2 Lengths	
Direction to discharge	N	
Height of observation point	Ground	
Height of discharge	200 ft.	
Plume color	Gray	
Plume background	Gray Sky	
Water vapor in plume ?		
Wind direction (from)	SE	
Wind speed	10 mph	
Ambient temperature	66°	
Discharge temperature		
Sky conditions	Cloudy	

Min.	Seconds 0	15	30	45
0	10	15	15	15
1	20	15	15	15
2	15	15	15	15
3	15	15	10	10
4	15	15	20	15
5	15	15	15	15
0	15	15	15	15
1	15	15	15	15
2	15	15	15	15
3	20	25	25	25
4	25	25	25	25
5	25	25	25	25
0	25	25	25	25
1	20	20	20	20
2	20	20	20	20
3	15	15	15	15
4	15	15	10	15
5	15	15	10	15

Diagram Of Observation/Discharge Point



Remarks: _____

Received By: _____

-48
Rev. 5/17/82

BOILER ROOM LOG SHEET

Date 5-22-82

ITEM		7-3 SHIFT
Cleaned fires No. 1 Boiler	Started	11:00
	Stopped	12:30
Cleaned fires No. 2 Boiler START	Started	2:00
	Stopped	3:00
Cleaned fires No. 3 Boiler	Started	3:30
	Stopped	10:00
Cleaned fires No. 4 Boiler	Started	X
	Stopped	X
Checked Fly Ash Hoppers	No. 1 Boiler	
	No. 2 Boiler	
	No. 3 Boiler	
	No. 4 Boiler	X
Residue Received - Gal.		

	No. 1	No. 2	No. 3	No. 4
Residue Burned - Boilers	✓		✓	
#6 Oil Burned - Boilers				

Residue Remaining In S-89 _____ (M Gal.).

Comments:

METER READINGS

Unit	Start	End	Diff.
#1	79937		
#2	68807		
#3	98736		
#4	X	X	
#5	X	X	
Tet. Gas	234111		
#5 Gas	X	X	
#5 Oil	X	X	
N.	36707		
S.	95087		
Total			

PERSONNEL

Fireman Lois Tim
#1 Ash Roller Smith
#2 Ash Roller McCollum
Fuel House House
#2 Helper Jackson

7-3 Start 6 AM - End 2 PM)
3-11 Start 2 PM - End 10 PM) Read meters at these times
11-7 Start 10 PM - End 6 AM)

OPACITY EVALUATION - WOOD BURNING BOILERS

Date 5-22-84

Boiler No. 1			Boiler No. 2			Boiler No. 3			Boiler No. 4		
Time	Duration	Note	Time	Duration	Note	Time	Duration	Note	Time	Duration	Note
						7:50	5 Min	4			

NOTES:

1. Load change.
2. Fuel oil adjustment.
3. Cleaning furnace.
4. Meter defect.
5. Cleaning meter lenses.

M = Minutes

HERCULES

Visible Emissions Evaluation Record

Plant Name: Hercules Inc

Address: West 7th St

City: Hi'bng Miss

Emission Point: 010

Date: 5-9-84

Is emission point operation normal ? _____

V. E. Observer: Bobbie Draughn

Certification Expiration: _____


Set No.	Time		Opacity	
	Start	End	Sum	Average
1	1 55 pm	2 01 pm	300	12.5
2	2 01 pm	2 07 pm	295	12.3
3	2 07 pm	2 13 pm	230	9.6

Overall Average: 11.5

	Initial	Final
Distance to discharge	2 Lengths	
Direction to discharge	N	
Height of observation point	Ground	
Height of discharge	225 ft	
Plume color	Gray	
Plume background	Blue Sky	
Water vapor in plume ?		
Wind direction (from)	NW	
Wind speed	10-20 mph	
Ambient temperature	77°	
Discharge temperature		
Sky conditions	Clear	

	Seconds			
Min.	0	15	30	45
0	10	10	10	10
1	10	10	10	10
2	10	10	15	10
3	10	15	15	15
4	15	15	15	15
5	15	15	15	15
0	15	10	15	10
1	15	15	10	15
2	15	15	15	15
3	15	15	15	15
4	15	10	10	10
5	5	5	5	10
0	10	10	10	10
1	10	15	15	10
2	15	15	15	10
3	10	15	10	10
4	5	5	5	5
5	5	5	5	5

Diagram Of Observation/Discharge Point



Remarks: _____

Received By: _____

HERCULES

Visible Emissions Evaluation Record

Plant Name: Hercules Inc

Address: West 7th St

City: Hattiesburg Miss

Emission Point: 009

Date: 5-9-84

Is emission point operation normal ? _____

V. E. Observer: Bobbie Draughon


Certification Expiration: _____

Set No.	Time		Opacity	
	Start	End	Sum	Average
1	1 55 PM	2 01 PM	310	12.9
2	2 01 PM	2 07 PM	365	15.2
3	2 07 PM	2 13 PM	350	14.6

Overall Average: 14.2

	Initial	Final
Distance to discharge	2 Lengths	
Direction to discharge	N	
Height of observation point	Ground	
Height of discharge	200 ft.	
Plume color	Gray	
Plume background	Blue Sky	
Water vapor in plume ?		
Wind direction (from)	NW	
Wind speed	10-20 mph	
Ambient temperature	77°	
Discharge temperature		
Sky conditions	Clear	

Diagram Of Observation/Discharge Point



Min.	Seconds 0	15	30	45
0	10	10	10	10
1	10	15	10	10
2	10	10	15	15
3	10	15	15	15
4	15	15	15	15
5	15	15	15	15
0	15	15	15	15
1	15	15	15	15
2	15	15	15	15
3	20	20	20	20
4	15	15	15	15
5	15	10	10	10
0	10	10	15	15
1	15	20	20	20
2	20	15	20	15
3	15	15	15	15
4	15	15	15	10
5	10	10	10	10

Remarks: _____

Received By: _____

S-48
Rev. 5/17/82

BOILER ROOM LOG SHEET

Date 5-9-84

ITEM			3/11 SHIF
Cleaned fires No. 1 Boiler		Started	8.00
		Stopped	1.00
Cleaned fires No. 2 Boiler	OUT	Started	
		Stopped	
Cleaned fires No. 3 Boiler	START	Started	3.20
		Stopped	4.35
Cleaned fires No. 4 Boiler		Started	5.00
		Stopped	6.05
Checked Fly Ash Hoppers		No. 1 Boiler	
		No. 2 Boiler	
		No. 3 Boiler	
		No. 4 Boiler	
Residue Received - Gal.			

	No. 1	No. 2	No. 3	No. 4
Residue Burned - Boilers				
#6 Oil Burned - Boilers				

Residue Remaining In S-89 _____ (M Gal.). 94% at 2:00 p.m.

Comments:

METER READINGS

Unit	Start	End	Diff.
#1	84847	87294	2447
#2	X		
#3	86083	89461	3378
#4	28128	31288	3160
#5	X		
Tot. Gas	228002	229862	1860
#5 Gas	X		
#5 Oil	X		
N.	36663	36666	3
S.	95036	95037	1
Total			898,500

PERSONNEL

Fireman Stephens
#1 Ash Roller Smith
#2 Ash Roller Travis
Fuel House Tisdale
#2 Helper Gray

7-3 Start 6 AM - End 2 PM)
3-11 Start 2 PM - End 10 PM) Read meters at these times
11-7 Start 10 PM - End 6 AM)

S-48
Rev. 5/17/82

BOILER ROOM LOG SHEET

Date _____

ITEM		SHIFT
Cleaned fires No. 1 Boiler	Started	8 .11
	Stopped	9 .45
Cleaned fires No. 2 Boiler	Started	X
	Stopped	X
Cleaned fires No. 3 Boiler	Started	7 .00
	Stopped	8 .10
Cleaned fires No. 4 Boiler	Started	11 .30
	Stopped	12 .40
Checked Fly Ash Hoppers	No. 1 Boiler	
	No. 2 Boiler	X
	No. 3 Boiler	
	No. 4 Boiler	
Residue Received - Gal.		

	No. 1	No. 2	No. 3	No. 4
Residue Burned - Boilers	0	X	3	0
#6 Oil Burned - Boilers				

Residue Remaining In S-89 _____ (M Gal.). 74%

94% at 2 Pail.

Comments:

METER READINGS

Unit	Start	End	Diff.
#1	81943	84847	2904
#2	X	X	X
#3	82575	86083	3508
#4	25727	28128	2401
#5	X	X	X
Tot. Gas	224355	228002	3647
#5 Gas	X	X	X
#5 Oil	X	X	X
	36663	36663	0
	94030	95036	6
Total			880300

PERSONNEL

Fireman Gilmore
#1 Ash Roller Haines
#2 Ash Roller Mc Donald
Fuel House Russell
#2 Helper W. Jackson

7-3 Start 6 AM - End 2 PM)
3-11 Start 2 PM - End 10 PM)
11-7 Start 10 PM - End 6 AM)

#1 30133
#3 42579
#4 34867

Read meters at these times

TOTAL STEAM 111,579

TOTAL GAS 551

28 Boilers

OPACITY EVALUATION - WOOD BURNING BOILERS

Date 5-9-84

7-5

Boiler No. 1			Boiler No. 2			Boiler No. 3			Boiler No. 4		
Time	Duration	Note	Time	Duration	Note	Time	Duration	Note	Time	Duration	Note
8:15	10 c	1		0			0			0	

NOTES:

1. Load change.
2. Fuel oil adjustment.
3. Cleaning furnace
4. Meter defect.
5. Cleaning meter lenses.

Jackson

OPACITY EVALUATION - WOOD BURNING BOILERS

Date 5-9-84
3/11 SHIFT

Boiler No. 1			Boiler No. 2			Boiler No. 3			Boiler No. 4		
Time	Duration	Note	Time	Duration	Note	Time	Duration	Note	Time	Duration	Note
1 [illegible]	30-S	2				7:21	20-S	2	7:11	20-S	2
						7:58	20-S	2	7:53	30-S	2
						9:13	20-S	2			

NOTES:

1. Load change.
2. Fuel oil adjustment.
3. Cleaning furnace
4. Meter defect.
5. Cleaning meter lenses.

Stephens

HERCULES

Visible Emissions Evaluation Record

Plant Name: Hercules Inc.

Address: West 7th St.

City: Hattiesburg Miss.

Emission Point: 009

Date: 5-8-84

Is emission point operation normal ?

V. E. Observer: Bobbie Draughn


Certification Expiration:

Set No.	Time Start	Time End	Opacity Sum	Opacity Average
1	9^04 Am	9^10 Am	240	10.0
2	9^09 Am	9^15 Am	240	10.0
3	9^16 Am	9^22 Am	240	10.0

Overall Average: 10.0

	Initial	Final
Distance to discharge	2 Lengths.	
Direction to discharge	N	
Height of observation point	Ground	
Height of discharge	200 ft.	
Plume color	Gray	
Plume background	Gray Sky	
Water vapor in plume ?		
Wind direction (from)	W	
Wind speed	5-10 mph	
Ambient temperature	67°	
Discharge temperature		
Sky conditions	Cloudy	

Diagram Of Observation/Discharge Point



Min.	Seconds 0	15	30	45
0	10	10	10	10
1	10	10	10	10
2	10	10	10	10
3	10	10	10	10
4	10	10	10	10
5	10	10	10	10
0	10	10	10	10
1	10	10	10	10
2	10	10	10	10
3	10	10	10	10
4	10	10	10	10
5	10	10	10	10
0	10	10	10	10
1	10	10	10	10
2	10	10	10	10
3	10	10	10	10
4	10	10	10	10
5	10	10	10	10

Remarks:

Received By:

HERCULES

Visible Emissions Evaluation Record

Plant Name: Hercules Inc.

Address: West 7th St.

City: H'burg. Miss

Emission Point: 010

Date: 5-8-84

Is emission point operation normal ? _____

V. E. Observer: Bobbie Draughn

Certification Expiration: _____


Set No.	Time		Opacity	
	Start	End	Sum	Average
1	9⁰⁴ Am	9¹⁰ Am	375	15.6
2	9¹⁰ Am	9¹⁶ Am	405	16.9
3	9¹⁶ Am	9²² Am	460	19.2

Overall Average: 17.2

	Initial	Final
Distance to discharge	2 Lengths	
Direction to discharge	N	
Height of observation point	Ground	
Height of discharge	225 ft.	
Plume color	Gray	
Plume background	Gray Sky	
Water vapor in plume ?		
Wind direction (from)	W	
Wind speed	5-10 mph	
Ambient temperature	67°	
Discharge temperature		
Sky conditions	Cloudy	

Min.	Seconds 0	15	30	45
0	15	15	20	20
1	15	15	15	15
2	15	15	15	15
3	15	15	15	15
4	15	15	20	20
5	15	15	10	15
0	20	15	15	15
1	20	20	15	15
2	15	15	20	15
3	15	20	20	20
4	20	20	15	15
5	15	15	15	15
0	15	15	15	25
1	25	20	20	15
2	15	20	20	15
3	20	20	20	20
4	20	20	15	15
5	20	20	25	25

Diagram Of Observation/Discharge Point



Remarks: _____

Received By: _____

48
ev. 5/17/82

BOILER ROOM LOG SHEET

Date 5-[illegible]-[illegible]

ITEM		SHIFT
Cleaned fires No. 1 Boiler	Started	11.30
	Stopped	1.25
Cleaned fires No. 2 Boiler	Started	
	Stopped	
Cleaned fires No. 3 Boiler	Started	7.25
	Stopped	9.50
Cleaned fires No. 4 Boiler	Started	9.51
	Stopped	10.35
Checked Fly Ash Hoppers	No. 1 Boiler	✓
	No. 2 Boiler	X
	No. 3 Boiler	✓
	No. 4 Boiler	✓
Residue Received - Gal. water & Slate dump in		4500

	No. 1	No. 2	No. 3	No. 4
Residue Burned - Boilers	0	X	0	0
#6 Oil Burned - Boilers				

Residue Remaining In S-89 _____ (M Gal.): 516 at 6 A.M.
94 70 at 2:PM.

Comments:

METER READINGS

Unit	Start	End	Diff.
#1	73907	76853	2946
#2	X	X	
#3	72809	76318	3509
#4	16583	19212	2629
#5	X	X	
Net. Gas	219743	222322	3179
#5 Gas	X	X	
#5 Oil	X	X	
#N	36663	36663	0
	95034	95034	0
Total			

PERSONNEL

Fireman [illegible]
#1 Ash Roller Smith
#2 Ash Roller Travis
Fuel House Horne
#2 Helper Myers

898400

7-3 Start 6 AM - End 2 PM)
3-11 Start 2 PM - End 10 PM)
11-7 Start 10 PM - End 6 AM)

#1 33483
#3 40692
#4 38100

Read meters at these times

TOTAL STEAM 112225

TOTAL GAS 461

S-48
Rev. 5/17/82

BOILER ROOM LOG SHEET

Date 5-8-82

ITEM		3/11 SHIFT
Cleaned fires No. 1 Boiler	Started	7.35
	Stopped	9.05
Cleaned fires No. 2 Boiler	Started	
	Stopped	
Cleaned fires No. 3 Boiler	Started	4
	Stopped	1.35
Cleaned fires No. 4 Boiler	Started	3.20
	Stopped	4.20
Checked Fly Ash Hoppers	No. 1 Boiler	
	No. 2 Boiler	X
	No. 3 Boiler	
	No. 4 Boiler	

	No. 1	No. 2	No. 3	No. 4
Residue Received - Gal.				
Residue Burned - Boilers				
#6 Oil Burned - Boilers				

Residue Remaining In S-89 _____ (M Gal.). 94% at 2:Van.

Comments:

METER READINGS

Unit	Start	End	Diff.
#1	76853	79583	2730
#2	X	X	
#3	76318	79435	3117
#4	19212	22517	3305
#5	X	X	
Tot. Gas	222322	224355	2033
#5 Gas	X	X	
#5 Oil	X	X	
N	36663	36665	0
S	95034	95034	0
Total			

915,200

PERSONNEL

Fireman Stephens
#1 Ash Roller Smith + Price
#2 Ash Roller McDonald
Fuel House Russell
#2 Helper Gray

7-3 Start 6 AM - End 2 PM)
3-11 Start 2 PM - End 10 PM) Read meters at these times
11-7 Start 10 PM - End 6 AM)

OPACITY EVALUATION - WOOD BURNING BOILERS

Date 5-8-84

7-3

Boiler No.			Boiler No. 2			Boiler No. 3			Boiler No. 4		
Time	Duration	Note	Time	Duration	Note	Time	Duration	Note	Time	Duration	Note

NOTES:

1. Load change.
2. Fuel oil adjustment.
3. Cleaning furnace.
4. Meter defect.
5. Cleaning meter lenses.

Jackson

OPACITY EVALUATION - WOOD BURNING BOILERS

Date 5-8-84
3/11

Boiler No. 1			Boiler No. 2			Boiler No. 3			Boiler No. 4		
Time	Duration	Note	Time	Duration	Note	Time	Duration	Note	Time	Duration	Note

NOTES:

1. Load change.
2. Fuel oil adjustment.
3. Cleaning furnace
4. Meter defect.
5. Cleaning meter lenses.

Stephens

HERCULES INCORPORATED

HATTIESBURG, MISSISSIPPI 39401

March 30, 1983

RECEIVED
MAR 31 REC'D
DEPT OF NATURAL RESOURCE
BUREAU OF POLLUTION CONTROL

Bureau of Pollution Control
P. O. Box 10385
Jackson, Mississippi 39209

Attention: Don Watts

Dear Mr. Watts:

Please find the enclosed test results for woodwaste boilers 3 and 4 on March 15 and 16, 1983. These results indicate a particulate concentration of 0.079 grains/dscf for boiler 3 and 0.096 grains/dscf for boiler 4 as compared to an allowable concentration of 0.30 grains/dscf.

If I can answer any questions, please call me.

Very truly yours,

Charles Jordan
Environmental Coordinator

CJ:bs

Enclosure

MODEL INPUT DATA
HERCULES, INC
MULTI-SOURCE CRSTER (ONE YEAR)
Jackson-Jackson 77 or MET DATA
Meridian - Burwood 64 ⇒ 366 * 1
03866 12863
→ MEM SHR 64

not a Leap year Run for 365 days

FIRST IF WORKS

SOUTH STACK

Em Rate = 84.93 #/hr = 10.71 g/sec
Velocity = 32.12 ft/sec = 9.79 m/sec
Diameter = 10 ft = 3.048 m
Temperature = 369 °F = 460.2 °K
Stack Ht = 200 ft = 60.96 m

NORTH STACK

Em Rate = 71.43 #/hr = 9.01 g/sec
Velocity = 31.94 ft/sec = 9.74 m/sec
Diameter = 10 ft = 3.048 m
Temperature = 307 °F = 425.8 °K
Stack Ht = 225 ft = 68.58 m

.3, .5, .7, .9, 1.1

Em Rate St. Height

Q	H	D	V	T	F	Ever.
31-40	41-45	46-50	51-55	56-60	61-70	71-80

FOR SOUTH STACK

① Temp - Avg $T_1 + T_2$

$(373 + 365)/2 = 369°F$

② Vol Flow - Add $(\text{Vol Flow})_1 + (\text{Vol Flow})_2$

$4,320,754 + 4,761,040 = 9,081,794\ ft^3/hr$

③ DIAMETER = 10 ft (given in appl.)

④ St. Ht = 200 ft (given in appl.)

⑤ VEL = Vol Flow / AREA OF STACK OUTLET

$= 9,081,794 / (\pi D^2/4)$

$= 115,633\ ft/hr\ (1hr/60\ min)(1min/60\ sec)$

VEL = 32.12 ft/sec

⑥ Em RATE = $ER_1 + ER_2 = 42.0 + 42.93 = 84.93\ \#/hr$

FOR NORTH STACK

① Temp - Avg $T_3 + T_4$

$(322 + 292)/2 = 307°F$

② Vol Flow - Add $(\text{Vol Flow})_3 + (\text{Vol Flow})_4$

$4,339,692 + 4,692,132 = 9,031,824\ ft^3/hr$

③ DIAMETER = 10 ft (given in appl)

④ St. Ht = 225 ft (given in appl)

⑤ VEL = Vol Flow / AREA

$= 9,031,824 / [\pi(10)^2/4]$

$= 114,997\ ft/hr\ (1hr/3600\ sec)$

VEL = 31.94 ft/sec

⑥ Em RATE = $ER_3 + ER_4 = 30.08 + 41.35 = 71.43\ \#/hr$

Stack Test 10/25/82 Boiler No.1

Em Rate 42.0 #/hr

Vel 60.40 ft/sec

Vol Flow 4,320,754 ft^3/hr

2,541,367 dscf/hr

Temp 373 °F

Stack Test 10/26/82 Boiler No.2

Em Rate 42.93 #/hr

Vel 61.95 ft/sec

Vol Flow 4,761,040 ft^3/hr

2,867,191 dscf/hr

Temp 365 °F

Stack Test 3/16/83 Boiler No. 3

Em Rate 30.08 #/hr

Vel 56.47 ft/sec

Vol Flow 4,339,692 ft^3/hr

2,676,248 dscf/hr

Temp 322 °F

Stack Test 3/15/83 Boiler No. 4

Em Rate 41.35 #/hr

Vel 61.06 ft/sec

Vol Flow 4,692,132 ft^3/hr

3,037,676 dscf/hr

Temp 292 °F

#1 & 2 - 200 ~~ft~~	378°	4.6'	62.8 fps	60.3 #/hr
#3 & 4 225 ~~ft~~	400°	10'	13.6 fps	69.1 #/hr

×

LAST APPL

009
#1 & #2
Combined

St Ht - 200 ft
DIA 10 ft
Vel 13.6 ft/sec
Temp 400°F

#3 & 4

St. Ht 225 ft
DIA 10 ft
Vel 13.6 ft/sec
Temp 400°F

REPORT OF
PARTICULATE EMISSIONS TESTS

HERCULES, INC.
WOODWASTE BOILERS - No. 3 and No. 4

HATTIESBURG, MISSISSIPPI
MARCH 15 and 16, 1983

Performed By:
Environmental Monitoring Laboratories, Inc.
Ridgeland, Mississippi

ENVIRONMENTAL MONITORING LABORATORIES, INC.

P.O. Box 655 • 224-B Highway 51 North
Ridgeland, Mississippi 39157

(601) 856-3092

On March 15 and 16, 1983, Environmental Monitoring Laboratories performed air emissions tests on the No. 3 and the No. 4 woodwaste boilers operated by Hercules, Inc. in Hattiesburg, Mississippi.

The tests were performed to determine if particulate emissions from the boilers are within limits established by Mississippi Air Quality Regulation APC-S-1, Section 3, paragraph 4.(b) - specifically 0.30 grains per dry standard cubic foot.

Following is a report of the emissions tests. Contents are:

1.0 Test Results

2.0 Validity of Results

3.0 Source Operation

4.0 Test Proceedures

5.0 Data Reduction - Boiler No. 3

6.0 Raw Data - Boiler No. 3

7.0 Data Reduction - Boiler No. 4

8.0 Raw Data - Boiler No. 4

1.0 Test Results

1.1 The average particulate emissions from Boiler No. 3 as determined from three separate samples taken on March 16, 1983, is 0.079 grains per dry standard cubic foot.

The table below is a summary of the pertinent results.

Boiler No. 3		Run 1	Run 2	Run 3	Avg.
Particulate conc.	grains/dscf	0.061	0.081	0.094	0.079
Allowable conc.	grains/dscf	0.30	0.30	0.30	0.30
Emission Rate	#/hr	22.76	30.36	37.12	30.08
Allowable Emissions	#/hr	112.51	112.83	118.75	114.70
Velocity	ft/sec	57.33	55.89	56.19	56.47
Volumetric Flowrate	ft^3/hr	4405876	4294808	4318391	4339692
Volumetric Flowrate	dscf/hr	2625348	2632585	2770810	2676248
Stack Temp.	^oF	341	328	298	322

1.2 The average particulate emissions from Boiler No. 4 is determined from three separate samples taken on March 15, 1983, is 0.096 grains per dry standard cubic foot.

The table below is a summary of the pertinent results.

Boiler No. 4		Run 1	Run 2	Run 3	Avg.
Particulate conc.	grains/dscf	0.086	0.116	0.085	0.096
Allowable conc.	grains/dscf	0.30	0.30	0.30	0.30
Emissions Rate	#/hr	34.32	50.20	39.54	41.35
Allowable Emissions	#/hr	120.18	130.11	140.27	130.19
Velocity	ft/sec	60.26	59.97	62.94	61.06
Volumetric Flowrate	ft^3/hr	4630950	4608339	4837107	4692132
Volumetric Flowrate	dscf/hr	2804220	3035895	3272912	3037676
Stack Temp.	^oF	333	271	272	292

2.0 Validity of Results

2.1 Volumetric flowrate values for both tests are within 3% of the mean values. Emission rates vary by less than 25% for the Boiler No. 3 test and by less than 22% for the Boiler No. 4 test.

2.2 Isokinetic variation: Sampling rates for the Boiler No. 3 test were 97%, 98%, and 96% isokinetic for runs 1, 2, and 3 respectively. Sampling rates for the Boiler No. 4 test were 97%, 94%, and 92% isokinetic for runs 1, 2, and 3 respectively.

2.3 Although there were slight deviations from the standard methods for these tests as described in section 4.0, the samples were representative of emissions under the encountered operating conditions and the results should be considered valid.

3.0 Source Operation

Hercules operates four nearly identical woodwaste boilers. The boilers are each capable of using fuel oil and gas although woodwaste is the primary fuel and a fire is maintained at all times with woodwaste.

Because insufficient woodwaste is generated at the facility, additional wood fuel must be purchased. The quality and quantity of the fuel varies.

During the tests the boilers were operated normally at steam production rates of between 50,000 and 60,000 pounds per hour. Fuel used was a mixture of dry and green woodwaste including some pelletized wood fuel. During the second and third runs of the test on Boiler No. 3, the fuel supplied consisted primarily of green chips and shavings.

4.0 Test Proceedures

4.1 Sampling and analytical proceedures used are those described in the Code of Federal Regulations, Title 40, Part 60, Appendix A, specifically Reference Method 5. No substantial deviations from the standard proceedures were taken. Each test was performed in triplicate. Testing was observed by Mr. Jesse Thompson of the Mississippi Bureau of Pollution Control.

4.2 A variation from the standard proceedures was necessary due to physical limitations of the sampling site. Method 5 testing requires that samples be taken from sample points as described in Method 1.

Because the masonry stacks serving the boilers have no sampling platforms, testing ports have been installed on each boiler's exhaust duct (breeching) prior to its entering the stack. One stack serves Boilers 1 and 2 and another serves Boilers 3 and 4. Each boiler's ducts have a rectangular vertical section in which sample ports are installed. Tapering duct sections and fans proceed and preceed the short vertical sections and there is less than the required number of diameter distance from disturbances both downstream and upstream of the portholes. The minimum diameter distances required by Method 1 are 0.5 diamters from the sample ports to the nearest downstream disturbance and 2 diameters from the sample ports to nearest upstream disturbance. These minimum diameter distances dictate that 48 points should be sampled.

The deviation from the standard method for these tests is that sampling was performed as though the minimum distances were met; 48 sample points were used. The test for the absence of cyclonic flow as described in Method 1 indicated that the flow at the sample site is acceptable for each boiler. If the cyclonic flow test had indicated unacceptable flow, sampling was to be done at 50% isokinetic to compensate for a possible negative bias from the cyclonic flow.

5.0 Data Reduction - Boiler No. 3

5.1 Nomenclature

SYMBOL	UNITS	DESCRIPTION
An	ft^2	Nozzle area
As	ft^2	Stack area
Bws	dimensionless	Propor tion by volume of water vapor
Cp	dimensionless	Pitot correction factor
Cs	grams/dscf	Particulate concentration
C's		Particulate concentration
Dn	inches	Nozzle diameter
ΔH	in. H_2O	Pressure drop across meter orifice
ΔP	in. H_2O	Stack velocity pressure head
E	#/hr	Particulate emission rate
E'		Particulate emission rate
Ea	#/hr	Allowable emissions
I	percent	Percent isokinetic sampling
Kp	consistent	Pitot tube constant = 85.49
Mn	mg	Particulate sample weight
Md	#/# mole	Dry molecular wt. of stack gas

5.2 Summary of Data - Boiler No. 3

1.	As	ft^2	21.347
2.	Dn	in.	.228
3.	An	ft^2	2.85×10^{-4}
4.	Cp	--	.86
5.	θ	min.	96
6.	Y	--	0.990

1.	Vm	ft^3	57.510	58.114	59.913
2.	$\sqrt{\Delta P}$, avg.	$(in.\ H_2O)^{\frac{1}{2}}$	0.797	0.785	0.806
3.	ΔH	in. H_2O	1.434	1.440	1.522
4.	Ts	^oR	801.1	788.1	757.5
5.	Tm	^oR	550.7	551.0	550.9
6.	Pbar	in. Hg	29.60	29.60	29.60
7.	Pm	in. Hg	29.71	29.71	29.71
8.	Pg	in. Hg	-.06	-.06	-.06
9.	Ps	in. Hg	29.54	29.54	29.54
10.	Vlc	ml	106	92	87
11.	O_2	%	18	18	18
12.	CO_2	%	3.5	3.5	3.5
13.	N_2+CO	%	78.5	78.5	78.5
14.	Mn	mg	213.3	286.6	343.3
15.					
16.					
17.					

5.3 Calculations - Boiler No. 3

1. Vmstd: Vm Y (Pm/Pstd)(Tstd/Tm)	54.205	54.744	56.449	
2. Vwstd: (.04707 ft^3/ml)Vlc	4.989	4.330	4.095	
3. Bws: Vwstd/(Vwstd+Vmstd)	0.084	0.073	0.068	
4. Md: .44 CO_2+.32 O_2+.28(N_2+CO)	29.28	29.28	29.28	
5. Ms: Md(1-Bws)+18 Bws	28.33	28.45	28.52	
6. Vs: Kp Cp $(\sqrt{\Delta P})\sqrt{Ts/(PsMs)}$	57.33	55.89	56.19	56.47
7. Q: Vs As(3600 sec/hr)	4405876	4294808	4318391	4339692
8. Qstd: Q(1-Bws)(Ps/Pstd)(Tstd/Ts)	2625348	2632585	2770810	2676248
9. Cs: (.001mg/g)(Mn/Vmstd)	.0039	.0052	.0061	
10. E: (1#/454 g)Cs Qstd	22.76	30.36	37.12	30.08
11. C's: (Cs)(15.419 gr/g)	0.061	0.081	0.094	0.079
12. Ea: (0.30 gr/dscf)(Qstd)	112.51	112.83	118.75	114.70
13.				
14.				
15.				
16.				
I: $\frac{100\ Ts\ [.002669\ Vlc + (Vm\ Pm/Tm)]}{60\ \Theta\ Vs\ Ps\ An}$	97.2	97.9	95.9	

6.0 Raw Data - Boiler No. 3

ISOKINETIC PRELIMINARY DATA


Hercules, Inc Hattiesburg, Miss

Wood Waste Boiler No. 3 — Particulate Test 3-16-83

Diameters upstream <1 downstream <1

No. sample points 48 time/pt. 2 Min.

Sketch of Stack:



Pt. No.	% Dia.	inches from wall	Preliminary ΔP 1	α	2	α	3	α	4	α
1		2.4	.14	0	.7	+5	.75	0	.75	+5
2		7.3	.16	0	.89	0	.8	+5	.70	+5
3		12.1	.12	+5	.9	0	.85	0	.50	+5
4		16.5	.10	+5	.86	0	.9	0	.60	+5
5		21.8	.11	+5	.75	+5	.55	0	.48	0
6		26.6	.15	0	.8	+5	.75	0	1.0	0
7		31.4	.15	0	.32	0	1.7	-5	1.8	0
8		36.3	.12	0	.45	-5	1.4	-5	1.5	0
9		41.1	.03	-5	.55	-5	1.1	-5	1.1	-5
10		45.9	.05	-10	.85	-5	1.1	0	.82	-5
11		50.8	.14	-20	1.7	-5	1.4	0	.78	-10
12		55.6	.08	-10	1.7	-5	1.5	0	.84	-10

Avg. α to obtain Null reading = < 5°

Temps acceptable flow conditions exist for Method 5 sampling.

Preliminary Data:

Pbar 29.6

Pg -.8

ΔH@ 1.79

Tm 95

%H_2O 8%

Ts < 300

ΔPavg x.a

ΔPmax 1.7

Dn .228

Nomograph Reference .93

Meter Box I.D. RAC

Probe I.D. S/T - SS

Pitot Cp .84

Box heat set 250

Notes:

Hercules Inc. - Hattiesburg, MS — Date: 3-16-83 — Pbar: 29.6

Woodwaste Boiler No. 3 — Dn .258 — P_g = -.8"

Run No. 1 Particulate Sample — Sample Time/pt. 2 min — Nomog. Ref.

Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250°	Imp Temp <70°	Time	V A C
1	1	562.508	0.08	0.14	324	62	62	✓	✓	9:30A	1
	2	563.0	0.13	0.24	320	64	62	✓	✓	2	1
	3	563.5	0.10	0.18	340	66	62	✓	✓	4	1
	4	564.0	0.08	0.14	360	66	62	✓	✓	6	1
	5	564.4	0.11	0.20	370	67	62	✓	✓	8	1
	6	564.9	0.15	0.28	370	69	61	✓	✓	10	1
	7	565.5	0.14	0.26	355	70	62	✓	✓	12	1
	8	566.1	0.06	0.11	360	72	62	✓	✓	14	1
	9	566.4	0.02	0.04	355	71	62	✓	✓	16	1
	10	566.7	0.36	0.69	355	73	62	✓	✓	18	1
	11	567.5	0.24	0.45	345	74	62	✓	✓	20	1
	12	568.2	0.03	0.05	330	76	63	✓	✓	22	1
2	1	568.498	0.68	1.30	350	81	63	✓	✓	0	2
	2	569.1	0.85	1.65	360	85	64	✓	✓	2	3
	3	571.0	0.85	1.65	370	90	65	✓	✓	4	3
	4	572.4	0.79	1.50	365	96	67	✓	✓	6	3
	5	573.7	0.76	1.45	355	99	67	✓	✓	8	3
	6	574.9	0.90	1.75	355	101	68	✓	✓	10	3
	7	576.4	0.20	0.37	355	99	68	✓	✓	12	2
	8	577.0	0.59	1.10	350	100	68	✓	✓	14	2
	9	578.2	0.62	1.15	355	102	72	✓	✓	16	2
	10	579.4	1.10	2.15	315	104	72	✓	✓	18	4
	11	580.9	1.50	3.00	310	108	72	✓	✓	20	5
	12	582.8	0.95	1.85	315	114	73	✓	✓	22	3
3	1	584.167	0.69	1.30	330	110	77	✓	✓	0	3
	2	585.4	0.77	1.50	330	112	75	✓	✓	2	3
	3	586.8	0.84	1.60	335	111	74	✓	✓	4	3
	4	588.1	0.89	1.70	335	112	76	✓	✓	6	3
	5	589.5	0.62	1.20	340	115	78	✓	✓	8	2
	6	590.7	0.62	1.20	330	111	77	✓	✓	10	2
	7	591.8	1.70	3.40	345	116	78	✓	✓	12	7
	8	593.9	1.30	2.60	340	120	79	✓	✓	14	5
	9	595.5	1.10	2.15	350	120	82	✓	✓	16	5
	10	597.2	1.10	2.15	356	122	82	✓	✓	18	4
	11	598.4	1.30	2.60	335	123	82	✓	✓	20	5
	12	600.4	1.30	2.60	335	125	83	✓	✓	22	5

© WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A.

Hercules

Date: 3-16-83

Woodwaste Boiler No. 3

Run No. 1 Cont'd

	1	2	3	4	5	6		7		8	
	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250	Imp Temp < 70°	Time	V A C
1	4	1	602.197	0.74	1.40	315	115	83	✓	✓	0	3
2		2	603.5	0.82	1.60	315	114	81	✓	✓	2	3
3		3	604.9	0.59	1.15	330	112	81	✓	✓	4	3
4		4	606.1	0.47	0.89	325	111	82	✓	✓	6	2
5		5	607.2	0.99	1.90	335	113	84	✓	✓	8	4
6		6	608.6	1.50	3.00	335	115	84	✓	✓	10	7
7		7	610.4	1.80	3.60	330	120	84	✓	✓	12	6
8		8	612.6	1.50	3.00	350	122	84	✓	✓	14	7
9		9	614.5	0.97	1.90	345	124	85	✓	✓	16	4
10		10	616.0	0.76	1.50	330	123	86	✓	✓	18	3
11		11	617.3	0.79	1.50	330	122	85	✓	✓	20	3
12		12	618.6	0.88	1.70	330	121	85	✓	✓	22	3
13	END		620.018								11.1KA	
14												
15												
16			Leak Check: 0.00 cfm @ 12" Hg				Fyrite:					
17								O_2	18			
18			Condensate: 89 ml					CO_2	3.5			
19			Silicagel: 17g									
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
32												
33												
34												
35												
36												
37												
38												
39												
40												

© WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A.

Hercules
Woodwaste Boiler No. 4
Run No. 2 Particulate Sample

Date: 3-16-83

Pbar 29.60
Pg -.8"

	Port	Point	V_m	ΔP	ΔH	T_s	T_m in	T_m out	Box Temp <250°	Imp Temp <70°	Time	V A C
1	1	1	620.335	0.14	0.26	0335	70	70	✓	✓	12:38 P	1
2		2	620.9	0.11	0.20	335	70	69	✓	✓	2	1
3		3	621.4	0.09	0.16	335	71	68	✓	✓	4	1
4		4	621.8	0.09	0.16	355	72	68	✓	✓	6	1
5		5	622.3	0.09	0.16	355	74	69	✓	✓	8	1
6		6	622.8	0.11	0.20	360	74	68	✓	✓	10	1
7		7	623.4	0.14	0.26	310	75	68	✓	✓	12	1
8		8	623.9	0.04	0.07	320	77	69	✓	✓	14	1
9		9	624.3	0.02	0.04	315	78	69	✓	✓	16	1
10		10	624.5	0.14	0.26	305	79	70	✓	✓	18	1
11		11	625.1	0.14	0.26	315	81	70	✓	✓	20	1
12		12	625.6	0.04	0.07	325	83	72	✓	✓	22	1
13												
14		1	625.98	0.72	1.40	315	86	72	✓	✓	0	2
15		2	627.3	0.93	1.85	315	92	72	✓	✓	2	3
16		3	628.7	0.93	1.85	315	96	73	✓	✓	4	3
17		4	630.2	0.84	1.65	340	101	73	✓	✓	6	3
18		5	631.5	0.84	1.65	320	105	75	✓	✓	8	3
19		6	633.0	0.40	0.77	310	105	75	✓	✓	10	3
20		7	633.9	0.40	0.77	360	105	76	✓	✓	12	1
21		8	634.9	0.55	1.05	355	106	76	✓	✓	14	2
22		9	636.1	0.62	1.20	355	107	75	✓	✓	16	2
23		10	637.4	1.10	2.20	360	109	78	✓	✓	18	4
24		11	638.9	1.60	3.20	360	111	79	✓	✓	20	7
25		12	640.8	1.20	2.40	340	115	80	✓	✓	22	5
26												2
27		1	642.545	0.70	1.35	300	95	76	✓	✓	0	3
28		2	643.8	0.80	1.60	300	98	77	✓	✓	2	3
29		3	645.1	0.86	1.70	300	100	77	✓	✓	4	4
30		4	646.6	0.90	1.80	325	106	78	✓	✓	6	4
31		5	648.0	0.60	1.19	355	109	80	✓	✓	8	2
32		6	649.2	0.86	1.70	310	113	81	✓	✓	10	4
33		7	650.7	1.70	3.40	335	118	82	✓	✓	12	7
34		8	652.6	1.20	2.40	320	122	82	✓	✓	14	5
35		9	654.3	1.00	2.00	310	123	82	✓	✓	16	5
36		10	656.0	1.10	2.20	325	125	83	✓	✓	18	5
37		11	657.5	1.20	2.40	355	128	84	✓	✓	20	5
38		12	659.3	1.40	2.80	370	130	84	✓	✓	22	6
39												
40												

© WILSON JONES COMPANY G7508 GREEN
MADE IN U.S.A.

Hercules
Woodwaste Boiler No. 3
Date: 3-16-83
Run No. 2 Cont'd

Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250	Imp Temp <70	Time	V A C
4	1	660.897	0.74	1.45	290	119	85	✓	✓	0	3
	2	662.2	0.82	1.60	290	116	86	✓	✓	2	3
	3	663.6	0.64	1.25	295	115	85	✓	✓	4	3
	4	664.8	0.56	1.10	290	114	85	✓	✓	6	3
	5	666.1	0.60	1.20	300	118	87	✓	✓	8	4
	6	667.5	1.60	3.20	300	122	86	✓	✓	10	8
	7	669.5	1.80	3.60	300	127	88	✓	✓	12	10
	8	671.9	1.50	3.00	305	131	89	✓	✓	14	8
	9	673.2	0.86	1.70	350	131	89	✓	✓	16	4
	10	674.6	0.72	1.40	375	129	89	✓	✓	18	4
	11	675.9	0.72	1.40	370	129	91	✓	✓	20	4
	12	677.2	0.79	1.55	370	125	90	✓	✓	22	4
END		678.449								2:18	

Leak Check: 0.00 cfm at 15" Hg

Condensate: 73
Silica gel: 19g

© WILSON JONES COMPANY G7508 GREEN MADE IN

Hercules — Date: 3-16-83 — Pbar 26.6

Woodward Boiler No. 3 — pg = -.8"

Run No. 3

COLUMN WRITE ®

	1	2	3	4	5	6		7		8	
	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250°	Imp. Temp <70°	Time	V A C
1	1	1	678.660	0.09	0.17	325	73	73	✓	✓	3:11P	1
2		2	679.1	0.09	0.17	325	73	72	✓	✓	2	1
3		3	679.6	0.07	0.13	325	73	72	✓	✓	4	1
4		4	680.0	0.06	0.11	355	75	72	✓	✓	6	1
5		5	680.4	0.06	0.11	330	75	72	✓	✓	8	1
6		6	680.8	0.11	0.20	365	77	72	✓	✓	10	1
7		7	681.3	0.09	0.17	350	78	72	✓	✓	12	1
8		8	681.8	0.03	0.05	330	80	73	✓	✓	14	1
9		9	682.1	0.02	0.04	210	81	73	✓	✓	16	1
10		10	682.3	0.21	0.41	360	84	74	✓	✓	18	1
11		11	683.1	0.21	0.41	320	85	75	✓	✓	20	1
12		12	683.8	0.07	0.13	300	87	78	✓	✓	22	1
13												
14		1	684.252	0.67	1.30	280	88	78	✓	✓	0	2
15		2	685.5	0.86	1.70	280	89	78	✓	✓	2	3
16		3	686.8	0.86	1.70	290	94	77	✓	✓	4	3
17		4	688.3	0.80	1.60	280	98	77	✓	✓	6	3
18		5	689.6	0.80	1.60	285	101	78	✓	✓	8	3
19		6	691.0	0.92	1.80	290	105	78	✓	✓	10	3
20		7	692.5	0.65	1.25	285	107	79	✓	✓	12	2
21		8	693.8	0.52	1.00	285	107	80	✓	✓	14	2
22		9	695.0	0.75	1.45	285	106	79	✓	✓	16	2
23		10	696.2	1.20	2.40	285	109	80	✓	✓	18	2
24		11	697.8	1.60	3.20	290	112	80	✓	✓	20	6
25		12	699.8	1.50	3.00	290	116	84	✓	✓	22	6
26												
27		1	701.702	0.72	1.40	280	110	82	✓	✓	0	2
28		2	703.0	0.79	1.50	280	109	83	✓	✓	2	3
29		3	704.3	0.88	1.70	285	107	81	✓	✓	4	3
30		4	705.8	0.94	1.80	290	109	82	✓	✓	6	3
31		5	707.3	0.84	1.65	290	110	84	✓	✓	8	3
32		6	708.6	0.80	1.60	290	110	86	✓	✓	10	3
33		7	710.0	1.70	3.40	290	112	86	✓	✓	12	7
34		8	712.0	1.40	2.80	285	112	84	✓	✓	14	6
35		9	713.7	1.00	2.00	285	113	84	✓	✓	16	5
36		10	715.4	1.10	2.20	285	114	83	✓	✓	18	5
37		11	717.0	1.40	2.80	285	117	87	✓	✓	20	6
38		12	718.8	1.43	2.80	280	118	88	✓	✓	22	6
39												3
40												4

© WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A.

Hercules — Date: 3-16-83

Woodwaste Boiler No: 3

Run No. 3 cont'd

	Port	Point	Vm	ΔP	ΔH	Ts	Tm		Box Temp ≥250°	Imp Temp ≤70°	Time	V A C
1	4	1	720.558	0.82	1.60	280	114	88	✓	✓	0	3
2		2	722.0	0.84	1.60	280	111	87	✓	✓	2	3
3		3	723.3	0.58	1.10	290	108	84	✓	✓	4	2
4		4	724.5	0.52	1.00	290	108	84	✓	✓	6	2
5		5	725.8	1.20	2.40	290	109	84	✓	✓	8	5
6		6	727.4	1.50	3.00	290	112	85	✓	✓	10	6
7		7	729.3	1.80	3.60	290	115	85	✓	✓	12	8
8		8	731.6	1.40	2.80	285	119	85	✓	✓	14	6
9		9	733.2	0.90	1.80	285	118	85	✓	✓	16	4
10		10	734.6	0.71	1.39	285	114	85	✓	✓	18	3
11		11	736.0	0.74	1.45	285	112	85	✓	✓	20	3
12		12	737.2	0.80	1.55	285	112	86	✓	✓	22	3
13	END		738.573								4:50 P	

Leak check 0.00 cfm @ 15" Hg

Condensate: 72

Silica gel: 15g

© WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A

Analytical Data

Hercules - Boiler No. 3
Tested: March 16, 1983

FILTERS:	Run 1	Run 2	Run 3	
Filter Number	8376	8377	8378	
Tare Weight, g	.6101	.6130	.6184	
Final Weight, g	.7300	.7530	.8268	
Net Gain, g	0.1199	0.1400	0.2084	

PROBE WASH	Run 1	Run 2	Run 3	Blank
Volume	144	180	145	100
Tare Weight, g	114.3933	178.6365	186.1540	114.3973
Final Weight, g	114.4879	178.7845	186.2901	114.3981
Net Gain, g	0.0946	0.1480	0.1361	.0008
Blank Correction g	-.0012	-.0014	-.0012	-

	Run 1	Run 2	Run 3	
Mn, mg	213.3	286.6	343.3	

7.0 Data Reduction - Boiler No. 4

7.1 Nomenclature - See Section 5.1

7.2 Summary of Data - Boiler No. 4

1.	As	ft^2	21.347
2.	Dn	in.	.228
3.	An	ft^2	2.835×10^{-4}
4.	Cp	--	.86
5.	θ	min.	96
6.	Y	--	0.990

1.	Vm	ft^3	60.512	63.448	67.352
2.	$\sqrt{\Delta P}$, avg.	$(in.\ H_2O)^{\frac{1}{2}}$	0.846	0.898	0.947
3.	ΔH	in. H_2O	1.651	1.674	1.863
4.	Ts	^oR	792.9	731.4	731.7
5.	Tm	^oR	548.0	549.4	552.2
6.	Pbar	in. Hg	29.90	29.90	29.89
7.	Pm	in. Hg	30.02	30.02	30.03
8.	Pg	in. Hg	- .05	- .05	- .05
9.	Ps	in. Hg	29.85	29.85	29.84
10.	Vlc	ml	119.5	120.0	86.5
11.	O_2	%	18.5	18.5	18.5
12.	CO_2	%	3.5	3.5	3.5
13.	N_2+CO	%	78	78	78
14.	Mn	mg	321.8	454.7	351.1
15.					
16.					
17.					

7.3 Calculations - Boiler No. 4

1. Vmstd: $Vm\ Y\ (Pm/Pstd)(Tstd/Tm)$	57.913	60.569	63.991	
2. Vwstd: $(.04707\ ft^3/ml)Vlc$	5.625	5.648	4.072	
3. Bws: $Vwstd/(Vwstd+Vmstd)$	0.089	0.085	0.060	
4. Md: $.44\ CO_2+.32\ O_2+.28(N_2+CO)$	29.30	29.30	29.30	
5. Ms: $Md(1-Bws)+18\ Bws$	28.30	28.34	28.62	
6. Vs: $Kp\ Cp\ (\sqrt{\Delta P})\sqrt{Ts/(PsMs)}$	60.26	59.97	62.94	61.06
7. Q: $Vs\ As(3600\ sec/hr)$	4630950	4608339	4837107	4692132
8. Qstd: $Q(1-Bws)(Ps/Pstd)(Tstd/Ts)$	2804220	3035895	3272912	3037676
9. Cs: $(.001mg/g)(Mn/Vmstd)$	.0056	.0075	.0055	
10. E: $(1\#/454\ g)Cs\ Qstd$	34.32	50.20	39.54	41.35
11. C's: $(cs)(15.419\ gr/g)$	0.086	0.116	0.085	.096
12.				
13.				
14.				
15.				
16.				
I: $\frac{100\ Ts\ [.002669\ Vlc + (Vm\ Pm/Tm)]}{60\ \Theta\ Vs\ Ps\ An}$	97.2	93.9	92.0	

8.0 Raw Data - Boiler No. 4

ISOKINETIC PRELIMINARY DATA


Hercules, Inc - Hattiesburg, Miss

Woodwaste boiler No. 4 — Particulate Test

Diameters upstream ≤1 downstream ≤7

No. sample points 48 time/pt. 2 min

Sketch of Stack:



Pt. No.	% Dia.	inches from wall	Preliminary ΔP							
			1	α	2	α	3	α	4	α
1	NA	2.4	.82	0°	.84	+5	1.0	+5	.15	12.
2		7.3	.89	+5	1.1	+5	1.3	+5	.25	+5
3		12.1	.60	+15	1.1	+5	1.1	+5	.25	+5
4		16.9	.90	+15	1.1	+5	.95	+10	.25	+5
5		21.8	1.0	0	.65	+5	1.3	+15	.25	+5
6		26.6	1.2	0	1.6	0	1.7	+10	.35	0
7		31.4	1.4	-5	1.7	+10	.9	0	.35	0
8		36.3	1.1	-5	1.4	+5	.8	+10	.15	0
9		41.1	.85	-5	1.1	+5	.65	0	.15	0
10		45.9	.70	0	1.3	0	.7	+5	.20	0
11		50.8	.65	0	1.5	+5	1.5	+10	.23	+5
12		55.6	.84	+5	1.6	+5	1.7	+5	1.5	+5

All α for Null reading: ≤10° Traverse complete plane

Preliminary Data:

Pbar 29.90

Pg neg.

ΔH@ 1.79

Tm 100

%H_2O est. 8%

Ts est. 325

ΔPavg ≈ .95

ΔPmax 1.8

Dn .228

Nomograph Reference .95

Meter Box I.D. RAC

Probe I.D. 55.5

Pitot Cp .84

Box heat set 250

Notes:

Hercules, Inc. - Hattiesburg, Ms.
Wood Waste Boiler No. 4
Run No. 1 Particulate Sample

Date: 3-15-83
Dn: .228
Sample time/pt: 2 min.

Pbar: 29.90 "Hg
Ps: -.7 "H2O
Nomograph Ref: .95

Port	Point	Vm	ΔP	ΔH	Ts °F	Tm °F in	Tm °F out	Box Temp <250	Imp Temp <70	Time	Vac.
1	1	370.114	0.76	1.45	325	65	65	✓	✓	10:10	1
	2	371.4	0.81	1.55	325	68	66	✓	✓	2	1
	3	372.8	0.45	.84	325	71	65	✓	✓	4	1
	4	373.7	0.84	1.60	325	73	65	✓	✓	6	1
	5	375.0	0.95	1.90	330	79	65	✓	✓	8	1
	6	376.4	1.10	2.20	330	84	65	✓	✓	10	1
	7	378.1	1.40	2.80	330	90	65	✓	✓	12	1
	8	379.7	1.10	2.05	330	92	65	✓	✓	14	1
	9	381.2	0.77	1.50	335	95	67	✓	✓	16	1
	10	382.5	0.61	1.25	335	97	67	✓	✓	18	1
	11	383.7	0.65	1.30	335	99	71	✓	✓	20	1
	12	385.0	0.78	1.60	335	97	70	✓	✓	22	1
2	1	386.327	0.85	1.75	330	97	72	✓	✓	0	1
	2	387.7	0.85	2.20	330	99	73	✓	✓	2	1
	3	389.1	1.05	2.20	335	101	76	✓	✓	4	1
	4	390.7	1.10	2.25	335	105	75	✓	✓	6	1
	5	392.4	0.70	1.40	335	105	74	✓	✓	8	1
	6	393.7	1.10	2.25	340	106	74	✓	✓	10	1
	7	395.3	1.60	3.35	340	110	76	✓	✓	12	1
	8	397.1	1.20	2.50	340	112	76	✓	✓	14	1
	9	398.8	1.00	2.00	345	114	78	✓	✓	16	1
	10	400.4	1.20	2.50	345	115	78	✓	✓	18	3
	11	402.0	1.30	2.65	350	118	81	✓	✓	20	4
	12	403.7	1.40	3.00	350	119	82	✓	✓	22	5
3	1	405.6	0.97	1.95	340	113	84	✓	✓	0	4
	2	407.1	0.10	2.25	340	111	84	✓	✓	2	4
	3	408.7	1.10	2.25	340	112	84	✓	✓	4	4
	4	410.2	0.89	1.80	340	112	84	✓	✓	6	3
	5	411.7	1.10	2.25	335	113	84	✓	✓	8	4
	6	413.2	1.60	4.30	330	117	87	✓	✓	10	9
	7	415.6	0.72	1.90	340	114	85	✓	✓	12	4
	8	417.0	0.94	2.00	340	114	86	✓	✓	14	4
	9	418.5	0.60	1.20	340	112	87	✓	✓	16	3
	10	419.7	0.72	1.30	340	109	88	✓	✓	18	3
	11	420.9	1.30	2.60	345	109	88	✓	✓	20	5
	12	422.1	1.80	3.60	350	102	86	✓	✓	22	6

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A

Hercules

Date: 3-15-83

Woodwaste Boiler No.

Run No. 1 cont'd

3-15-83

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250°	Imp Temp <70°	Time	V A c
1	4	1	423.678	0.13	0.24	300	95	83	✓	✓	0	1
2		2	424.2	0.11	0.20	300	93	85	✓	✓	2	1
3		3	424.6	0.10	0.18	300	90	85	✓	✓	4	1
4		4	425.3	0.10	0.18	310	87	82	✓	✓	6	1
5		5	425.7	0.16	0.30	325	87	84	✓	✓	8	1
6		6	426.2	0.28	0.54	325	86	82	✓	✓	10	1
7		7	427.0	0.25	0.49	330	87	82	✓	✓	12	1
8		8	427.7	0.08	0.15	330	87	82	✓	✓	14	1
9		9	428.2	0.04	0.06	330	86	81	✓	✓	16	1
10		10	428.5	0.30	0.58	335	86	81	✓	✓	18	1
11		11	429.1	0.37	0.71	340	87	81	✓	✓	20	1
12		12	430.1	0.04	0.15	340	87	80	✓	✓	22	
13	END		430.626								11:51 A	

Leak check: 0.00 cfm @ 14" Hg

Condensate: 100 ml

Silica gel: 19.5 g

Fyrite:

O_2 = 16.5%

CO_2 = 3.5%

© WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A

Hercules
Woodward Boiler No. 4
Run No. 2 Particulate Sample

Date: 3-15-83

Pbar 29.90
Pg = -.7
Nomo Ref = .98

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250°	Imp. Temp <70°	Time	A/C
1	1	1	430.927	0.78	1.45	295	77	77	✓	✓	1:00P	1
2		2	432.2	0.81	1.50	295	80	77	✓	✓	2	1
3		3	433.6	0.56	1.05	295	83	77	✓	✓	4	1
4		4	434.6	0.88	1.65	295	86	78	✓	✓	6	1
5		5	435.9	0.95	1.80	295	87	78	✓	✓	8	2
6		6	437.3	1.20	2.30	290	90	77	✓	✓	10	4
7		7	438.9	1.20	2.30	285	93	77	✓	✓	12	4
8		8	440.4	1.10	2.10	275	95	77	✓	✓	14	4
9		9	442.0	0.75	1.40	270	96	77	✓	✓	16	2
10		10	443.2	0.65	1.20	255	97	78	✓	✓	18	2
11		11	444.4	0.65	1.20	260	97	77	✓	✓	20	2
12		12	445.6	0.83	1.55	275	98	80	✓	✓	22	2
13												
14	2	1	446.954	0.94	1.80	260	93	78	✓	✓	0	3
15		2	448.3	1.10	2.10	260	94	81	✓	✓	2	4
16		3	449.8	1.10	2.10	260	95	81	✓	✓	4	5
17		4	451.4	1.10	2.10	260	98	80	✓	✓	6	5
8		5	453.0	0.70	1.30	260	98	80	✓	✓	8	5
19		6	454.2	1.70	3.30	260	102	79	✓	✓	10	9
20		7	455.9	1.70	3.30	260	106	79	✓	✓	12	9
21		8	458.0	1.20	2.30	250	112	80	✓	✓	14	6
22		9	459.6	1.20	2.30	255	114	82	✓	✓	16	6
23		10	461.4	1.20	2.30	280	114	84	✓	✓	18	6
24		11	463.0	1.40	2.80	250	113	85	✓	✓	20	8
25		12	464.7	1.60	3.20	255	113	85	✓	✓	22	9
26												
27	3	1	466.875	1.10	2.20	250	103	85	✓	✓	0	6
28		2	468.2	1.40	2.70	250	102	92	✓	✓	2	8
29		3	470.0	1.20	2.70	250	104	84	✓	✓	4	7
30		4	471.6	0.97	1.85	250	104	84	✓	✓	6	6
31		5	473.2	1.30	2.50	250	104	84	✓	✓	8	8
32		6	474.8	1.70	3.30	250	105	83	✓	✓	10	11
33		7	476.7	0.47	0.87	250	103	84	✓	✓	12	2
34		8	477.7	1.10	2.10	250	103	83	✓	✓	14	6
35		9	479.1	0.75	1.45	250	101	83	✓	✓	16	5
36		10	480.5	.83	1.60	255	101	85	✓	✓	18	5
17		11	481.7	1.40	2.80	250	102	95	✓	✓	20	10
38		12	483.5	1.70	3.30	260	105	84	✓	✓	22	12
39												
40												

© WILSON JONES COMPANY G7508 GREEN
MADE IN U.S.A

Hercules
Woodwaste Boiler No. 4
Run No 2. cont'd

Date: 3-15-83

3-15-83

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp <250°	Imp Temp <70	Time	V A C
1	4	1	485.615	0.20	0.28	250	99	82	✓	✓	0	1
2		2	486.3	0.24	0.45	250	96	82	✓	✓	2	1
3		3	487.1	0.16	0.29	250	94	85	✓	✓	4	1
4		4	487.7	0.13	0.24	245	92	82	✓	✓	6	1
5		5	488.2	0.24	0.45	245	91	83	✓	✓	8	1
6		6	489.0	0.32	0.60	245	91	80	✓	✓	10	1
7		7	489.8	0.32	0.60	245	93	83	✓	✓	12	1
8		8	490.7	0.08	0.15	250	92	84	✓	✓	14	1
9		9	491.3	0.08	0.15	265	91	84	✓	✓	16	1
10		10	491.8	0.29	0.57	255	91	81	✓	✓	18	1
11		11	492.6	0.37	0.73	250	90	81	✓	✓	20	1
12		12	493.6	0.20	0.38	250	92	85	✓	✓	22	1
13	END		494.375								2:42P	1

Leak Check: 0.00 cfm @ 15" Hg

Condensate: 103 g

Silica gel: 17g

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A

Hercules
Woodwaste Boiler No: 4
Run No. 3 Particulate Sample

Date: 3/5-83

Pbar: 29.85
P_g = -.7"
@ 5:42
5:50

Port	Point	V_m	ΔP	ΔH	T_s	T_m in	T_m out	Box Temp <250°	Imp Temp <70°	Time	V A C.
1	1	494.834	0.88	1.70	285	75	75	✓	✓	3:48P	1 1
	2	496.2	0.86	1.65	285	80	75	✓	✓	2	1 2
	3	497.6	0.67	1.20	285	85	75	✓	✓	4	1 3
	4	499.9	0.93	1.75	290	88	75	✓	✓	6	1 4
	5	500.2	1.10	2.10	300	94	75	✓	✓	8	2 5
	6	501.8	1.40	2.80	305	100	76	✓	✓	10	3 6
	7	503.5	1.50	3.00	305	104	76	✓	✓	12	3 7
	8	505.4	1.30	2.60	305	107	78	✓	✓	14	3 8
	9	507.1	0.85	1.65	295	106	78	✓	✓	16	1 9
	10	508.6	0.73	1.40	305	105	78	✓	✓	18	1 10
	11	509.9	0.73	1.40	295	104	77	✓	✓	20	1 11
	12	511.2	0.91	1.80	290	105	78	✓	✓	22	1 12
											13
2	1	512.606	0.89	1.75	290	102	78	✓	✓	0	1 14
	2	514.1	1.20	2.30	290	104	80	✓	✓	2	2 15
	3	515.7	1.20	2.30	290	107	80	✓	✓	4	2 16
	4	517.3	1.30	2.60	280	107	79	✓	✓	6	2 17
	5	519.1	0.99	1.90	280	110	79	✓	✓	8	1 8
	6	520.5	1.80	3.70	275	114	81	✓	✓	10	5 19
	7	522.4	1.90	3.80	270	115	81	✓	✓	12	5 20
	8	524.7	1.40	2.70	270	116	84	✓	✓	14	2 21
	9	526.5	1.20	2.30	270	114	82	✓	✓	16	2 22
	10	528.2	1.40	2.70	270	113	84	✓	✓	18	2 23
	11	529.9	1.40	2.70	270	111	83	✓	✓	20	2 24
	12	531.7	1.40	2.70	275	112	85	✓	✓	22	3 25
								✓	✓		26
3	1	533.405	1.20	2.30	275	104	84	✓	✓	0	3 27
	2	535.0	1.40	2.70	270	104	84	✓	✓	2	3 28
	3	536.8	1.10	2.10	270	104	80	✓	✓	4	2 29
	4	538.4	0.99	1.90	260	107	82	✓	✓	6	2 30
	5	539.9	1.40	2.70	250	107	83	✓	✓	8	3 31
	6	541.6	1.80	3.70	255	111	84	✓	✓	10	5 32
	7	543.7	1.30	2.60	250	113	84	✓	✓	12	4 33
	8	545.6	1.00	1.95	255	113	83	✓	✓	14	3 34
	9	547.0	0.76	1.45	260	112	84	✓	✓	16	2 35
	10	548.4	0.90	1.75	260	111	85	✓	✓	18	2 36
	11	549.7	1.40	2.70	265	111	86	✓	✓	20	4 37
	12	551.5	1.90	3.60	271	112	84	✓	✓	22	5 38
											39
											40

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules
Woodwaste Boiler No. 4
Run No. 3 Cont'd

Date: 3-15-83

28-SIE

	Port	Point	Vm	ΔP	ΔH	Ts	Tm		Box Temp <250	Imp Temp <70	Time	
1	4	1	553.484	0.14	0.26	250	102	83	✓	✓	0	1
2		2	554.0	0.23	0.42	250	99	84	✓	✓	2	1
3		3	554.7	0.15	0.28	250	96	80	✓	✓	4	1
4		4	555.4	0.15	0.28	250	96	82	✓	✓	6	1
5		5	556.0	0.21	0.39	245	95	82	✓	✓	8	1
6		6	556.6	0.35	0.66	250	97	82	✓	✓	10	1
7		7	557.6	0.36	0.67	250	98	83	✓	✓	12	1
8		8	558.5	0.18	0.33	250	98	82	✓	✓	14	1
9		9	559.1	0.11	0.19	255	99	83	✓	✓	16	1
10		10	559.5	0.33	0.60	255	100	83	✓	✓	18	1
11		11	560.4	0.46	0.86	260	100	82	✓	✓	20	1
12		12	561.4	0.28	0.51	260	102	83	✓	✓	22	1
13	END		562.186								5:33P	

Leak check 0.00 cfm @ 10" Hg

Condensate 71 ml
Silica Gel: 15.5g

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A

Analytical Data

Hercules - Boiler No. 4
Tested: March 15, 1983

FILTERS:	Run 1	Run 2	Run 3	
Filter Number	8375	8370	8371	
Tare Weight, g	.6199	.5775	.5819	
Final Weight, g	.8224	.8707	.7784	
Net Gain, g	0.2025	0.2932	0.1965	

PROBE WASH	Run 1	Run 2	Run 3	Blank
Volume	170	175	180	100
Tare Weight, g	112.0254	112.7453	111.5213	114.3973
Final Weight, g	112.1461	112.9082	111.6773	114.3981
Net Gain, g	0.1207	0.1629	0.1560	.0008
Blank Correction g	-0.0014	-0.0014	-0.0014	-

	Run 1	Run 2	Run 3	
Mn, mg	321.8	454.7	351.1	

HERCULES INCORPORATED
HATTIESBURG, MISSISSIPPI 39401

RECEIVED
1983 MAR -2 AM 9:21
AIR & WATER POLLUTION CONTROL COMMISSION
STATE OF MISSISSIPPI

March 1, 1983

Bureau Of Pollution Control
P. O. Box 10385
Jackson, Mississippi 39209

ATTN: Don Watts

Dear Mr. Watts:

Re your February 11, 1983, letter we have reviewed your comments and expect to comply with them starting in March.

Please find the enclosed test results for woodwaste boilers 1 and 2 on October 25 and 26, 1982. These results indicate a particulate concentration of 0.12 grains/dscf for boiler 1 and 0.11 grains/dscf for boiler 2 as compared to an allowable concentration of 0.30 grains/dscf.

The dates of ~~April~~ March 15 and 16, 1983, have been set up for sampling boilers 3 and 4.

If I can answer any question please call me.

Very truly yours,

Charles Jordan
Environmental Coordinator

CSJ:ml

Enclosure

Change per phone call w/ CJ by DAW 3/4/83

REPORT OF
PARTICULATE EMISSIONS TESTS

HERCULES
WOODWASTE BOILERS-NO. 1 and NO. 2

HATTIESBURG, MISSISSIPPI
OCTOBER 25 and 26, 1982

Performed By:
Environmental Monitoring Laboratories, Inc.
Ridgeland, Mississippi

ENVIRONMENTAL MONITORING LABORATORIES, INC.

P.O. Box 655 • 224-B Highway 51 North
Ridgeland, Mississippi 39157

(601) 856-3092

On October 25 and 26, 1982, Environmental Monitoring Laboratories performed air emissions tests on two of four woodwaste boilers operated by Hercules, Inc. in Hattiesburg, Mississippi.

The tests were performed to determine particulate emissions from woodwaste boilers No. 1 and No. 2. Particulate emissions from woodwaste boilers not classified under New Source Performance Standards or otherwise restricted by permit condition are limited to 0.30 grains per dry standard cubic foot as described in Air Quality Regulations APC-S-1 Section 3, paragraph 4.(b).

Following is a report of the results of the emissions tests. Contents are:

1.0 Test Results

2.0 Validity of Results

3.0 Source Operation

4.0 Test Proceedures

5.0 Data Reduction - Boiler No. 1

6.0 Raw Data - Boiler No. 1

7.0 Data Reduction - Boiler No. 2

8.0 Raw Data - Boiler No. 2

1.0 Test Results

1.1 The average particulate emissions concentration from Boiler No. 1 as determined from three separate samples taken on October 25, 1982, is 0.12 grains per dry standard cubic foot.

The table below is a summary of the pertinent results

Boiler No. 1		Run 1	Run 2	Run 3	Avg.
Particulate conc.	grains/dscf	0.09	0.13	0.13	0.12
Allowable Conc.	grains/dscf	0.30	0.30	0.30	0.30
Emission rate	#/hr	31.72	46.69	47.58	42.00
Allowable emissions	#/hr	110.2	106.9	109.7	108.9
Velocity	ft/sec.	61.19	59.36	60.66	60.40
Volumetric flowrate	ft^3/hr	4604327	4181535	4176401	4320754
Volumetric flowrate	dscf/hr	2571205	2493529	2559366	2541367
Stack Temperature	^oF	386	369	364	373

1.2 The average particulate emissions concentration from Boiler No. 2 as determined from three separate samples taken on October 26, 1982, is 0.11 grains per dry standard cubic foot.

The table below is a summary of the pertinent results:

Boiler No. 2		Run 1	Run 2	Run 3	Avg.
Particulate conc.	grains/dscf	0.05	0.11	0.16	0.11
Allowable conc.	grains/dscf	0.30	0.30	0.30	0.30
Emission rate	#/hr	20.34	44.41	64.03	42.93
Allowable emissions	#/hr	125.3	122.3	121.1	122.9
Velocity	ft/sec	62.50	61.39	61.97	61.95
Volumetric flowrate	ft^3/hr	4803141	4717864	4762116	4761040
Volumetric flowrate	dscf/hr	2922962	2853446	2825164	2867191
Stack Temperature	^oF	372	358	364	365

2.0 Validity of Results

2.1 The largest deviation from the average volumetric flowrate for both tests is less than 7%. Considerable variation in emission results was experienced with both tests. Emissions values were within 25% of the mean for the test on Boiler 1. Emissions values for Boiler 2 varied as much as 55%.

The average emissions rates of each boiler, however, were extremely close, which is to be expected of two nearly identical boilers. The wide variations from one run to another may be due to the fact that different qualities of woodwaste may fuel a boiler from one time period to another. Woodwaste is purchased from a variety of sources.

2.2 Isokinetic variation: The sampling rates for the Boiler No. 1 test were 101.9%, 94.0% and 89.2% isokinetic for Runs 1, 2, and 3 respectively. The third run was below the desired 90% to 110% range due to a sharp decrease in moisture content. The effect, if any, of this below-isokinetic rate would be to bias the results high.

The sampling rates for the Boiler No. 2 test were 96.9%, 96.4%, and 96.4% for Runs 1, 2, and 3 respectively.

2.3 Although there were slight deviations from the standard methods for these tests as described in section 4.0, the samples were representative of emissions under the encountered operating conditions and the results should be considered valid.

3.0 Source Operation

Hercules operates four nearly identical woodwaste boilers. The boilers are each capable of using fuel oil and gas although woodwaste is the primary fuel and a fire is maintained at all times with woodwaste.

Because insufficient woodwaste is generated at the facility, additional wood fuel must be purchased. the quality and quantity of the fuel varies.

On the two days of testing, the supply of wood fuel was low. In order to test the boilers under an "all woodwaste" condition, the supply was shifted to an all wood condition during the test for each boiler.

4.0 Test Proceedure

4.1 Sampling and analytical proceedures used are those described in the Code of Federal Regulations, Title 40, Part 60, Appendix A, specifically Reference Method 5. No substantial deviations from the standard proceedures were taken. Each test was performed in triplicate. Testing was observed by Mr. Jesse Thompson of the Mississippi Bureau of Pollution Control.

4.2 A variation from the standard proceedures was necessary due to physical limitations of the sampling site. Method 5 testing requires that samples be taken from sample points as described in Method 1.

Because the masonry stacks serving the boilers have no sampling platforms, testing ports have been installed on each boiler's exhaust duct (breeching) prior to its entering the stack. One stack serves Boilers 1 and 2 and another serves Boilers 3 and 4. Each boiler's ducts have a rectangular vertical section in which sample ports are installed. Tapering duct sections and fans proceed and preceed the short vertical sections and there is less than the required number of diameter distance from disturbances both downstream and upstream of the portholes. The minimum diameter distances required by Method 1 are 0.5 diameters from the sample ports to the nearest downstream disturbance and 2 diameters from the sample ports to nearest upstream disturbance. These minimum diameter distances dictate that 48 points should be sampled.

The deviation from the standard method for these tests is that sampling was performed as though the minimum distances were met; 48 sample points were used. The test for the absense of cyclonic flow as described in Method 1 indicated that the flow at the sample site is acceptable for each boiler. If the cyclonic flow test had indicated unacceptable flow, sampling was to be done at 50% isokinetic to compensate for a possible negative bias from the cyclonic flow.

5.0 Data Reduction - Boiler No. 1

5.1 Nomenclature

SYMBOL	UNITS	DESCRIPTION
An	ft^2	Nozzle area
As	ft^2	Stack area
Bws	dimensionless	Propor tion by volume of water vapor
Cp	dimensionless	Pitot correction factor
Cs	grams/dscf	Particulate concentration
C's	grains/dscf	Particulate concentration
Dn	inches	Nozzle diameter
ΔH	in. H_2O	Pressure drop across meter orifice
ΔP	in. H_2O	Stack velocity pressure head
E	#/hr	Particulate emission rate
E'		Particulate emission rate
Ea		Allowable emissions
I	percent	Percent isokinetic sampling
Kp	consistent	Pitot tube constant = 85.49
Mn	mg	Particulate sample weight
Md	#/# mole	Dry molecular wt. of stack gas

SYMBOL	UNITS	DESCRIPTION
Ms	#/# mole	Wet molecular wt. of stack gas
Pbar	in. Hg	Barometric pressure
Pg	in. Hg	Static pressure in stack
Pm	in. Hg	Meter pressure = Pbar + (ΔH/13.6)
Ps	in. Hg	Stack pressure = Pbar + Pg
Pstd	in. Hg	Standard pressure = 29.92
Q	ft^3/hr	Volumetric flow rate @ stack conditions
Qstd	dscf/hr	Volumetric flow rate @ dry, std. conditions
θ	minutes	Sampling time per run
Tm	^oR	Average meter temperature
Ts	^oR	Average stack temperature
Tstd	^oR	Standard temperature = 528^o
Vlc	ml	Volume of water collected
Vm	ft^3	Volume of dry gas sampled
Vmstd	dscf	Sample volume @ standard conditions
Vwstd	scf	Sample volume of water vapor
Y	dimensionless	Meter correction factor
Xa	percent	Excess air

5.2 Summary of Data - Boiler No. 1

1.	As	ft^2	21.347
2.	Dn	in.	.188
3.	An	ft^2	1.928×10^{-4}
4.	Cp	--	.86
5.	θ	min.	94, 88, 86 *
6.	Y	--	1.00

1.	Vm	ft^3	38.828	34.240	33.416
2.	$\sqrt{\Delta P}$, avg.	$(in. H_2O)^{\frac{1}{2}}$	.838	.825	.850
3.	ΔH	in. H_2O	.615	.545	.622
4.	Ts	^oR	846.0	829.3	823.8
5.	Tm	^oR	537.4	540.1	541.5
6.	Pbar	in. Hg	30.27	30.24	30.24
7.	Pm	in. Hg	30.32	30.28	30.29
8.	Pg	in. Hg	-.022	-.015	-.015
9.	Ps	in. Hg	30.25	30.23	30.23
10.	Vlc	ml	107	56.5	42.0
11.	O_2	%	15.0	15.0	15.0
12.	CO_2	%	5.5	5.5	5.5
13.	N_2+CO	%	79.5	79.5	79.5
14.	Mn	mg	216.5	289.1	278.4
15.					
16.					
17.					

*One negative point during Run 1, four during Run2, and five during Run 3.

5.3 Calculations - Boiler No. 1

1. Vmstd: $Vm\ Y\ (Pm/Pstd)(Tstd/Tm)$	38.659	33.876	32.986	
2. Vwstd: $(.04707\ ft^3/ml)Vlc$	5.036	2.659	1.977	
3. Bws: $Vwstd/(Vwstd+Vmstd)$	.115	.073	.057	
4. Md: $.44\ CO_2+.32\ O_2+.28(N_2+CO)$	29.48	29.48	29.48	
5. Ms: $Md(1-Bws)+18\ Bws$	28.16	28.64	28.83	
6. Vs: $Kp\ Cp\ (\sqrt{\Delta P})\sqrt{Ts/(PsMs)}$	61.19	59.36	60.66	60.40
7. Q: $Vs\ As(3600\ sec/hr)$	4604327	4181535	4176401	4320754
8. Qstd: $Q(1-Bws)(Ps/Pstd)(Tstd/Ts)$	2571205	2493529	2559366	2541367
9. Cs: $(.001mg/g)(Mn/Vmstd)$	.0056	.0085	.0084	
10. E: $(1\#/454\ g)Cs\ Qstd$	31.72	46.69	47.58	42.00
11. C's: $(Cs)(15.419\ gr/g)$	0.09	0.13	0.13	0.12
12.				
13.				
14.				
15.				
16.				
I: $\frac{100\ Ts\ [.002669\ Vlc + (Vm\ Pm/Tm)]}{60\ \Theta\ Vs\ Ps\ An}$	101.9	94.0	89.2	

*As reduced by area represented by negative areas.

6.0 Raw Data - Boiler No. 1

ISOKINETIC PRELIMINARY DATA


Hercules - No. 1 Boiler

10-25-82

Diameters upstream < 1 downstream < 1

No. sample points 48 time/pt. 2

Sketch of Stack:



Pt. No.	% Dia.	inches from wall	Preliminary ΔP 1 ∠ 2 ∠ 3 ∠ 4	∠
1	NA	2.4	.10 -45° .95 -20 .8 -5 .8	0°
2		7.3	.13 -45 1.10 -10 1.2 -10 .85	-5
3		12.1	.10 0 .98 -10 1.2 -5 .20	-5
4		16.9	.08 0 .80 -5 1.3 -5 1.4	-5
5		21.8	.05 0 .10 -10 .6 0 1.1	0
6		26.6	.15 -20 .65 -10 .5 0 1.3	0
7		31.4	.40 -20 Neg 0 1.5 0 1.5	5
8		36.3	.60 -15 .35 0 1.8 0 1.5	5
9		41.1	.15 0 .90 0 1.5 +5 1.05	5
10		45.9	.40 0 .90 0 1.5 0 .95	5
11		50.8	.40 0 .90 0 1.7 0 .95	0
12		55.6	.40 0 .90 0 1.7 0 .95	0

Preliminary Data:

Pbar 30.27 "Hg

Pg -.30"H₂O

ΔH@ 1.73"H₂O

Tm 90°F

%H₂O 7%

Ts 380°F

ΔPavg .8

ΔPmax 1.8

Dn .188

Nomograph Reference 2.21

Meter Box I.D. L.S. - 1

Probe I.D. S-S.S.

Pitot Cp .86

Box heat set 250°F

Notes:

AVG. ∠ to obtain null reading is 5.7°. Therefore acceptable flow conditions exist.

Hercules - Woodwaste Boiler No. 1 — 10-25-82 — Pbar 30.27

10-25-82 — Pg = ~~-.30~~

Run No. 1

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	V A C
1	1	1	319.900	.07	.05	375	74	72	250	70	12:49P	2
2		2	320.2	.05	.03	375	74	72	250	70	2	2
3		3	320.4	.25	.19	375	74	72	250	70	2	2
4		4	320.8	.25	.19	375	74	72	250	70	2	2
5		5	321.3	.60	.48	375	75	72	250	70	2	2
6		6	321.9	.55	.44	375	75	72	250	70	2	2
7		7	322.6	.65	.49	380	76	72	250	70	2	2
8		8	323.1	.25	.19	380	76	72	250	70	2	2
9		9	323.5	.15	.12	385	76	72	250	70	2	2
10		10	324.0	.25	.19	390	76	72	250	70	2	2
11		11	324.4	.15	.12	390	76	72	250	70	2	2
12		12	324.9	.15	.12	395	76	72	250	70	2	2
13												
14	2	1	325.195	1.1	.9	380	76	72	250	70	2	3
15		2	326.2	1.1	.9	380	80	72	250	70	2	3
16		3	327.2	.80	.65	390	82	73	250	70	2	3
17		4	328.2	.55	.44	390	82	73	250	70	2	3
18		5	328.9	.50	.40	385	80	73	250	70	2	3
19		6	329.7	.65	.51	385	80	73	250	70	2	3
20		7	330.5	.20	.17	385	80	73	250	70	2	3
21		8	331.0	.05	.03	390	80	72	250	70	2	2
22		9	331.2	.90	.72	390	80	72	250	70	2	3
23		10	332.1	.90	.72	395	80	74	250	70	2	3
24		11	333.1	.90	.72	400	82	74	250	70	2	3
25		12	334.0	.90	.72	400	82	74	250	70	2	3
26												
27	3	1	335.020	1.1	.9	380	82	74	250	70	2	3
28		2	336.0	1.1	.9	380	84	74	250	70	2	3
29		3	337.1	1.1	.9	390	84	74	250	70	2	3
30		4	338.1	1.1	.9	390	84	74	250	70	2	3
31		5	339.2	1.1	.9	390	85	74	250	70	2	3
32		6	340.3	neg.	-	-	-	-	-	-	-	-
33		7	340.3	1.2	.97	390	85	74	250	70	2	3
34		8	341.4	1.3	1.05	390	85	74	250	70	2	4
35		9	342.5	1.2	.97	390	86	74	250	70	2	4
36		10	343.6	1.2	.97	390	86	74	250	70	2	4
37		11	344.7	1.3	1.05	395	84	75	250	70	2	4
38		12	345.8	1.5	1.2	395	88	75	250	70	2	4
39												
40												

COLUMN WRITE®

© WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A.

Hercules - Boiler No. 1

10-25-82

Run No. 1 Cont'd

10-25-82

	Part, Point		Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	V	A	C
1	4	1	347.108	.85	.68	385	86	74	250	70	2			3
2		2	348.0	.85	.68	385	85	74	250	70	2			3
3		3	348.9	.35	.27	385	84	74	250	70	2			3
4		4	349.5	.95	.76	385	84	74	250	70	2			3
5		5	350.5	1.0	.80	385	84	74	250	70	2			3
6		6	351.5	1.0	.80	385	85	74	250	70	2			3
7		7	352.5	1.1	.90	385	86	74	250	70	2			4
8		8	353.6	1.1	.9	385	86	74	250	70	2			4
9		9	354.6	1.0	.80	390	86	74	250	70	2			3
10		10	355.7	.90	.73	390	86	74	250	70	2			3
11		11	356.6	1.0	.80	390	86	74	250	70	2			3
12		12	357.7	1.1	.90	390	86	74	250	70	2			4
13	END		358.728								2:24P			

leak check < .02 cfm at 5" Hg

condensate: ~~70 ml~~ 99 ml

silica gel 8 g

Filter No 8281

Hercules - Boiler 1

10-25-82

Run No. 2

$P_{bar} = 30.24$

$P_s = -.2$

Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	V A C
1	1	358.915	.1	.03	355	74	72	250	70	3:31P	2
	2	359.2	.02	.01	355	74	72	250	70	2	2
	3	359.3	neg	-	-	-	-	-	-	0	-
	4	359.3	neg	-	-	-	-	-	-	0	-
	5	359.3	neg	-	-	-	-	-	-	0	-
	6	359.3	.05	.02	355	74	72	250	70	2	2
	7	359.4	.07	.03	360	74	72	250	70	2	2
	8	357.4	.22	.14	365	74	72	250	70	2	2
	9	360.0	.15	.09	370	75	72	250	70	2	2
	10	360.4	.05	.02	370	75	72	250	70	2	2
	11	360.6	.13	.06	365	75	72	250	70	2	2
	12	360.9	.13	.06	360	75	72	250	70	2	2
		-									
2	1	361.222	1.2	.81	360	76	73	250	70	2	4
	2	362.2	1.2	.81	365	80	73	250	70	2	4
	3	363.3	.76	.51	370	80	73	250	70	2	3
	4	364.1	.57	.38	370	80	74	250	70	2	3
	5	364.8	.50	.33	370	80	74	250	70	2	3
	6	365.5	.55	.36	370	80	74	250	70	2	3
	7	366.1	.35	.23	370	80	74	250	70	2	3
	8	366.7	.05	.02	370	90	74	250	70	2	2
	9	367.0	1.0	.69	370	80	74	250	70	2	4
	10	367.9	1.0	.69	370	82	74	250	70	2	4
	11	368.9	1.1	.75	370	84	74	250	70	2	4
	12	369.9	.9	.6	370	89	76	250	70	2	4
3	1	370.786	1.3	.89	370	94	78	250	70	2	4
	2	371.8	1.1	.75	370	98	80	250	70	2	4
	3	372.8	1.1	.75	370	94	80	250	70	2	4
	4	373.8	1.1	.75	370	92	80	250	70	2	4
	5	374.8	1.1	.75	370	92	78	250	70	2	4
	6	375.8	neg	-	-	-	-	-	-	0	-
	7	375.8	1.4	.95	370	90	78	250	70	2	4
	8	376.8	1.4	.95	370	90	78	250	70	2	4
	9	377.9	1.2	.81	370	90	78	250	70	2	4
	10	378.9	1.4	.95	370	90	78	250	70	2	4
	11	380.0	1.6	1.1	375	90	78	250	70	2	5
	12	381.2	1.6	1.1	375	90	78	250	70	2	5

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules - Boiler No. 1

10-25-82

Run No. 2 Cont'd

	Port, Point		Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	V A C
1	4	1	382.378	.90	.60	370	88	76	250	70	2	4
2		2	383.3	.97	.65	370	90	78	250	70	2	4
3		3	384.2	.35	.09	370	90	78	250	70	2	4
4		4	384.6	.72	.48	370	87	78	250	70	2	4
5		5	385.4	1.1	.75	375	87	78	250	70	2	4
6		6	386.4	1.0	.69	375	90	78	250	70	2	4
7		7	387.3	1.1	.75	375	90	78	250	70	2	4
8		8	388.3	1.2	.81	375	90	78	250	70	2	4
9		9	389.3	1.0	.69	375	90	78	250	70	2	4
10		10	390.3	.95	.64	370	88	78	250	70	2	4
11		11	391.2	1.0	.69	375	88	78	250	70	2	4
12		12	392.2	1.1	.75	385	88	76	250	70	2	4
13	END		393.155								5:01P	

Leak check 0.00 cfm @ 8" Hg

condensate: 50 ml

silica gel: 65 g

Filter No. 8282

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules - Boiler No1

10-25-82

Run No. 3

Pbkm 30.24

10-25-82

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Amp Temp	Time	V A C
1	1	1	393.329	.10	.03	360	72	70	250	70	5:49P	2
2		2	393.5	.05	.02	360	72	70	250	70	2	2
3		3	393.6	"	—	—	—	—	—	—	0	—
4		4	393.6	"	—	—	—	—	—	—	0	—
5		5	393.6	"	—	—	—	—	—	—	0	—
6		6	393.6	.06	.02	360	74	72	250	70	2	2
7		7	393.8	.09	.03	360	74	72	250	70	2	2
8		8	394.1	.20	1.3	360	76	74	250	70	2	2
9		9	394.5	.20	1.3	365	80	74	250	70	2	2
10		10	394.9	.03	.01	370	82	76	250	70	2	2
11		11	395.0	.20	1.3	370	82	78	250	70	2	2
12		12	395.4	.05	.02	370	86	80	250	70	2	2
13												
14	2	1	395.664	1.1	.75	360	90	82	250	70	2	3
15		2	396.6	1.1	.75	360	96	82	250	70	2	3
16		3	397.6	.85	.57	365	98	82	250	70	2	3
17		4	398.5	.60	.40	365	90	80	250	70	2	3
18		5	399.2	.53	.36	365	90	79	250	70	2	3
19		6	399.9	.75	.5	360	90	78	250	70	2	3
20		7	400.7	.20	.13	360	90	76	250	70	2	2
21		8	401.2	"	—	—	—	—	—	—	0	—
22		9	401.2	1.0	.69	365	90	76	250	70	2	3
23		10	402.1	.85	.56	365	90	76	250	70	2	3
24		11	402.9	.55	.36	365	90	76	250	70	2	3
25		12	403.6	.68	.45	365	90	75	250	70	2	3
26												
27	3	1	404.415	1.2	.80	365	88	74	250	70	2	3
28		2	405.4	1.2	.80	365	90	78	250	70	2	3
29		3	406.5	1.1	.75	370	90	74	250	70	2	3
30		4	407.4	1.1	.75	370	90	74	250	70	2	3
31		5	408.4	.52	.34	370	92	73	250	70	2	3
32		6	409.1	Neg	—	—	—	—	—	—	0	—
33		7	409.1	1.4	.95	370	94	73	250	70	2	3
34		8	410.0	1.4	.95	365	94	72	250	70	2	4
35		9	411.1	1.4	.95	360	96	74	250	70	2	4
36		10	412.2	1.3	.89	360	96	72	250	70	2	4
37		11	413.3	1.4	.95	365	96	72	250	70	2	4
38		12	414.4	1.4	.95	365	96	72	250	70	2	4
39												
40												

WILSON JONES COMPANY G7508 GREEN

MADE IN U.S.A.

Hercules - Boiler No. 1
10-25-82
Run No. 3 cont'd

JH 10-25-82

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	Vac
1	4	1	415.485	.95	.64	360	92	72	250	70	2	3
2		2	416.4	.98	.66	360	92	72	250	70	2	3
3		3	417.3	.25	.16	365	90	70	250	70	2	2
4		4	417.9	1.2	.8	360	88	70	250	70	2	3
5		5	418.8	1.1	.69	360	90	70	250	70	2	3
6		6	419.7	1.1	.69	355	92	70	250	70	2	3
7		7	420.7	1.1	.69	~~360~~ 350	94	70	250	70	2	3
8		8	421.6	1.3	.89	~~365~~ 345	94	70	250	70	2	4
9		9	422.6	1.3	.89	~~360~~ 340	96	70	250	70	2	4
10		10	423.6	1.3	.89	~~365~~ 345	96	70	250	70	2	4
11		11	424.7	1.1	.78	~~365~~ 345	96	70	250	70	2	4
12		12	425.7	1.3	.89	~~365~~ 345	96	70	250	70	2	4
13	END		426.745								7:16 P	

Leak check 0.00 cfm at 10" Hg

Condensate: 30 ml
silica gel: 6.0g

Filter No. 8283

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Analytical Data

Hercules - Boiler No. 1
Tested: 10-25-82

FILTERS:	Run 1	Run 2	Run 3	
Filter Number	8281	8282	8283	
Tare Weight, g	.5693	.5754	.5731	
Final Weight, g	.6854	.7504	.7500	
Net Gain, g	.1161	.1750	.1769	

PROBE WASH	Run 1	Run 2	Run 3	Blank
Volume, ml	178	160	159	200
Tare Weight, g	112.0233	112.7270	111.5147	114.3857
Final Weight, g	112.1249	112.8721	111.6172	114.3870
Net Gain, g	.1016	.1151	.1025	.0013
Blank Correction,g	-.0012	-.0010	-.0010	

	Run 1	Run 2	Run 3	
Mn, mg	216.5	289.1	278.4	

7.0 Data Reduction - Boiler No. 2

7.1 Nomenclature - See Section 5.1

7.2 Summary of Data - Boiler No. 2

1.	As	ft^2	21.347
2.	Dn	in.	.228
3.	An	ft^2	2.835×10^{-4}
4.	Cp	--	.86
5.	θ	min.	96
6.	Y	--	1.00

1.	Vm	ft^3	58.574	59.468	58.943
2.	$\sqrt{\Delta P}$, avg.	$(in.\ H_2O)^{\frac{1}{2}}$	.868	.860	.863
3.	ΔH	in. H_2O	1.361	1.447	1.380
4.	Ts	^oR	832.4	817.6	824.1
5.	Tm	^oR	533.3	546.3	547.0
6.	Pbar	in. Hg	30.29	30.31	30.33
7.	Pm	in. Hg	30.39	30.42	30.43
8.	Pg	in. Hg	0.000	0.000	0.000
9.	Ps	in. Hg	30.29	30.31	30.33
10.	Vlc	ml	97.5	101.5	116.5
11.	O_2	%	15.0	15.0	15.0
12.	CO_2	%	5.5	5.5	5.5
13.	N_2+CO	%	79.5	79.5	79.5
14.	Mn	mg	186.1	412.9	595.4
15.					
16.					
17.					

7.3 Calculations - Boiler No. 2

1. Vmstd: $Vm\ Y\ (Pm/Pstd)(Tstd/Tm)$	58.903	58.436	57.865	
2. Vwstd: $(.04707\ ft^3/ml)Vlc$	4.589	4.778	5.484	
3. Bws: $Vwstd/(Vwstd+Vmstd)$	.072	.076	.087	
4. Md: $.44\ CO_2+.32\ O_2+.28(N_2+CO)$	29.48	29.48	29.48	
5. Ms: $Md(1-Bws)+18\ Bws$	28.65	28.61	28.49	
6. Vs: $Kp\ Cp\ (\sqrt{\Delta P})\sqrt{Ts/(PsMs)}$	62.50	61.29	61.97	61.95
7. Q: $Vs\ As(3600\ sec/hr)$	4803141	4717864	4762116	4761040
8. Qstd: $Q(1-Bws)(Ps/Pstd)(Tstd/Ts)$	2922962	2853446	2875164	2867191
9. Cs: $(.001mg/g)(Mn/Vmstd)$	.0032	.0071	.0103	
10. E: $(1\#/454\ g)Cs\ Qstd$	20.34	44.41	64.03	42.93
11. C's: $(Cs)(15.419\ gr/g)$	0.05	0.11	0.16	0.11
12.				
13.				
14.				
15.				
16.				
I: $\frac{100\ Ts\ [.002669\ Vlc + (Vm\ Pm/Tm)]}{60\ \Theta\ Vs\ Ps\ An}$	96.9	96.4	96.4	96.6

8.0 Raw Data - Boiler No. 2

ISOKINETIC PRELIMINARY DATA


Hercules - Boiler No-2

Oct. 26-82

Diameters upstream < 1 downstream < 1

No. sample points 48 time/pt. 2

Sketch of Stack:



Pt. No.	% Dia.	inches from wall	Preliminary ΔP 1	α	2	α	3	α	4	α
1	NA	2.4	.5	30°	.35	25	.5	10	.3	10
2		7.3	.45	10	.6	30	.5	10	.4	10
3		12.1	.5	0	.65	15	.6	5	.3	5
4		16.5	.7	10	.7	5	.5	5	.2	0
5		21.8	.9	5	.85	0	.45	5	.2	0
6		26.6	1.2	0	.2	0	.45	0	.15	0
7		31.4	1.0	-5	1.0	0	.25	0	.2	0
8		36.3	.6	-5	.7	0	.15	0	.15	0
9		41.1	.6	0	.7	0	.4	0	.05	5
10		45.9	.6	0	.9	0	.55	0	.56	0
11		50.9	.65	0	1.0	10	.7	5	2.0	0
12		55.6	.65	5	1.2	5	.5	5	2.0	0

Preliminary Data:

Pbar 30.29

Pg negligible

ΔH@ 1.73

Tm 90

%H_2O 7

Ts 380°F

ΔPavg ≈.5

ΔPmax 2.0

Dn .228

Nomograph Reference L.C

Meter Box I.D. L.S.-1

Probe I.D. S-S.S.

Pitot Cp .86

Box heat set 250°F

Notes:

Avg. α for all readings = 5.0°.

Therefore flow is acceptable.

Hercules Boiler No. 2
10-26-82
Run No. 1

$P_{bar} = 30.29$

Port, Point		Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time 10:	V M C
1	1	427.2	.90	1.5	360	62	60	250	60	10:20	3
	2	428.7	.80	1.3	360	64	60	250	70	2	3
	3	429.5	.18	0.3	360	64	60	250	70	2	2
	4	430.1	.85	1.4	360	64	60	250	70	2	3
	5	431.3	1.1	1.8	360	68	60	250	70	2	4
	6	432.8	1.2	2.0	360	70	60	250	70	2	4
	7	434.3	1.5	2.5	360	74	62	250	70	2	5
	8	436.0	1.5	2.5	360	76	62	250	70	2	5
	9	437.7	1.05	1.75	360	78	62	250	70	2	4
	10	439.2	.88	1.45	370	78	64	250	70	2	4
	11	440.6	.88	1.45	370	77	64	250	70	2	4
	12	441.9	1.05	1.75	365	78	64	250	70	2	4
2	1	443.359	.70	1.15	375	76	64	250	70	2	3
	2	444.5	.85	1.4	380	76	64	250	70	2	4
	3	445.8	.85	1.4	380	78	65	250	70	2	4
	4	447.2	1.0	1.65	380	78	66	250	70	2	4
	5	448.5	.82	1.3	380	80	66	250	70	2	4
	6	449.6	.64	1.05	380	80	66	250	70	2	4
	7	450.7	1.5	2.5	385	80	66	250	70	2	5
	8	452.3	1.3	2.2	385	84	67	250	70	2	5
	9	453.7	1.05	1.75	380	85	68	250	70	2	4
	10	455.4	1.05	1.75	380	84	68	250	70	2	4
	11	456.9	1.1	1.8	375	85	68	250	70	2	4
	12	458.3	1.3	2.2	375	86	68	250	70	2	5
3	1	460.0	.59	.97	370	82	68	250	70	2	3
	2	461.1	.59	.97	370	82	68	250	70	2	3
	3	462.2	1.0	1.65	365	82	68	250	70	2	4
	4	463.6	.95	1.60	365	84	68	250	70	2	4
	5	464.9	.80	1.3	380	84	70	250	70	2	4
	6	466.3	.90	1.5	385	85	70	250	70	2	4
	7	467.6	.45	.72	385	84	70	250	70	2	3
	8	468.6	.42	.67	385	83	70	250	70	2	3
	9	469.5	.75	1.3	380	82	70	250	70	2	4
	10	470.7	1.1	1.8	380	84	70	250	70	2	5
	11	472.1	1.4	2.4	375	88	72	250	70	2	5
	12	473.9	1.4	2.4	375	91	72	250	70	2	5

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A

Hercules Boiler 2
10-26-82
Run No. 2 / cont'd

10-26-82

Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	Unit A/C
4	1	475.565	.35	.56	360	80	72	250	70	2	3
	2	476.5	.43	.69	360	80	72	250	70	2	3
	3	477.4	.25	.46	325	80	72	250	70	2	3
	4	478.0	.17	.26	375	80	72	250	70	2	3
	5	478.8	.17	.26	375	80	72	250	70	2	3
	6	479.4	.20	.32	375	80	72	250	70	2	3
	7	480.2	.22	.35	375	80	72	250	70	2	3
	8	480.9	.14	.22	375	80	72	250	70	2	3
	9	481.4	.04	.07	375	80	72	250	70	2	3
	10	481.8	.35	.56	375	80	72	250	70	2	3
	11	482.7	1.20	2.00	370	80	72	250	70	2	4
	12	484.0	1.50	2.50	370	88	72	250	70	2	5
END:		485.785								12:01 PM	

Leak check: 0.00 cfm @ 8" Hg

condensate: 84 ml

silica gel: ~~6.0~~ g 13.5

Filter No. 8284

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules Boiler 2
10-26-82
Run No. 2

Pbar = 30.31

Da 228

	Port, Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	Vc/A/C
1	1 1	486.032	.90	1.50	350	80	76	250	70	1.23	5
2	2	487.4	.64	1.05	350	80	76	250	70	2	4
3	3	488.5	.17	.26	355	80	76	250	70	2	2
4	4	489.1	.90	1.50	355	80	76	250	70	2	5
5	5	490.5	1.05	1.75	360	84	76	250	70	2	6
6	6	491.9	1.30	2.20	360	86	76	250	70	2	7
7	7	493.6	1.60	2.70	365	90	76	250	70	2	8
8	8	495.3	1.50	2.50	360	92	76	250	70	2	8
9	9	497.1	1.05	1.75	360	92	76	250	70	2	6
10	10	498.6	.85	1.40	360	92	77	250	70	2	5
11	11	499.9	.90	1.50	355	92	78	250	70	2	5
12	12	501.3	1.05	1.75	350	92	78	250	70	2	6
13											
14	2 1	502.788	.83	1.35	350	92	78	250	70	2	5
15	2	504.1	.90	1.50	350	92	78	250	70	2	5
16	3	505.4	.90	1.50	355	92	79	250	70	2	5
17	4	506.8	1.05	1.75	360	94	80	250	70	2	6
18	5	508.3	.52	.82	360	93	80	250	70	2	4
19	6	509.3	.75	1.20	360	92	80	250	70	2	5
20	7	510.5	1.60	2.70	365	96	80	250	70	2	8
21	8	512.3	1.40	2.40	360	100	80	250	70	2	8
22	9	514.1	1.10	1.80	360	100	80	250	70	2	6
23	10	515.6	1.05	1.75	360	100	80	250	70	2	6
24	11	517.1	1.10	1.80	355	98	81	250	70	2	6
25	12	518.6	1.30	2.20	355	100	82	250	70	2	7
26											
27	3 1	520.218	.68	1.10	355	98	82	250	70	2	5
28	2	521.4	.96	1.50	355	96	82	250	70	2	6
29	3	522.8	1.05	1.75	355	96	82	250	70	2	6
30	4	524.4	0.97	1.60	360	98	82	250	70	2	6
31	5	525.7	.84	1.45	360	98	82	250	70	2	5
32	6	527.1	1.05	1.75	365	98	82	250	70	2	6
33	7	528.5	.22	.34	365	96	82	250	70	2	3
34	8	529.3	.60	.99	360	94	82	250	70	2	4
35	9	530.3	.65	1.05	360	94	82	250	70	2	4
36	10	531.5	1.05	1.75	355	95	82	250	70	2	6
37	11	532.9	1.40	2.40	355	98	82	250	70	2	8
38	12	534.6	1.40	2.40	355	100	82	250	70	2	8
39											
40											

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules No. 2 Boiler

10-26-82

Run No. 2 cont'd

10-26

	Port	Point	Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	V A C
1	4	1	536.3	.46	.74	355	96	82	250	70	2	4
2		2	537.3	.51	.81	355	94	82	250	70	2	4
3		3	538.4	.30	.48	360	94	82	250	70	2	3
4		4	539.2	.19	.30	360	92	82	250	70	2	3
5		5	539.8	.19	.30	360	90	82	250	70	2	3
6		6	540.5	.25	.39	360	90	82	250	70	2	3
7		7	541.2	.25	.39	360	90	82	250	70	2	3
8		8	541.9	.07	.10	360	90	82	250	70	2	2
9		9	542.3	.07	.10	360	88	82	250	70	2	2
10		10	542.8	.42	.67	360	88	82	250	70	2	4
11		11	543.7	.45	.72	355	90	82	250	70	2	4
12		12	544.6	.35	.55	350	90	82	250	70	2	4
13	END		545.500								3:01 PM	

Leak check, 0.02 cfm @ 8" Hg

Condensate: 86 ml

Silica gel: 13.5 g

Filter No. 8285

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules - Boiler 2

10-26-82

Run No. 3

Pbar = 20.23

	1	2	3	4	5	6		7		8	
	Port	Pt	Va	ΔP	ΔH	Ts	Ta in oar		Box Temp	Imp Temp	Time	V A C
1	1	1	545.619	.90	1.50	360	82	80	200	70	3:38P	4
2		2	547.0	.72	1.15	360	85	80	225	70	2 min	4
3		3	548.2	.30	.48	360	86	80	225	70	2	3
4		4	548.9	.88	1.30	365	86	80	225	70	2	4
5		5	550.3	1.05	1.75	370	88	80	225	70	2	5
6		6	551.7	1.30	2.20	370	92	80	250	70	2	5
7		7	553.2	1.60	2.70	370	95	80	250	70	2	6
8		8	555.1	1.40	2.40	370	97	80	250	70	2	6
9		9	556.8	1.05	1.75	365	97	80	250	70	2	5
10		10	558.2	.95	1.55	365	96	81	250	70	2	4
11		11	559.6	.95	1.55	365	96	81	250	70	2	4
12		12	560.9	1.05	1.75	365	96	81	250	70	2	5
13												
14	2	1	562.410	.84	1.40	365	96	81	250	70	2	4
15		2	563.7	.84	1.40	365	96	82	250	70	2	4
16		3	565.1	.86	1.45	365	96	81	250	70	2	4
17		4	566.4	.98	1.60	370	96	81	250	70	2	4
18		5	567.8	.16	.25	370	94	81	250	70	2	2
19		6	568.4	.88	1.45	370	90	81	250	70	2	4
20		7	569.6	1.60	2.70	375	96	81	250	70	2	6
21		8	571.4	1.50	2.50	375	100	82	250	70	2	6
22		9	573.1	1.05	1.75	370	100	82	250	70	2	5
23		10	574.6	.99	1.65	365	100	82	250	70	2	5
24		11	576.0	1.05	1.75	365	95	82	250	70	2	5
25		12	577.5	1.20	2.00	360	100	82	250	70	2	5
26												
27		1	579.345	.70	1.15	360	96	82	250	70	2	4
28		2	580.4	.95	1.60	360	94	82	250	70	2	5
29		3	581.7	1.00	1.65	360	96	82	250	70	2	5
30		4	583.2	.92	1.50	360	96	82	250	70	2	5
31		5	584.6	.85	1.40	360	96	82	250	70	2	5
32		6	585.8	1.05	1.75	365	96	82	250	70	2	3
33		7	587.3	.30	.48	365	94	81	250	70	2	3
34		8	588.1	0.70	1.15	365	92	80	250	70	2	4
35		9	589.3	.70	1.15	370	92	80	250	70	2	4
36		10	590.5	1.30	2.20	370	92	80	250	70	2	6
37		11	591.9	1.50	2.50	360	99	80	250	70	2	6
38		12	593.7	1.40	2.40	360	100	80	250	70	2	7
39												
40												

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A.

Hercules No. 2 Boiler
10-26-82
Run No. 3 cont'd

10-26-82

	Port, Point		Vm	ΔP	ΔH	Ts	Tm in	Tm out	Box Temp	Imp Temp	Time	A/C
1	4	1	595.371	.32	.51	360	96	80	250	70	2	3
2		2	596.2	.47	.75	360	92	81	250	70	2	4
3		3	597.2	.32	.51	360	92	81	250	70	2	3
4		4	598.0	.14	.22	360	90	81	250	70	2	3
5		5	598.6	.14	.22	360	88	80	250	70	2	3
6		6	599.1	.21	.33	360	88	80	250	70	2	3
7		7	599.8	.21	.33	360	88	80	250	70	2	3
8		8	600.4	.06	.08	360	87	80	250	70	2	2
9		9	600.8	.03	.04	360	86	80	250	70	2	2
10		10	601.0	.60	.97	360	86	80	250	70	2	4
11		11	602.1	.60	.97	360	90	80	250	70	2	4
12		12	603.2	.85	1.40	360	92	80	250	70	2	5
13	END		604.562								5:16 PM	

Leak Check:

condensate: 100 ml
silica gel: 16.5 gm

Filter No. 8238

© WILSON JONES COMPANY G7508 GREEN MADE IN U.S.A

Analytical Data

Hercules - Boiler No. 2
Tested: 10/26/82

FILTERS:	Run 1	Run 2	Run 3	
Filter Number		8285	8238	
Tare Weight, g	.5804	.5765	.5849	
Final Weight, g	.7066	.7702	.9585	
Net Gain, g	.1262	.1937	.3736	

PROBE WASH	Run 1	Run 2	Run 3	Blank
Volume, ml	179	180	240	200
Tare Weight, g	112.0236	112.7281	111.5101	114.3857
Final Weight, g	112.0847	112.9485	111.7335	114.3870
Net Gain, g	.0611	.2204	.2234	.0013
Blank Correction, g	-.0012	-.0012	-.0016	.0013

	Run 1	Run 2	Run 3	
Mn, mg	186.1	412.9	595.4	

PERFORMANCE EVALUATION TESTS
FOR THE
DETERMINATION OF PARTICULATE EMISS

HERCULES, INC.
HATTIESBURG, MISSISSIPPI


JANUARY, 1976

Environmental Protection Systems

ENGINEERING AND MANAGEMENT
AIR, LAND, AND WATER RESOUR


TEST No 1

HERCULES BOILER



WBA 1/22/76


46 1240
KE 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.



46 1240
20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO MADE IN U.S.A.

TEST NO. 3

HERCULES BOILER



WBA 1/22/76

46 1240
K&E 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.

HERCULES BOILER

RUN # 1

TRAVERSE POINT → PORT	R_1	R_2	R_3	R_4
1	.4	.38	.5	.5
2	.4	.38	.5	5
3	.38	.35	.35	NEGATIVE
4	.38	.35	.35	.17
5	.22	.3	.13	.17
6	.1	.22	.07	.17
7	.05	.07	.13	.17
8	.012	.3	.22	.17
9	.15	.38	.3	.25
10	.35	.4	.45	.25
11	.07	.4	.7	.25
12	.1	.4	.7	.25

STACK VELOCITY HEAD, INCHES H_2O

HERCULES BOILER — RUN #2

TRAVERSE POINT → PORT	R_1 4	R_2 3	R_3 2	R_4 1
1	.07	.45	.45	.43
2	.3	.45	.45	.6
3	NEGATIVE	.45	.43	.5
4	.25	.45	.43	.4
5	.3	.07	.3	.3
6	.3	.07	.2	.13
7	.25	.2	.07	.06
8	.3	.25	.07	.06
9	.3	.25	.45	NEGATIVE
10	.3	.45	.45	.06
11	.45	.6	.45	.13
12	.45	.6	.45	.15

STACK VELOCITY HEAD, INCHES H_2O

HERCULES BOILER RUN #3

TRAVERSE POINT ↓ / PORT →	R_1	R_2	R_3	R_4
1	.35	.55	.5	.4
2	.6	.5	.4	.2
3	.6	.4	.38	NEGATIVE
4	.35	.35	.38	.2
5	.2	.2	.3	.2
6	.13	.05	.3	.35
7	.07	.2	.2	.2
8	NEGATIVE	.3	.2	.2
9	.07	.4	.38	.2
10	.13	.6	.38	.3
11	.22	.6	.6	.3
12	.3	1.00	.6	.3

STACK VELOCITY HEAD, INCHES H_2O

PERFORMANCE EVALUATION TESTS

FOR THE

DETERMINATION OF PARTICULATE EMISSIONS

for

HERCULES, INC.

HATTIESBURG, MISSISSIPPI

by

ENVIRONMENTAL PROTECTION SYSTEMS

106 UPTON DRIVE

JACKSON, MISSISSIPPI

Test Number 76163

January, 1976

TABLE OF CONTENTS

	Page
PURPOSE	3
CONCLUSION	4
DISCUSSION	5
EMISSION SOURCE SAMPLING PROCEDURE	6
DESCRIPTION OF ISOKINETIC SAMPLING TRAIN	8
DESCRIPTION OF THE SAMPLING SITE	10
PARTICULATE CALCULATIONS	12
REFERENCES	18
ACKNOWLEDGMENTS	19
NOMENCLATURE	20
APPENDIX - RAW DATA AND CALIBRATION DATA	21

PURPOSE

The purpose of this performance evaluation test was to establish the particulate emissions from a woodwaste boiler owned and operated by Hercules, Inc., located at Hattiesburg, Mississippi. Environmental Protection Systems was retained to perform the required particulate emissions tests.

CONCLUSION

Three (3) performance tests were conducted on January 14, 1976, in accordance with the procedures outlined in the Federal Register, Volume 36, Number 247, Part II, by the Environmental Protection Agency and the Mississippi Air and Water Pollution Control Commission. The results of the three (3) tests are shown below in tabular form in the Data Summary.

DATA SUMMARY

Run Number	Emission Loading Grains/dscf	Emission Loading Corrected to 12% CO_2	Emission Rate lbs/hr	Percent Isokinetic (%)
1	.1209	.3225	60.41	98
2	.0693	.1848	35.30	98
3	.0639	.1705	34.30	98
Average	.0847	.2260	43.34	98

DISCUSSION

A performance evaluation test was conducted on January 14, 1976, on a woodwaste boiler operated by Hercules, Inc., located at Hattiesburg, Mississippi.

The boiler is classified as a combination boiler which is defined as a fuel burning operation utilizing a mixture of combustibles such as, but not limited to, fossil fuels plus bark, oil plus bark or spent wood, or water treatment sludge. According to the MAWPCC Air Quality Regulation APC-S-1, 1972, the combination boilers may be allowed emissions up to 0.30 grains per standard dry cubic foot. The average emissions for the tested boiler as determined by three (3) tests was found to be .0847 Grains/dscf.

EMISSION SOURCE SAMPLING PROCEDURE

The test methods and procedures used for this performance evaluation were those outlined in the Federal Register, Volume 36, Number 247, Part II, as promulgated by the Environmental Protection Agency (EPA). Method 1 for determination of sample and velocity traverses was used to arrive at the correct number of sampling points. The determination of stack gas velocity and volumetric flow rate was performed in accordance with Method 2 using a type S pitot tube. Method 3--Gas Analysis for Carbon Dioxide, Excess Air, and Dry Molecular Weight was used for this test and an integrated sample was collected and analyzed. Methods 4 and 5 were followed to establish the moisture content and particulate emissions, respectively.


The EPA Method 5 relies on the removal of a dust-laden gaseous sample from the duct followed by the subsequent removal of the particulate matter on a filter media. Concurrently a measurement of the sample volume is made to determine particulate concentration. The sample is removed from the stack by using a prescribed traversing procedure, which in effect is an approximate integration of collected mass and sample volume over the cross-sectional area of the

stack. The velocity distribution is also determined during the sample traverse. This information is used with the particulate concentration to determine mass emission rates. Method 5 requires that isokinetic sampling conditions be maintained. Thus at each traverse point the sample velocity at the nozzle is adjusted to equal the duct velocity. The sampling train required to maintain isokinetic conditions is discussed in the following section.

DESCRIPTION OF ISOKINETIC SAMPLING TRAIN

The sampling train used to conduct this sampling was manufactured by the Research Appliance Company according to the construction details provided by EPA. The sampling train can be divided into component parts as follows:

1. Nozzle and probe
2. Pitot tube (S-Type)
3. Cyclone or by-pass
4. Filter
5. Impinger
6. Sampling box
7. Umbilical cord
8. Meter or control box
9. External equipment
    a. Omega thermocouple-pyrometer
    b. Gas analysis apparatus (ORSAT)



1) Probe
2) Cyclone
3) Flask
4) Particulate Filter
5) Impingers (Greenburg-Smith)
6) Thermometer
7) Check Valve
8) Umbilical Cord
9) Vacuum Gage
10) Course Flow Adjust Valve
11) Fine Flow Adjust Valve
12) Oiler
13) Vacuum Pump
14) Filter
15) Dry Gas Meter
16) Orifice Tube
17) Incline Manometer
18) Solenoid Valves
19) Pitot
20) Thermocouple
21) Pyrometer

PROPERTY OF
RESEARCH APPLIANCE Co. ALLISON PARK, PA.

TOLERANCES DEC. ± FRACT. ±	TITLE STAK SAMPLER FLOW SYSTEM		
	DWG. NO. 1748	MATL	SCALE
NO. REQ'D	DRAWN BY R.G.	APPR.	DATE 6-23-69
FINISH		JIG NO.	ART NO.

DESCRIPTION OF SAMPLING SITE

The sampling site was located on a custom-built platform adjacent to the exhaust breeching approximately twenty (20) feet above the ground level. Four (4) sampling ports were located in a horizontal line equally spaced from each other. The sampling ports were located at less than one (1) stack diameter upstream and one (1) diameter downstream from a potential fluid disturbance. The equivalent stack diameter was calculated to be 55.38 inches. In this case, a required number of sampling points, forty-eight (48), were calculated in accordance with the prescribed EPA procedures. The sampling port arrangement and sampling points are shown in Figure 1.




FIGURE 1: Location of Ports and Traverse Points

PARTICULATE TEST CALCULATIONS

Plant Hercules, Stack Boiler, Date 1/14/76

Bar. Press. 30.54 "Hg, Stack Press. 30.54 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 279.8°F, Ave. Meter Temp. 79.6°F, Ave. $\sqrt{h}$ 0.55 "H_2O, Nozzle Dia. .375 in.

C_p 0.83, Meter Vol. 71.695 ft^3, Moisture plus Silica Gel 1003 ml, Sample Time 94 min.

Orsat Analysis: CO_2 4.5%, O_2 15.0%, CO 0.2%, N_2 78.3% Ave. Orifice ΔH 2.12 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) V_{wv} = (0.0474) x (Moisture + Silica Gel)ml = 47.54 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 72.23 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 119.77 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.40

5) FDA = (1.0) - (W) = 0.60

6) $M_d = [(0.44) \times (__ \%CO_2)] + [(0.32) \times (__ \%O_2)] + [(0.28) \times (__ \%N_2 + __ \%CO)]$ = 28.76

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 24.49

8) $G_s = \frac{M_s}{28.99}$ = 0.84

9) Excess Air, $EA = \frac{\left[(__ \%O_2) - (\frac{__}{2} \%CO) \right]}{[(0.266) \times (__ \%N_2)] - \left[(__ \%O_2) - (\frac{__}{2} \%CO) \right]} \times 100$ = 246 %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 2333 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 49814 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 29888 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 21856 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 73.81 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 98 %

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 98 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.3088 gm	0.1209	0.3225		60.41
Filter	0.2573 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.5661 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Stack Boiler, Date 11/14/76

Bar. Press. 30.54 "Hg, Stack Press. 30.54 "Hg, Stack Dia. 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 279.2°F, Ave. Meter Temp. 87.6°F, Ave. $\sqrt{h}$ .56 $"H_2O$, Nozzle Dia. .375 in.

C_p 0.83, Meter Vol. 72.329 ft^3, Moisture plus Silica Gel 1015 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.5%, O_2 15.0%, CO 0.2%, N_2 78.3% Ave. Orifice ΔH 2.44 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})\text{ml}$ = 48.11 scf

2) $V_{stpd} = (17.71) \times \left(P_o + \frac{\overline{\Delta H}}{13.6}\right) \times (V_m) \times \left(\frac{1}{T_m + 460}\right)$ = 71.86 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 119.97 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.40

5) $FDA = (1.0) - (W)$ = 0.60

6) $M_d = [(0.44) \times (___\%CO_2)] + [(0.32) \times (___\%O_2)] + [(0.28) \times (___\%N_2 + ___\%CO)]$ = 28.76

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 24.44

8) $G_s = \frac{M_s}{28.99}$ = .84

9) Excess Air, $EA = \frac{\left[(___\%O_2) - \left(\frac{___\%CO}{2}\right)\right]}{[(0.266) \times (___\%N_2)] - \left[(___\%O_2) - \left(\frac{___\%CO}{2}\right)\right]} \times 100$ = 246 %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 2375 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 50699 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 30420 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 22262 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (\text{Time}) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 73.58 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 98 %

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 98 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100 + EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.2075 gm	0.0693	0.1848		35.3
Filter	0.1153 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.3228 gm				

COMMENTS:

Run #3

PARTICULATE TEST CALCULATIONS

Plant Hercules, Stack Boiler, Date 1/14/76

Bar. Press. 30.54 "Hg, Stack Press. 30.54 "Hg, Stack Dia. 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 268.4°F, Ave. Meter Temp. 87.8°F, Ave. $\sqrt{h}$ 0.58 "H_2O, Nozzle Dia. .375 in.

C_p 0.83, Meter Vol. 76.192 ft^3, Moisture plus Silica Gel 1042 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.5%, O_2 15.0%, CO 0.2%, N_2 78.3% Ave. Orifice ΔH 2.62 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 49.39 scf

2) $V_{stpd} = (17.71) \times \left(P_o + \frac{\overline{\Delta H}}{13.6}\right) \times (V_m) \times \left(\frac{1}{T_m + 460}\right)$ = 75.70 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 125.09 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.39

5) $FDA = (1.0) - (W)$ = 0.61

6) $M_d = [(0.44) \times (__ \%CO_2)] + [(0.32) \times (__ \%O_2)] + [(0.28) \times (__ \%N_2 + __ \%CO)]$ = 28.76

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 24.51

8) $G_s = \frac{M_s}{28.99}$ = 0.85

9) Excess Air, $EA = \frac{\left[(__ \%O_2) - \left(\frac{__}{2} \%CO\right)\right]}{\left[(0.266) \times (__ \%N_2)\right] - \left[(__ \%O_2) - \left(\frac{__}{2} \%CO\right)\right]} \times 100$ = 246 %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 2427 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 51817 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 31609 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 23476 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (\text{Time}) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 77.59 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 98 %

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 98 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.2519 gm	0.0639	0.1705		34.3
Filter	0.0618 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.3137 gm				

COMMENTS:


REFERENCES

Environmental Protection Agency, "Standard of Performance for New Stationary Sources," Federal Register, Vol. 36, No. 247, Part II (1971).

Brenchly, D. L., Turley, C. D., and Yarmac, R. F., Industrial Source Sampling: Ann Arbor Science, Ann Arbor, Michigan (1973).

ACKNOWLEDGMENTS

A sincere thank you is extended to Mr. Charles Jordan and his staff for their assistance during the sampling period.



E.P.S. SOURCE SAMPLING NOMENCLATURE SHEET

PB - Barometric pressure, inches Hg
PS - Stack pressure, inches Hg
As - Stack area, sq. ft.
AS'- Effective area of positive stack gas flow, sq. ft.
NPTS - Number of traverse points where the pitot velocity head was greater than zero
TS - Stack temperature, ^{o}R
TM - Meter temperature, ^{o}R
$\sqrt{\overline{H}}$ - Average square root of velocity head, $\sqrt{\text{inches } H_2O}$
$\overline{\Delta H}$ - Average meter orifice pressure differential, inches H_2O
AN - Sampling nozzle area, square feet
CP - S-type pitot tube correction factor
VM - Recorded meter volume sample, cubic feet (meter conditions)
VC - Condensate and silica gel increase in impringers, milliliters
Po - Pressure at the dry test meter orifice, $\left[PB + \frac{\Delta H}{13.6}\right]$ inches Hg
STP - Standard conditions, dry, $70^{o}F$, 29.92 inches Hg

- -

VWV - Conversion of condensate in milliliters to water vapor in cubic feet (STP)
VSTPD - Volume sampled, cubic feet (STP)
VT - Total water vapor volume and dry gas volume sampled, cubic feet (STP)
W - Moisture fraction of stack gas
FDA - Dry gas fraction
MD - Molecular weight of stack gas, lbs/lb-mole (dry conditions)
MS - Molecular weight of stack gas, lbs/lb-mole (stack conditions)
GS - Specific gravity of stack gas, referred to air
EA - Excess air, %
$\sqrt{\text{HxTS}}$ - Average square root of velocity head times stack temperature
VS - Stack gas velocity, feet per minute
QS - Stack gas flow rate, cubic feet per minute (stack conditions)
QD - Stack gas flow rate, cubic feet per minute (dry conditions)
QSTPD - Stack gas flow rate, cubic feet per minute (STP)
PISO - Percent isokinetic volume sampled (method described in Federal Register)

APPENDIX

RAW DATA AND CALIBRATION DATA

DISCUSSION OF SAMPLING

In an effort to avoid structural damage to the existing boiler stack, EPS utilized a sampling site in the breeching selected by the Hercules engineering staff. The sampling site did not conform to the procedures set forth in the Federal Register; therefore, a maximum number of traverse points (48) was used.

Five (5) negative pressure points were encountered during the entire sampling program. Negative pressure was measured at one (1), two (2) and two (2) traverse points during sampling runs one, two, and three, respectively. These negative pressure traverse points were avoided and sampling was resumed at the next positive pressure point. During the first two tests, an access hatch was inadvertently left open which can account for some of the variation in results between tests. The moisture content was found to be higher than anticipated; however, the high value was accounted for in sampling and maintaining isokinesis.

CALIBRATION SUMMARY SHEET

Dry Gas Meter and Orifice

1. $\Delta H@$ = 2.00 for Meter Box S-1461.
2. = 1.01 for Meter Box S-1461.
3. $\Delta H@$ = 1.95 for Meter Box S-1936.
4. = 1.02 for Meter Box S-1936.

Nozzle (inches)

Micrometer Reading

1	2	3	4	AVG
.1873	.1876	.1875	.1876	.1875
.248	.249	.251	.249	.249
.249	.248	.250	.252	.250
.373	.376	.375	.376	.375
.377	.375	.374	.374	.375
.502	.495	.503	.498	.500

Pitot Tube

$$C_{p(s)} = C_{p(std)} \sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

$C_{p(s)}$ = 0.83 for tube 002.

Miscellaneous Equipment:

Description	Calibration Date
Barometer	1/6/76
Thermometers	1/6/76
Thermacouple/pyrometer	1/6/76
Magnehelic Gages	1/6/76

DRY MOLECULAR WEIGHT DETERMINATION

PLANT Hercules

DATE 1/14/76

SAMPLING (24-hr. CLOCK)

SAMPLING LOCATION Hattiesburg, Mississippi

SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) Integrated

ANALYTICAL METHOD Orsat

AMBIENT TEMPERATURE

OPERATOR Blunt

COMMENTS

RUN / GAS	1		2		3		AVERAGE NET VOLUME	MULTIPLIER	MOLECULAR WEIGHT OF STACK GAS (DRY BASIS) M_d, lb/lb-mole
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET			
CO_2	4.5	4.5					4.5	44/100	1.98
O_2 (NET IS ACTUAL O_2 READING MINUS ACTUAL CO_2 READING)	19.5	15.0					15.0	32/100	4.80
CO (NET IS ACTUAL CO READING MINUS ACTUAL O_2 READING)	19.7	0.2					0.2	28/100	0.06
N_2 (NET IS 100 MINUS ACTUAL CO READING)	78.3	78.3					78.3	28/100	21.92
								TOTAL	28.76

ENVIRONMENTAL PROTECTION SYSTEMS
Jackson, Mississippi

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules

Sampling Location Hattiesburg, Ms.

Date 1/14/76 Run No. 1

Time Start 9:25 Time End 11:10

Sampling Time/Point 2 min.

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.54 "Hg, Stack Press. 30.54 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather partly cloudy

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 1936 Meter Box No. 1

Meter ΔH@ 2.0 Pitot Corr. Factor ~~1.375~~ .84

Nozzle Dia. ~~.375~~ .336 in., Probe Len. 6 ft.


Probe Heater Set. 90? Nomograph Cf .53

Stack Dimensions 55.38 in

Stack Area 21.35 ft²

Stack Height ____ ft

Sketch of Stack



Mat'l Processing Rate ____

Final Gas Meter Reading 820.583 - 71.695 ft³

Initial Gas Meter Reading 748.888 ft³

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. A Filter No. 0021

Orsat: CO_2 ____
O_2 ____
CO ____
N_2 ____
Excess Air ____

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 8:50 am

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head ("H2O)	Meter Orifice Press. Diff. ("H2O) Calc.	Meter Orifice Press. Diff. ("H2O) Actual	Stack Gas Temp. (°F)	Gas Sample Temp. @Dry Gas Meter (°F) In	Gas Sample Temp. @Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
1		9:25	748.9	.40	~~3.20~~ 3.2		300	57	55	250	60	5
2			750.6	.40	~~3.2~~ 3.20		310	62	55	"	"	5
3			752.4	.38	~~2.9~~ 2.9		300	68	55	"	"	5
4							300	71	54	"	"	5

Run #7

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) Calc.	Meter Orifice Press. Diff. ("H_2O) Actual	Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF) In	Gas Sample Temp.@ Dry Gas Meter (^oF) Out	Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
5			755.8	~~.20~~ .22	1.69		300	65	56	250	60	2
6			757.2	.10	.82		310	68	58			1
7			758.3	.05	.41		310	76	58			1
8			759.0	.012	.10		310	76	60			1
9			759.5	.15	1.20		310	74	60			1
10			760.4	.35	2.70		270	78	61			5
11			762.0	.07	.58		270	80	62			1
12			763.2	.10	.82		270	80	63			1
1			764.1	.38	2.90		270	82	64			6
2			765.9	.38	2.90		275	85	66			6
3			767.6	.35	2.70		275	88	67			6
4			769.3	.35	2.70		275	90	68			6
5			770.0	.30	2.23		275	91	69			5
6			772.6	~~.20~~ .22	1.69		275	91	70			3
7			774.0	.07	.58		275	90	70			1
8			775.0	.30	2.70		275	90	71			5
9			776.7	.38	2.90		275	92	72			5
10			778.6	.40	3.20		275	94	73			6
11			780.3	.40	3.20		275	95	73			6
12			781.9	.40	3.20		275	96	74			6

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1			784.8	.50	3.80		270	94	65	250	60	7
2			786.0	.50	3.80		270	96	76			8
3			787.8	.35	2.70		270	98	78			5
4			789.6	.35	2.70		270	98	78			5
5			791.3	.13	1.08		270	98	78			2
6			792.6	~~.10~~ .07	.58		270	98	78			2
7			793.5	.13	1.08		275	93	78			2
8			794.4	~~.20~~ .22	1.69		275	92	78			2
9			795.8	.30	2.23		275	92	78			3
10			797.6	.45	3.42		275	96	78			7
11			799.3	.70	~~5.40~~ 5.35		275	100	79			12
12			801.4	.70	5.35		275	101	80			12
1			804.0	.50	3.80		275	102	80			7
2			806.0	.50	3.80		275	102	80			7
3			808.0	—								
4			808.1	.17	1.38		275	102	82			2
5			809.9	.17	1.38		275	102	82			2
6			811.0	.17	1.38		275	102	82			2
7			812.4	.17	1.38		275	102	82			2
8			813.9	.17	1.38		275	102	82			2

Run #1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			814.9	.25	1.95		275	98	82	250	60	3
10			816.2	.25	1.95		275	98	82			3
11			816.6	.25	1.95		275	98	82			3
12			819.0	.25	1.95		275	98	82			3

ENVIRONMENTAL PROTECTION SYSTEMS

Jackson, Mississippi

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules

Sampling Location Hattiesburg, Ms.

Date 1/14/76 Run No. 2

Time Start 11:25 Time End 1:05

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.54 "Hg, Stack Press. 30.54 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather clear & warm

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. ~~1936~~ Meter Box No. 1936

Meter ΔH@ 2.0 Pitot Corr. Factor ____

Nozzle Dia. .375 in., Probe Len. 6 ft.

Probe Heater Set. 900 Nomograph Cf .53

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 893.194 → 72.329 ft^3

Initial Gas Meter Reading 820.865 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. B Filter No. 0022

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt/Kreuz

Remarks: Leak ck ok 11:15 am

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1			820.9	.07	.58		275	76	76	250	60	2
2			821.7	~~.45~~ .30	2.32		275	78	76			2
3			822.9	—			~~275~~	79	77			
4				.25	1.85		275	80	76			3

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			824.3	.30	2.32		275	84	76	250	60	4
6			826.0	.30	2.32		275	87	76			4
7			827.5	.25	1.95		270	90	76			3
8			829.0	.30	2.32		270	90	76			4
9			830.7	.30	2.32		270	92	76			4
10			832.2	.30	2.32		270	93	76			4
11			834.0	.45	3.45		270	94	77			6
12			835.7	.45	3.45		270	96	77			6
1			838.0	.45	3.45		275	96	78			6
2			839.9	.45	3.45		275	98	78			6
3			841.7	.45	3.45		275	100	79			6
4			843.9	.45	3.45		275	100	80			6
5			846.1	.07	.58		275	100	80			1
6			846.7	.07	.58		275	100	80			1
7			847.6	.20	1.54		275	100	80			2
8			848.9	.25	1.95		275	100	80			2
9			850.2	.25	1.95		270	98	80			2
10			851.8	.45	3.45		270	98	80			6
11			853.7	.60	4.55		270	99	81			8
12			855.8	.60	4.55		285	104	81			8

Run #2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1			858.0	.45	3.45		300	104	82	250	60	5
2			859.9	.45	3.45		275	104	82			5
3			861.7	.43	3.30		275	104	82			5
4			863.7	.43	3.30		280	104	82			5
5			865.8	.30	2.32		275	104	82			3
6			867.3	.20	1.59		275	102	82			2
7			868.7	.07	.58		275	98	83			1
8			869.7	.07	.58		275	96	83			1
9			870.5	.45	3.45		290	96	83			5
10			872.4	.45	3.45		290	98	83			5
11			872.3	.45	3.45		290	100	83			5
12	/		872.2	.45	3.45		290	101	84			5
1			878.1	.43	3.30		295	101	84			5
2			879.9	.60	4.55		300	102	84			9
3			881.6	.50	3.80		300	102	84			6
4			883.6	.40	3.20		300	103	84			5
5			885.5	.30	2.32		300	103	84			4
6			887.2	.13	1.08		295	102	84			2
7			888.4	.06	.495		275	98	84			1
8			889.3	.06	.495		275	95	84			1

Run 2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			890.1	—						250	60	~~7~~
10			890.1	.06	.495		275	94	83			1
11			891.0	.13	1.08		275	92	83			2
12			892.0	.15	1.21		275	93	83			2

[redacted] ENVIRONMENTAL [redacted] TECH[redacted] SYSTEMS [redacted]
Jackson, Mississippi

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules

Sampling Location Hattiesburg, Ms.

Date 1/14/76 Run No. 3

Time Start 1:40 Time End 3:23

Sampling Time/Point 2 min.

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.54 "Hg, Stack Press. 30.54 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather cloudy

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 1 Meter Box No. 1936

Meter ΔH@ 2.0 Pitot Corr. Factor ____

Nozzle Dia. .375 in., Probe Len. 6 ft.

Probe Heater Set. 90% Nomograph Cf .53

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 971.451 → 76.192 ft^3

Initial Gas Meter Reading 895.259 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. B C Filter No. 0023

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt/Kreuz

Remarks: Leak ck ok 1:25 pm

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1			895.3	.35	2.70		275	70	69	250	60	2
2			896.9	.60	4.55		280	75	69	"	"	6
3			899.2	.60	4.55		280	84	70	"	"	6
4			901.2	.35	2.70		270	86	70	"	"	3

Run #3

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			903.1	.20	1.59		275	86	70	250	60	1
6			904.3	.13	1.08		275	87	70			1
7			905.5	.07	.58		275	85	70			1
8			906.4	—								
9			906.4	.07	.58		275	85	70			1
10			907.3	.13	1.08		275	85	71			1
11			908.3	.22	1.62		275	85	71			2
12			909.7	.30	2.32		275	87	72			3
~~1~~			911.3	.55	4.20		270	90	73			6
~~2~~			913.2	.50	3.80		270	94	74			6
3			915.3	.40	3.10		275	96	75			5
~~3~~4			917.2	.35	2.70		275	96	75			4
~~4~~5			918.8	.20	1.59		275	95	76			2
6			920.2	.05	.41		275	92	76			1
~~7~~			921.1	.20	1.59		275	92	77			2
8			922.3	.30	2.32		275	93	77			3
9			923.8	.40	3.10		275	95	78			4
10			925.8	.60	4.55		270	98	80			7
11			928.2	.60	4.55		270	98	80			7
12			929.5	1.00	7.50		275	106	81			14

Run #3

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1			933.1	.50	3.80		275	106	82	250	60	4
2			934.9	.40	3.10		275	108	83			4
3			936.8	.38	2.92		275	107	83			3
4			938.8	.38	2.92		275	107	83			3
5			940.4	.30	2.32		275	106	85			2
6			942.0	.30	2.32		275	106	85			2
7			944.0	.20	1.59		270	105	85			2
8			945.2	.20	1.59		270	103	86			2
9			946.7	.38	2.92		275	103	86			4
10			948.7	.38	2.92		275	105	87			4
11			950.3	.60	4.55		275	107	87			6
12	/		952.5	.60	4.55		275	107	87			6
1			954.8	.40	3.10		275	107	88			4
2			956.6	.20	1.59		275	107	88			2
3			957.8	—								
4			957.8	.20	1.59		275	105	88			2
5			958.7	.20	1.59		275	105	88			2
6			961.0	.35	2.70		275	103	88			3
7			962.3	.20	1.59		275	103	88			2
8			963.8	.20	1.59		275	103	88			2

Run #3

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			965.2	.20	1.59		275	103	88	250	60	2
10			966.5	.30	2.32		275	103	88			3
11			968.1	.30	2.32		275	103	88			3
12			969.8	.30	2.32		275	103	88			3

PERFORMANCE EVALUATION TEST
FOR THE DETERMINATION OF
PARTICULATE EMISSIONS

HERCULES, INCORPORATED
HATTIESBURG, MISSISSIPPI

JUNE, 1976

Environmental Protection Systems

ENGINEERING AND LABORATORY
SERVICES FOR
AIR, LAND, AND WATER RESOURCE

PERFORMANCE EVALUATION TEST
FOR THE DETERMINATION OF
PARTICULATE EMISSIONS

for

Hercules, Incorporated

Hattiesburg, Mississippi

by

Environmental Protection Systems

106 Upton Drive

Jackson, Mississippi

Test Number 76183

June, 1976

TABLE OF CONTENTS

	Page
PURPOSE	3
CONCLUSION	4
DISCUSSION	5
EMISSION SOURCE SAMPLING PROCEDURE	6
DESCRIPTION OF ISOKINETIC SAMPLING TRAIN	8
DESCRIPTION OF THE SAMPLING SITE	10
PARTICULATE CALCULATIONS	12
REFERENCES	18
ACKNOWLEDGMENTS	19
NOMENCLATURE	20
APPENDIX - RAW DATA AND CALIBRATION DATA	21

PURPOSE

The purpose of this performance evaluation test was to establish the particulate emission from a stack servicing two woodwaste boilers. The boilers, located at Hattiesburg, Mississippi, are owned and operated by Hercules, Incorporated. EPS was retained to perform the required emissions tests.

CONCLUSION

Six (6) performance tests using two nozzle sizes were conducted on each of the two boilers on May 20 and 21, 1976 in accordance with the procedures outlined in the Federal Register, Volume 36, Number 247, Part II, by the U.S. Environmental Protection Agency and the Mississippi Air and Water Pollution Control Commission. The results of the tests are shown in tabular form in the Data Summary.

DATA SUMMARY

Boiler No.	Test No.	Grain Loading Grains/dscf	Nozzle Size	Emission Rate lbs/hr.	Percent Isokinetic (%)
1	1	0.0885	3/8"	40.0	102
1	2*	0.0944	3/8"	35.6	108
1	3*	0.0897	3/8"	35.1	103
1	Ave	0.0909	3/8"	36.9	104
1	1	0.0371	3/16"	15.1	102
1	2	0.0297	3/16"	11.5	101
1	3	0.0547	3/16"	21.1	98
1	Ave	0.0405	3/16"	15.9	100

Boiler No.	Test No.	Grain Loading Grains/dscf	Nozzle Size	Emission Rate lbs/hr	Percent Isokinetic (%)
2	1*	0.1658	3/8"	62.5	109
2	2	0.0648	3/8"	23.7	106
2	3**	0.1205	3/8"	43.6	109
2	Ave	0.1170	3/8"	43.2	108
2	1	0.0854	3/16"	30.3	107
2	2	0.0928	3/16"	36.1	105
2	3*	0.1612	3/16"	60.0	103
2	Ave	0.1131	3/16"	42.1	105

	Grain Loading Grains/dscf	
	Actual	Allowable
Stack Total (3/8" nozzle)	0.1033	0.30
Stack Total (3/16"nozzle)	0.0758	0.30

*Fire cleaning in boiler during all or most of test

**Fire Cleaning in boiler during approximately half of test

DISCUSSION

Performance evaluation tests were conducted on May 20 and 21, 1976, on two woodwaste boilers, boiler # 1 (east) and boiler # 2 (west), both common to the south stack. The boilers are operated by Hercules, Incorporated, located at Hattiesburg, Mississippi. The boilers at this facility perform two major operational functions: Specifically the boilers are used to incinerate mostly wood waste generated by the various processes and to process steam for plant usage. Simultaneous performance tests were conducted using prodedures set forth by EPA and the MAWPCC which are described in the Appendix under Discussion of Sampling.

The boilers tested are classified as combination type which has been defined by the MAWPCC as a fuel-burning operation which utilized a mixture of combustibles such as, but not limited to, fossil fuels plus bark, oil plus bark, spent wood, or water treatment sludge. According to the MAWPCC Air Quality Regulations APC-5-1, 1972, a combination boiler may be allowed emissions up to 0.30 grains per standard cubic foot. The average emissions for the tested boilers with both nozzle sizes can be found in the Data Summary.

EMISSION SOURCE SAMPLING PROCEDURE

The test methods and procedures used for this performance evaluation were those outlined in the Federal Register, Volume 36, Number 247, Part II, as promulgated by the Environmental Protection Agency (EPA). Method 1 for determination of sample and velocity traverses was used to arrive at the correct number of sampling points. The determination of stack gas velocity and volumetric flow rate was performed in accordance with Method 2 using a type S pitot tube. Method 3--Gas Analysis for Carbon Dioxide, Excess Air, and Dry Molecular Weight was used for this test and an integrated sample was collected and analyzed. Methods 4 and 5 were followed to establish the moisture content and particulate emissions, respectively.


The EPA Method 5 relies on the removal of a dust-laden gaseous sample from the duct followed by the subsequent removal of the particulate matter on a filter media. Concurrently a measurement of the sample volume is made to determine particulate concentration. The sample is removed from the stack by using a prescribed traversing procedure, which in effect is an approximate integration of collected mass and sample volume over the cross-sectional area of the

stack. The velocity distribution is also determined during the sample traverse. This information is used with the particulate concentration to determine mass emission rates. Method 5 requires that isokinetic sampling conditions be maintained. Thus at each traverse point the sample velocity at the nozzle is adjusted to equal the duct velocity. The sampling train required to maintain isokinetic conditions is discussed in the following section.

DESCRIPTION OF ISOKINETIC SAMPLING TRAIN

The sampling train used to conduct this sampling was manufactured by the Research Appliance Company according to the construction details provided by EPA. The sampling train can be divided into component parts as follows:

1. Nozzle and probe
2. Pitot tube (S-Type)
3. Cyclone or by-pass
4. Filter
5. Impinger
6. Sampling box
7. Umbilical cord
8. Meter or control box
9. External equipment
    a. Omega thermocouple-pyrometer
    b. Gas analysis apparatus (ORSAT)



1) Probe
2) Cyclone
3) Flask
4) Particulate Filter
5) Impingers (Greenburg-Smith)
6) Thermometer
7) Check Valve
8) Umbilical Cord
9) Vacuum Gage
10) Course Flow Adjust Valve
11) Fine Flow Adjust Valve
12) Oiler
13) Vacuum Pump
14) Filter
15) Dry Gas Meter
16) Orifice Tube
17) Incline Manometer
18) Solenoid Valves
19) Pitot
20) Thermocouple
21) Pyrometer

PROPERTY OF
RESEARCH APPLIANCE Co. ALLISON PARK, PA

TOLERANCES DEC. ± FRACT. ±	TITLE STAKSAMPLER FLOW SYSTEM		
	DWG. NO. 1748	MAT'L	SCALE
NO. REQ'D	DRAWN BY R.G.	APPR.	DATE 6-23-69
FINISH		JIG NO.	ART NO.

DESCRIPTION OF THE SAMPLING SITES

The sampling sites were located on custom built platforms adjacent to the exhaust breechings approximently twenty (20) feet above the ground level. Since each breeching has the same dimensions, the following discription will apply to both breechings.

Four (4) sampling ports were located in a horizontal line equally spaced from each other. The sampling ports were located at less than one (1) stack diameter upstream and downstream from a potential fluid disturbance. The equivalent stack diameter was calculated to be 55.38 inches. In this case, a required number of sampling points, forty-eight (48), were calculated in accordance with the prescribed EPA procedures. The sampling port arrangements and sampling points are shown in Figure I.




FIGURE 1: Location of Ports and Traverse Points

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 1, Date 5/20/76

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 387 °F, Ave. Meter Temp 94.9°F, Ave. $\sqrt{h}$ 0.96 "H_2O, Nozzle Dia. .375 in.*

C_p 0.83, Meter Vol. 43.757 ft^3, Moisture plus Silica Gel 28 ml, Sample Time 88 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH 0.95 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) V_{wv} = (0.0474) x (Moisture + Silica Gel)ml = 1.33 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 42.51 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 43.84 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.03

5) FDA = (1.0) - (W) = 0.97

6) $M_d = [(0.44)x(__\%CO_2)] + [(0.32)x(__\%O_2)] + [(0.28)x(__\%N_2 + __\%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.01

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[\frac{(__\%O_2) - (__\%CO)}{2}\right]}{[(0.266)x(__\%N_2)] - \left[(__\%O_2) - \frac{(__\%CO)}{2}\right]} \times 100$ = --- %

10) $\bar{U} = (174) \times (C_p) \times (\sqrt{\bar{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 4004 fpm

11) $Q_s = (\bar{U}) \times (A_s)$ = 85492 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 82927 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 52688 cfm

14) $V_i = (\bar{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 41.61 scf

15) *Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 102 %

*Percent Isokinetic based on a 3/16" nozzle

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 102 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.1211 gm	0.0885	0.2260		40.0
Filter	0.1226 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.2437 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 1, Date 5/20/76

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 379 °F, Ave. Meter Temp 110 °F, Ave. $\sqrt{h}$ 0.80 $"H_2O$, Nozzle Dia. 0.375 in. *

C_p 0.83, Meter Vol. 41.516 ft^3, Moisture plus Silica Gel 27 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.7%, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH 0.80 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})\text{ml}$ = 1.28 scf

2) $V_{stpd} = (17.71) \times \left(P_o + \frac{\overline{\Delta H}}{13.6}\right) \times (V_m) \times \left(\frac{1}{T_m + 460}\right)$ = 39.25 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 40.53 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.03

5) $FDA = (1.0) - (W)$ = 0.97

6) $M_d = [(0.44)\times(__\%CO_2)] + [(0.32)\times(__\%O_2)] + [(0.28)\times(__\%N_2 + __\%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.00

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(__\%O_2) - \left(\frac{__\%CO}{2}\right)\right]}{[(0.266)\times(__\%N_2)] - \left[(__\%O_2) - \left(\frac{__\%CO}{2}\right)\right]} \times 100$ = --- %

10) $\bar{U} = (174) \times (C_p) \times (\sqrt{\bar{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3321 fpm

11) $Q_s = (\bar{U}) \times (A_s)$ = 70906 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 68779 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 44116 cfm

14) $V_i = (\bar{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 36.42 scf

15) * Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 108 %

*Percent Isokinetic based on 3/16 inch nozzle

Run # 2

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 108 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.1043 gm	0.0944	0.2409		35.6
Filter	0.1359 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.2402 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 1, Date 5/21/76

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 378 °F, Ave. Meter Temp 102 °F, Ave. $\sqrt{h}$ 0.83 $"H_2O$, Nozzle Dia. 0.375 in. *

C_p 0.83, Meter Vol. 40.686 ft^3, Moisture plus Silica Gel 24 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1%, CO 0.2 %, N_2 80.0% Ave. Orifice ΔH 0.74 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 1.14 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 38.83 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 39.97 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.03

5) FDA = (1.0) - (W) = 0.97

6) $M_d = [(0.44) \times (___ \%CO_2)] + [(0.32) \times (___ \%O_2)] + [(0.28) \times (___ \%N_2 + ___ \%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.03

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(___ \%O_2) - (\frac{___ \%CO}{2}) \right]}{[(0.266) \times (___ \%N_2)] - \left[(___ \%O_2) - (\frac{___ \%CO}{2}) \right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \sqrt{\frac{T_s + 460}{G_s}} \times \sqrt{\frac{29.92}{P_s}}$ = 3452 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 73691 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 71480 cfm

13) $Q_{stpd} = (Q_d) (\frac{70 + 460}{T_s + 460}) \times (\frac{P_s}{29.92})$ = 45692 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (Time) \times (\frac{70 + 460}{T_s + 460}) \times (\frac{P_s}{29.92})$ = 37.72 scf

15) * Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 103 %

*Percent Isokinetic based on 3/16 inch nozzle

3/8 Inch nozzle Boiler # 1
Run # 3

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 103 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.1247 gm	0.0897	0.2290		35.1
Filter	0.1010 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.2257 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 2, Date 5/20/76

Bar. Press. 30.37 "Hg, Stack Press 30.38 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 380 °F, Ave. Meter Temp. 94.5F, Ave. $\sqrt{h}$ 0.79 "H_2O, Nozzle Dia. 0.375 in. *

C_p 0.83 Meter Vol. 40.700 ft^3, Moisture plus Silica Gel 17 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH 0.67 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 0.81 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 39.54 scf

3) $V_t = (V_{wv}) + (v_{stpd})$ = 40.35 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.02

5) $FDA = (1.0) - (W)$ = 0.98

6) $M_d = [(0.44) \times (___\%CO_2)] + [(0.32) \times (___\%O_2)] + [(0.28) \times (___\%N_2 + ___\%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.13

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(___\%O_2) - (\frac{___}{2}\%CO) \right]}{\left[(0.266) \times (___\%N_2) \right] - \left[(___\%O_2) - (\frac{___}{2}\%CO) \right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3282 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 70061 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 68660 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 43987 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 36.32 scf

15) * Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 109 %

* Percent Isokinetic based on a 3/16 inch nozzle

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 109 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.2633 gm	0.1658	0.4234		62.5
Filter	0.1619 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.4252 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 2, Date 5/20/76

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 388 °F, Ave. Meter Temp. 109 °F, Ave. $\sqrt{h_o}$ 0.77 $"H_2O$, Nozzle Dia. 0.375 in. *

C_p 0.83, Meter Vol. 39.366 ft^3, Moisture plus Silica Gel 16 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.7%, O_2 15.1%, CO 0.2 %, N_2 80.0% Ave. Orifice ΔH 0.67 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 0.76 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 37.27 scf

3) $V_t = (V_{wv}) + (v_{stpd})$ = 38.03 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.02

5) $FDA = (1.0) - (W)$ = 0.98

6) $M_d = [(0.44)x(___\%CO_2)] + [(0.32)x(___\%O_2)] + [(0.28)x(___\%N_2 + ___\%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.13

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[\frac{(___\%O_2) - (___\%CO)}{2}\right]}{[(0.266)x(___\%N_2)] - \left[(___\%O_2) - \frac{(___\%CO)}{2}\right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \sqrt{\frac{T_s + 460}{G_s}} \times \sqrt{\frac{29.92}{P_s}}$ = 32.14 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 68612 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 67240 cfm

13) $Q_{stpd} = (Q_d) (\frac{70 + 460}{T_s + 460}) \times (\frac{P_s}{29.92})$ = 42671 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (\text{Time}) \times (\frac{70 + 460}{T_s + 460}) \times (\frac{P_s}{29.92})$ = 35.23 scf

15) * Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 106 %

* Percent Isokinetic based on 3/16 inch nozzle

3/8" Nozzle
Run # 2

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 106 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.0861 gm	0.0648	0.1655		32.7
Filter	0.0705 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.1566 gm				

COMMENTS:

Run # 3

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 2, Date 5/21/76

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 371 °F, Ave. Meter Temp 100 °F, Ave. $\sqrt{h}$ 0.76 $"H_2O$, Nozzle Dia. 0.375 in. *

C_p 0.83, Meter Vol. 38.896 ft^3, Moisture plus Silica Gel 14 ml, Sample Time 90 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH 0.63 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})\text{ml}$ = 0.66 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\Delta H}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 37.24 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 37.91 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.02

5) $FDA = (1.0) - (W)$ = 0.98

6) $M_d = [(0.44)x(__\%CO_2)] + [(0.32)x(__\%O_2)] + [(0.28)x(__\%N_2 + __\%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.16

8) $G_s = \frac{M_s}{28.99}$ = 1.01

9) Excess Air, $EA = \frac{\left[(__\%O_2) - \frac{(__\%CO)}{2}\right]}{[(0.266)x(__\%N_2)] - \left[(__\%O_2) - \frac{(__\%CO)}{2}\right]} \times 100$ = --- %

10) $\bar{U} = (174) \times (C_p) \times (\sqrt{\bar{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3132 fpm

11) $Q_s = (\bar{U}) \times (A_s)$ = 66860 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 65523 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 42237 cfm

14) $V_i = (\bar{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 34.11 scf

15) * Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 109 %

*Percent Isokinetic based on 3/16 inch nozzle

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 109 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.1515 gm	0.1205	0.3077		43.6
Filter	0.1394 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.2909 gm				

COMMENTS:

Run # 1

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 1, Date 5/20/76

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg, Stack Dia. 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 392 °F, Ave. Meter Temp. 112 °F, Ave. $\sqrt{h}$ .87 $"H_2O$, Nozzle Dia. .1875 in.

C_p 0.83 Meter Vol. 40.867 ft^3, Moisture plus Silica Gel 26.5 ml, Sample Time 88 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1%, CO 0.2 %, N_2 80.0% Ave. Orifice ΔH 0.82 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 1.26 scf

2) $V_{stpd} = (17.71) \times \left(P_o + \frac{\overline{\Delta H}}{13.6}\right) \times (V_m) \times \left(\frac{1}{T_m + 460}\right)$ = 38.50 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 39.76 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.03

5) $FDA = (1.0) - (W)$ = 0.97

6) $M_d = \left[(0.44)x(___\%CO_2)\right] + \left[(0.32)x(___\%O_2)\right] + \left[(0.28)x(___\%N_2 + ___\%CO)\right]$ = 29.36

7) $M_s = \left[(M_d) \times (FDA)\right] + \left[(18) \times (W)\right]$ = 29.00

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(___\%O_2) - \left(\frac{___\%CO}{2}\right)\right]}{\left[(0.266)x(___\%N_2)\right] - \left[(___\%O_2) - \left(\frac{___\%CO}{2}\right)\right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3640 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 77705 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 75374 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 47609 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (\text{Time}) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 37.60 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 102 %

3/16 Nozzle Size: " -
Run # 1

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 102 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.0601 gm	0.0371	0.0948		15.1
Filter	0.0325 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.0926 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 1, Date 5/21/76

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 382 °F, Ave. Meter Temp. 93 °F, Ave. $\sqrt{h}$ 0.82 "H_2O, Nozzle Dia. .1875 in.

C_p 0.83, Meter Vol. 36.884 ft^3, Moisture plus Silica Gel 23 ml, Sample Time 88 min.

Orsat Analysis: CO_2 4.7%, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH 0.75 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 1.09 scf

2) $V_{stpd} = (17.71) \times \left(P_o + \frac{\overline{\Delta H}}{13.6}\right) \times (V_m) \times \left(\frac{1}{T_m + 460}\right)$ = 35.77 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 36.86 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.03

5) $FDA = (1.0) - (W)$ = 0.97

6) $M_d = \left[(0.44)x(__\%CO_2)\right] + \left[(0.32)x(__\%O_2)\right] + \left[(0.28)x(__\%N_2 + __\%CO)\right]$ = 29.36

7) $M_s = \left[(M_d) \times (FDA)\right] + \left[(18) \times (W)\right]$ = 29.02

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(__\%O_2) - \frac{(__\%CO)}{2}\right]}{\left[(0.266)x(__\%N_2)\right] - \left[(__\%O_2) - \frac{(__\%CO)}{2}\right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3418 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 72977 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 70788 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 45034 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (\text{Time}) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 35.56 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 101 %

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 101 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.0397 gm	0.0297	0.0759		11.5
Filter	0.0292 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.0689 gm				

COMMENTS:

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 1, Date 5/21/76

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 383 °F, Ave. Meter Temp 107 °F, Ave. $\sqrt{h}$ .82 $"H_2O$, Nozzle Dia. .1875 in.

C_p 0.83, Meter Vol. 35.870 ft^3, Moisture plus Silica Gel 21 ml, Sample Time 86 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH .74 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 1.00 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 33.93 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 34.93 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.03

5) $FDA = (1.0) - (W)$ = 0.97

6) $M_d = [(0.44) \times (___ \%CO_2)] + [(0.32) \times (___ \%O_2)] + [(0.28) \times (___ \%N_2 + ___ \%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.03

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(___ \%O_2) - (\frac{___ \%CO}{2})\right]}{\left[(0.266) \times (___ \%N_2)\right] - \left[(___ \%O_2) - (\frac{___ \%CO}{2})\right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3421 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 73032 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 70841 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 45000 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (\text{Time}) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 34.73 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 98 %

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 98 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.0813 gm	0.0547	.1396		21.1
Filter	0.0389 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.1202 gm				

COMMENTS:

Run # 1

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc, Stack Boiler # 2, Date 5/20/76

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 394 °F, Ave. Meter Temp. 113 °F, Ave. $\sqrt{h}$ .75 "H_2O, Nozzle Dia. .1875 in.

C_p 0.83, Meter Vol. 40.725 ft^3, Moisture plus Silica Gel 17.5 ml, Sample Time 96 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1 %, CO 0.2 %, N_2 80.0 % Ave. Orifice ΔH 0.62 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) V_{wv} = (0.0474) x (Moisture + Silica Gel)ml = 0.83 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 38.28 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 39.11 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.02

5) FDA = (1.0) - (W) = 0.98

6) $M_d = [(0.44) \times (__ \%CO_2)] + [(0.32) \times (__ \%O_2)] + [(0.28) \times (__ \%N_2 + __ \%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.12

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(__ \%O_2) - (\frac{__}{2} \%CO) \right]}{\left[(0.266) \times (__ \%N_2) \right] - \left[(__ \%O_2) - (\frac{__}{2} \%CO) \right]} \times 100$ = --- %

10) $\bar{U} = (174) \times (C_p) \times (\sqrt{\bar{h}}) \times \sqrt{\frac{T_s + 460}{G_s}} \times \sqrt{\frac{29.92}{P_s}}$ = 3141 fpm

11) $Q_s = (\bar{U}) \times (A_s)$ = 67066 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 65725 cfm

13) $Q_{stpd} = (Q_d) (\frac{70 + 460}{T_s + 460}) \times (\frac{P_s}{29.92})$ = 41416 cfm

14) $V_i = (\bar{U}) \times (A_n) \times (FDA) \times (Time) \times (\frac{70 + 460}{T_s + 460}) \times (\frac{P_s}{29.92})$ = 35.68 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 107 %

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 107 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.0742 gm	0.0854	0.2182		30.3
Filter	0.1378 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.2120 gm				

COMMENTS:

Run # 2

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 2, Date 5/21/76

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 383 °F, Ave. Meter Temp. 94 °F, Ave. $\sqrt{h}$ .82 "H_2O, Nozzle Dia. .1875 in.

C_p 0.83, Meter Vol. 40.820 ft^3, Moisture plus Silica Gel 18 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.7%, O_2 15.1%, CO 0.2%, N_2 80.0% Ave. Orifice ΔH .74 "H_2O

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) $V_{wv} = (0.0474) \times (\text{Moisture + Silica Gel})ml$ = 0.85 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 39.52 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 40.37 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.02

5) $FDA = (1.0) - (W)$ = 0.98

6) $M_d = [(0.44) \times (___\%CO_2)] + [(0.32) \times (___\%O_2)] + [(0.28) \times (___\%N_2 + ___\%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.12

8) $G_s = \frac{M_s}{28.99}$ = 1.00

9) Excess Air, $EA = \frac{\left[(___\%O_2) - \frac{(___\%CO)}{2}\right]}{\left[(0.266) \times (___\%N_2)\right] - \left[(___\%O_2) - \frac{(___\%CO)}{2}\right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3420 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 73020 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 71560 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 45471 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 37.54 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 105 %

3/16 " nozzle Boiler # 2
Run # 2

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 105 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.1558 gm	0.0928	.2368		36.1
Filter	0.0818 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.2376 gm				

COMMENTS:

Run # 3

PARTICULATE TEST CALCULATIONS

Plant Hercules, Inc., Stack Boiler # 2, Date 5/21/76

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg, Stack Dia 55.38 in., Stack Area 21.35 ft^2

Ave. Stack Temp. 389 °F, Ave. Meter Temp. 105 °F, Ave. $\sqrt{h}$ .79 $"H_2O$, Nozzle Dia. .1875 in.

C_p 0.83, Meter Vol. 39.102 ft^3, Moisture plus Silica Gel 15 ml, Sample Time 92 min.

Orsat Analysis: CO_2 4.7 %, O_2 15.1 % CO 0.2 %, N_2 80.0 % Ave. Orifice ΔH .67 $"H_2O$

Nozzle Dia. and Area: 1/4 in.---0.000341 ft^2, 3/8 in.---0.000767 ft^2, 1/2 in.---0.013 ft^2

3/16 in.---0.0001916 ft^2, 1/8 in.---0.000085 ft^2

1) V_{wv} = (0.0474) x (Moisture + Silica Gel)ml = 0.71 scf

2) $V_{stpd} = (17.71) \times (P_o + \frac{\overline{\Delta H}}{13.6}) \times (V_m) \times (\frac{1}{T_m + 460})$ = 37.11 scf

3) $V_t = (V_{wv}) + (V_{stpd})$ = 37.82 scf

4) $W = \frac{V_{wv}}{V_t}$ = 0.02

5) FDA = (1.0) - (W) = 0.98

6) $M_d = [(0.44) \times (___ \%CO_2)] + [(0.32) \times (___ \%O_2)] + [(0.28) \times (___ \%N_2 + ___ \%CO)]$ = 29.36

7) $M_s = [(M_d) \times (FDA)] + [(18) \times (W)]$ = 29.14

8) $G_s = \frac{M_s}{28.99}$ = 1.01

9) Excess Air, $EA = \frac{\left[(___ \%O_2) - \frac{(___ \%CO)}{2} \right]}{\left[(0.266) \times (___ \%N_2) \right] - \left[(___ \%O_2) - \frac{(___ \%CO)}{2} \right]} \times 100$ = --- %

10) $\overline{U} = (174) \times (C_p) \times (\sqrt{\overline{h}}) \times \left(\sqrt{\frac{T_s + 460}{G_s}}\right) \times \left(\sqrt{\frac{29.92}{P_s}}\right)$ = 3290 fpm

11) $Q_s = (\overline{U}) \times (A_s)$ = 70248 cfm

12) $Q_d = (Q_x) \times (FDA)$ = 68843 cfm

13) $Q_{stpd} = (Q_d) \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 43436 cfm

14) $V_i = (\overline{U}) \times (A_n) \times (FDA) \times (Time) \times \left(\frac{70 + 460}{T_s + 460}\right) \times \left(\frac{P_s}{29.92}\right)$ = 35.86 scf

15) Percent Isokinetic $= \frac{(V_{stpd})(100)}{(V_i)}$ = 103 %

3/16 " nozzle Boiler # 2
Run # 3

PARTICULATE TEST CALCULATIONS - Cont'd.

16) Percent Isokinetic by the EPA = $\dfrac{\left[(0.00267)\times(V_{H_2O})+\dfrac{(Vm)}{(Tm+460)}\times(P_{bar}+\dfrac{\Delta H}{13.6})\right](Ts+460)}{(Vs)\times(Time)\times(Ps)\times(An)}$ = 103 %

17) $E_{stp} = \dfrac{(15.43)\times(Y)}{V_{stpd}}$

18) $E_{12} = \dfrac{(12)\times(E_{stp})}{(CO_2\%)}$

19) $E_{50} = \dfrac{(E_{stp})\times(100+EA\%)}{150}$

20) $E_m = (E_{stp})\times(Q_{stpd})\times(0.00857)$

Particulate Lab Analysis (Y)		Particulate Concentrations, grains/scf (E_{stp})	(E_{12})	(E_{50})	Emission Rate, lbs/hr. (E_m)
Probe	0.1236 gm	0.1612	0.4115		60.0
Filter	0.2610 gm				
Imp. H_2O	gm				
Organics	gm				
After Filter	gm				
Total	0.3876 gm				

COMMENTS:


REFERENCES

Environmental Protection Agency, "Standard of Performance for New Stationary Sources," Federal Register, Volume 36, No. 247, Part II (1971).

Brenchly, D. L., Turley, C. D., and Yarmac, R. F., Industrial Source Sampling: Ann Arbor Science, Ann Arbor, Michigan (1973).

ACKNOWLEDGMENTS

A sincere thank you is extended to Mr. Charles Jordan and his staff for their assistance during the sampling period.



E.P.S. SOURCE SAMPLING NOMENCLATURE SHEET

PB - Barometric pressure, inches Hg
PS - Stack pressure, inches Hg
As - Stack area, sq. ft.
AS'- Effective area of positive stack gas flow, sq. ft.
NPTS - Number of traverse points where the pitot velocity head was greater than zero
TS - Stack temperature, ^{o}R
TM - Meter temperature, ^{o}R
$\sqrt{\overline{H}}$ - Average square root of velocity head, $\sqrt{\text{inches } H_2O}$
$\overline{\Delta H}$ - Average meter orifice pressure differential, inches H_2O
AN - Sampling nozzle area, square feet
CP - S-type pitot tube correction factor
VM - Recorded meter volume sample, cubic feet (meter conditions)
VC - Condensate and silica gel increase in impringers, milliliters
Po - Pressure at the dry test meter orifice, $\left[PB + \frac{\Delta H}{13.6}\right]$ inches Hg
STP - Standard conditions, dry, $70^{o}F$, 29.92 inches Hg

- -

VWV - Conversion of condensate in milliliters to water vapor in cubic feet (STP)
VSTPD - Volume sampled, cubic feet (STP)
VT - Total water vapor volume and dry gas volume sampled, cubic feet (STP)
W - Moisture fraction of stack gas
FDA - Dry gas fraction
MD - Molecular weight of stack gas, lbs/lb-mole (dry conditions)
MS - Molecular weight of stack gas, lbs/lb-mole (stack conditions)
GS - Specific gravity of stack gas, referred to air
EA - Excess air, %
$\sqrt{\text{HxTS}}$ - Average square root of velocity head times stack temperature
VS - Stack gas velocity, feet per minute
QS - Stack gas flow rate, cubic feet per minute (stack conditions)
QD - Stack gas flow rate, cubic feet per minute (dry conditions)
QSTPD - Stack gas flow rate, cubic feet per minute (STP)
PISO - Percent isokinetic volume sampled (method described in Federal Register)

APPENDIX

RAW DATA AND CALIBRATION DATA

CALIBRATION SUMMARY SHEET

Dry Gas Meter and Orifice

1. $\Delta H@$ = 1.95 for Meter Box S-1461.
2. = 1.01 for Meter Box S-1461.
3. $\Delta H@$ = 1.9 for Meter Box S-1936.
4. = 1.02 for Meter Box S-1936.

Nozzle (inches)

Micrometer Reading

1	2	3	4	AVG
.1873	.1876	.1875	.1876	.1875
.248	.249	.251	.249	.249
.249	.248	.250	.252	.250
.373	.376	.375	.376	.375
.377	.375	.374	.374	.375
.502	.495	.503	.498	.500

Pitot Tube

$$C_{p(s)} = C_{p(std)} \sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

$C_{p(s)}$ = 0.83 for tube 002.

Miscellaneous Equipment:

Description	Calibration Date
Barometer	5/19/76
Thermometers	5/19/76
Thermacouple/pyrometer	5/19/76
Magnehelic Gages	5/19/76

DISCUSSION OF SAMPLING

Because of the great expense of the platform construction and the possibility of structural damage to the existing boiler stack, sampling sites in the breechings were selected by the Hercules engineering staff. The sampling locations were permitted by the U.S. Environmental Protection Agency (EPA) and the Mississippi Air and Water Pollution Control Commission (MAWPCC) even though they did not conform to the procedures set forth in the Federal Register. Due to this nonconformance and the fact that the two boilers are common to a single stack the following stipulations were set forth and adhered to in sampling:

1. Simultaneous forty-eight point preliminary velocity traverses were performed.

2. Simultaneous testing was conducted using the ideal nozzle size and then the next larger size.

3. A total of six (6) simultaneous tests were run using alternating nozzle sizes.

DRY MOLECULAR WEIGHT DETERMINATION

PLANT Hercules, Inc.

DATE May 21, 1976

SAMPLING (24-hr. CLOCK)

SAMPLING LOCATION Hattiesburg, Mississippi

SAMPLE TYPE (BAG, INTEGRATED, CONTINUOUS) Continuous

ANALYTICAL METHOD Orsat

AMBIENT TEMPERATURE

OPERATOR Blunt

COMMENTS

RUN / GAS	1		2		3		AVERAGE NET VOLUME	MULTIPLIER	MOLECULAR WEIGHT OF STACK GAS (DRY BASIS) M_d, lb/lb-mole
	ACTUAL READING	NET	ACTUAL READING	NET	ACTUAL READING	NET			
CO_2	4.6	4.6	4.5	4.5	4.9	4.9	4.7	44/100	2.068
O_2 (NET IS ACTUAL O_2 READING MINUS ACTUAL CO_2 READING)	19.7	15.1	19.6	15.1	20.0	15.1	15.1	32/100	4.832
CO (NET IS ACTUAL CO READING MINUS ACTUAL O_2 READING)	19.9	0.2	19.8	0.2	20.2	0.2	0.2	28/100	0.056
N_2 (NET IS 100 MINUS ACTUAL CO READING)	---	80.1	---	80.2	---	79.8	80.0	28/100	22.40
								TOTAL	29.356

HERCULES INCORPORATED

HATTIESBURG, MISSISSIPPI 39401

May 28, 1976

Environmental Protection Systems
P. O. Box 20382
Jackson, Mississippi 39209

Attn: Brent Blunt

With reference to your performance evaluation tests on May 20 and 21, 1976, would you please include the following wood boiler data in your report.

May 20, 1976	Boiler #1 (East)	Boiler #2 (West)
Steam Rate	48,625 lbs/hr.	26,375 lbs/hr.
Cleaning Fires	7:00 AM to 9:00 AM 3:30 PM to 5:00 PM	9:00 AM to 11:00 AM 5:00 PM to 6:30 PM

May 21, 1976		
Steam Rate	37,675 lbs/hr.	38,175 lbs/hr.
Cleaning Fires	10:30 AM to 12:00 Noon	12:00 Noon to 2:00 PM

Very truly yours,

Charles Jordan

Charles Jordan
Senior Chemical Engineer

CJ:p

cc: State of Mississippi
Air & Water Pollution Control Commission
P. O. Box 827
Jackson, Mississippi 39205

Attn: Cal Thames

PRELIMINARY VELOCITY TRAVERSE

PLANT Hercules, Inc.

DATE 5-20-76

LOCATION Hattiesburg, Ms.

STACK I.D.

BAROMETRIC PRESSURE, in. Hg 30.37

STACK GAUGE PRESSURE, in. H_2O 30.38

OPERATORS Blunt / Wells

Boiler #1

SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s), in. H_2O	STACK TEMPERATURE (T_s), °F
# 1	1.0	
2	1.0	
3	0.6	
4	0.9	
5	1.0	
6	1.1	
7	1.1	
8	1.2	
9	1.2	
10	1.2	
11	1.1	
12	1.1	
#2 1	1.1	
2	1.1	
3	1.0	
4	1.1	
5	1.2	
6	0.2	
7	1.5	
8	1.5	
9	1.6	
10	1.5	
11	1.0	
12	1.0	
AVERAGE		

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s), in. H_2O	STACK TEMPERATURE (T_s), °F
#3 1	1.1	
2	1.1	
3	1.0	
4	0.6	
5	0.6	
6	0.8	
7	0.4	
8	0.25	
9	1.1	
10	1.0	
11	0.9	
12	0.8	
#4 1	0.1	
2	0.12	
3	—	
4	0.1	
5	0.1	
6	0.1	
7	0.3	
8	0.5	
9	0.13	
10	0.15	
11	0.15	
12	0.15	
AVERAGE		

PRELIMINARY VELOCITY TRAVERSE

PLANT Hercules, Inc.

DATE 5-20-76

LOCATION Hattiesburg, Ms.

STACK I.D.

BAROMETRIC PRESSURE, in. Hg 30.37

STACK GAUGE PRESSURE, in. H_2O 30.38

OPERATORS Blunt / Kreus

Boiler #2

SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER		VELOCITY HEAD (Δp_s), in. H_2O	STACK TEMPERATURE (T_s), °F
#1	1	0.8	
	2	0.8	
	3	0.15	
	4	1.0	
	5	1.0	
	6	1.2	
	7	1.2	
	8	1.2	
	9	1.2	
	10	1.2	
	11	1.0	
	12	1.0	
#2	1	0.6	
	2	0.9	
	3	0.9	
	4	0.95	
	5	1.0	
	6	1.2	
	7	1.1	
	8	1.0	
	9	1.0	
	10	—	
	11	1.5	
	12	1.5	
AVERAGE			

TRAVERSE POINT NUMBER		VELOCITY HEAD (Δp_s), in. H_2O	STACK TEMPERATURE (T_s), °F
#3	1	0.5	
	2	0.9	
	3	0.9	
	4	0.9	
	5	0.8	
	6	1.0	
	7	0.3	
	8	0.2	
	9	0.2	
	10	0.2	
	11	0.8	
	12	1.0	
#4	1	0.1	
	2	0.1	
	3	0.15	
	4	0.15	
	5	0.1	
	6	0.1	
	7	0.1	
	8	—	
	9	0.1	
	10	0.1	
	11	0.1	
	12	0.1	
AVERAGE			

[redacted] IRO[redacted]TAL [redacted]DTE[redacted]N S[redacted]MS [redacted]

Jackson, Mississippi

boiler #1

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.

Sampling Location Hattiesburg, Ms.

Date 5-20-76 Run No. 1a

Time Start 9:30 Time End 11:30

Sampling Time/Point 2 min.

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather ____

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 1 Meter Box No. 1461

Meter ΔH@ 1.95 Pitot Corr. Factor 0.83

Nozzle Dia. 3/8 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 1010.800 → 43.757 ft^3

Initial Gas Meter Reading 967.043 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. A Filter No. 0105

Orsat: CO_2 ____

C_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 8:30

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#4												
1			967.0	.1	.1		380	70	70	250	60	1
2				—				~~75~~	~~72~~			
3				—								
				—								

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			967.5	.10	.10		380	74	72	250	60	1
6			967.8	.30	.29		380	76	72			1
7			968.6	.55	.54		390	77	74			1
8			969.3	.35	.35		390	78	75			1
#9			970.0	1.2	1.16		400	84	78			1
10			970.9	1.2	1.16		400	84	78			1
11			972.1	.95	.92		380	87	79			2
12			973.1	.82	.79		385	89	80			2
#3			974.0	.82	.79		385	90	80			2
2			974.9	1.2	1.16		385	93	82			2
3			976.0	1.2	1.16		385	95	83			2
4			977.1	—								
5			977.1	1.2	1.16		385	95	84			2
6			978.2	1.0	0.96		390	96	84			2
7			979.3	1.0	0.96		390	96	86			2
8			980.3	0.95	.92		395	96	88			2
9			981.3	1.0	.96		390	97	89			2
10			982.3	1.0	.96		390	99	90			2
11			983.3	1.1	1.05		385	100	91			2
12			984.4	1.2	1.16		385	102	92			2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1			985.6	1.2	1.16		390	104	92	250	60	1
2			986.8	1.1	1.05		390	106	94			1
3			987.8	1.1	1.05		390	108	95			1
4			988.8	1.1	1.05		390	109	95			1
5			990.0	0.83	0.81		390	110	97			1
6			990.8	~~1.0~~ 0.1	0.1		385	110	98			1
7			991.4	1.5	1.42		385	109	98			1
8			992.4	1.5	1.42		385	110	98			1
9			993.5	1.8	1.70		380	113	100			1
10			994.9	1.5	1.42		380	115	101			2
11			996.2	1.5	1.42		385	116	102			2
12			997.6	1.5	1.42		380	118	103			2
#1 1			998.7	.95	.92		380	98	98			1
2			999.7	.83	0.81		380	98	98			2
3			1000.7	.55	0.54		400	98	98			2
4			001.5	.55	0.54		410	100	98			2
5			002.3	~~.55~~ .55	0.54		390	102	98			2
6			003.1	1.1 ~~1.0~~	1.05		390	104	98			2
7			004.1	0.95	0.92		385	106	98			2
8			005.1	1.5	1.42		390	108	99			3

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			006.3	1.5	1.42		380	110	99	250	60	5
10			007.6	1.1	1.05		385	112	99			3
11			008.7	1.0	0.96		380	115	99			3
12			009.7	1.0	0.96		380	115	100			

[redacted]IRO[redacted]TAL [redacted]OTEC[redacted]N S[redacted]MS
Jackson, Mississippi

boiler #1

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules Inc.
Sampling Location Hatties burg, Ms.
Date 5-20-76 Run No. 2a
Time Start 2:55 Time End 4:30
Sampling Time/Point 2 min
DB ____ °F, WB ____ °F, VP @ DP ____ "HG
Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg
Moisture ____ %, FDA ____, Gas Den. Fac. ____
Weather clear-warm
Temp. ____ °F, W/D ____, W/S ____
Sample Box No. 1 Meter Box No. 1461
Meter ΔH@ 1.95 Pitot Corr. Factor 0.83
Nozzle Dia. 3/8 in., Probe Len. 6 ft.
Probe Heater Set. ____ Nomograph Cf 1.16
Stack Dimensions ____ in
Stack Area ____ ft^2
Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____
Final Gas Meter Reading 93.677 & 41.516 ft^3
Initial Gas Meter Reading 52.161 ft^3
Condensate Increase in Impingers ____ ml
Moisture in Silica Gel ____ gm
Silica Gel Container No. E Filter No. 008

Orsat:

CO_2				
O_2				
CO				
N_2				
Excess Air				

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 2:44

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#1			52.2	.10	.10		385	104	104	250	60	1
2			52.5	.15	.15		385	103	105			1
3				—								
4				—								

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) Calc.	Actual	Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF) In	Out	Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
5			53.0	0.1	0.1		380	104	105	250	60	1
6			53.4	0.1	0.1		380	104	105			1
7			53.8	0.2	0.2		385	105	105			1
8			54.3	0.55	0.54		385	105	105			1
9			55.1	0.13	0.13		385	105	105			1
10			55.5	0.13	0.13		380	~~106~~	105			1
11			~~55.9~~	0.15	0.15		~~400~~	106	105			1
12			56.4	0.15	0.15		400	106	105			1
#3 1			56.8	1.10	1.05		400	106	105			~~1~~ 3
2			57.8	1.0	.96		390	108	105			~~1~~ 3
3			58.9	1.0	.96		390	109	106			3
4			59.9	0.65	0.64		370	110	107			1
5			61.1	0.65	0.64		380	111	108			1
6			61.7	0.80	0.77		380	112	108			1
7			62.7	0.30	0.30		380	112	108			1
8			63.3	~~0.25~~	~~0.25~~		380	112	108			1
9			63.8	~~0.75~~ 1.10	~~0.44~~ 1.05		380	112	108			2
10			64.9	0.80	0.77		380	114	108			2
11			65.8	0.65	0.64		380	114	108			2
12			66.8	0.80	0.77		385	114	108			2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1			67.7	1.10	1.05		380	110	108	260	60	1
2			68.8	1.10	1.05		380	110	108			3
3			70.0	1.10	1.05		380	110	108			3
4			70.9	1.2	1.16		380	112	108			3
5			72.0	1.2	1.16		380	112	108			3
6			73.3	0.10	0.10		380	112	108			1
7			73.6	1.6	1.51		420	112	108			2
8			74.8	1.6	1.51		420	112	108			2
9			75.9	1.6	1.51		400	112	108			3
10			77.2	1.5	1.42		390	114	108			3
11			78.5	1.5	1.42		390	115	108			3
12			79.7	1.5	1.42		390	115	108			3
#1 1			80.9	1.0	0.96		395	117	109			2
2			82.0	1.0	0.96		395	116	110			2
3			83.1	0.4	0.39		395	116	110			1
4			83.8	0.9	0.87		395	116	110			2
5			84.7	1.2	1.16		390	116	110			3
6			85.8	1.2	1.16		390	116	110			3
7			87.0	1.2	1.16		390	118	110			3
8			88.1	1.2	1.16		390	119	110			3

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
			89.3	1.5	1.42		380	120	110	250	60	3
9			90.5	1.2	1.16		380	120	110			3
10			91.7	0.9	0.87		380	120	110			2
11			92.7	0.9	0.87		380	120	110			2
12												

ENVIRONMENTAL PROTECTION SYSTEMS
Jackson, Mississippi

DO, lev

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.

Sampling Location Hattiesburg, Ms.

Date 5-21-76 Run No. 3a

Time Start 10:48 Time End 12:40

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.23 "Hg, Stack Press 30.24 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather clear - warm

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 1 Meter Box No. 1461

Meter ΔH@ 1.95 Pitot Corr. Factor 0.83

Nozzle Dia. 3/8 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 171.803 → 40.688 ft^3

Initial Gas Meter Reading 131.115 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. C Filter No. 013

Orsat: CO_2 ____

C_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 10:30

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#4 1			131.1	0.1	0.1		380	96	96	250	60	1
2			131.5	0.1	0.1		385	96	96			1
3			131.9	0.1	0.1		360	97	97			1
4			132.3	—								

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
				—						250	60	
5												
6			132.3	0.1	0.1		380	98	97			1
7			132.7	0.4	0.4		380	100	98			1
8			133.3	0.45	0.44		380	101	98			1
9			134.1	0.30	0.30		380	102	98			1
10			134.7	0.1	0.1		380	104	98			1
11			135.1	0.1	0.1		380	104	100			1
12			135.5	0.1	0.1		385	106	100			1
#3 1			135.9	1.1	1.05		380	106	100			1
2			136.9	1.1	1.05		380	107	102			1
3			138.1	1.0	.96		380	109	103			1
4			139.1	0.9	0.87		380	110	103			1
5			140.2	0.9	0.87		380	112	104			1
6			141.1	0.7	0.68		380	113	104			1
7			142.2	0.65	0.64		380	114	106			1
8			142.9	0.65	0.64		380	115	106			1
9			143.8	0.85	0.82		380	116	106			1
10			144.9	0.85	0.82		380	116	108			1
11			145.9	0.55	0.54		385	117	108			1
12			146.6	0.30	0.30		385	117	108			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp.@ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1			147.2	0.55	~~0.54~~ 0.54		375	113	108	250	60	1
2			147.9	0.65	0.64		375	113	109			1
3			148.9	0.85	0.82		395	113	109			1
4			149.8	0.90	0.87		395	113	109			1
5			150.8	1.10	1.05		395	114	109			1
6			151.8	1.10	1.05		395	114	109			1
7			153.1	~~0.9~~ 1.0	0.96		395	114	109			1
8			153.9	1.0	0.96		395	114	109			1
9			155.0	1.0	0.96		395	114	109			1
10			156.1	1.0	0.96		395	114	109			1
11			157.1	1.0	0.96		395	115	109			1
12			158.2	1.0	0.96		395	115	109			1
#1 1			158.9	1.5	1.42		390	113	108			1
2			160.2	1.5	1.42		390	115	108			1
3			162.0	1.5	1.42		390	116	109			1
4			162.7	1.2	1.05		390	117	109			1
5			163.4	1.0	.96		390	117	109			1
6			164.3	1.0	.96		390	117	109			1
7			165.3	0.35	0.35		390	116	109			1
8			166.7	0.80	0.77		400	112	108			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			167.8	1.0	0.96		400	112	108	250	60	1
10			168.7	1.0	0.96		400	113	108			1
11			169.8	0.95	0.92		400	115	108			1
12			170.7	0.95	0.82		400	115	108			1

[redacted]IRON[redacted]TAL [redacted]TEC[redacted]N SY[redacted]MS
Jackson, Mississippi

boiler #2

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.
Sampling Location Hatties burg, Ms
Date 5-20-74 Run No. 1 b
Time Start 9:31 Time End 11:29
Sampling Time/Point 2 min.
DB ____ °F, WB ____ °F, VP @ DP ____ "HG
Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg
Moisture ____ %, FDA ____, Gas Den. Fac. ____
Weather ____
Temp. ____ °F, W/D ____, W/S ____
Sample Box No. 2 Meter Box No. 1936
Meter ΔH@ 1.90 Pitot Corr. Factor 0.83
Nozzle Dia. 3/8 in., Probe Len. 6 ft.
Probe Heater Set. ____ Nomograph Cf 1.16
Stack Dimensions ____ in
Stack Area ____ ft^2
Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate 694.536 - 40.700
Final Gas Meter Reading 653.836 ft^3
Initial Gas Meter Reading ____ ft^3
Condensate Increase in Impingers ____ ml
Moisture in Silica Gel ____ gm
Silica Gel Container No. B Filter No. 0106

Orsat:

CO_2				
C_2				
CO				
N_2				
Excess Air				

Test Conducted by: Blunt / Wells

Remarks: Leak ck ok 8:30

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#4 1			653.8	.1	.1		370	70	70	250	60	1
2				.26	.26		385	74	72			1
3			654.9	.10	.10		390	76	72			1
1				1	.1		390	78	73			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			655.8	.1	.1		380	90	74	250	60	1
6			656.1	.1	.1		385	80	74			1
7				—								
8			656.6	.1	.1		390	82	75			1
9			656.9	.65	.64		395	85	78			2
10			657.8	.92	.89		400	88	78			3
11			659.0	.95	.92		390	91	79			3
12			660.0	.82	.79		390	93	80			2
#3 1			660.9	.60	.59		390	96	82			1
2			661.8	.82	.79		390	99	83			1
3			662.8	.25	.25		395	100	84			1
4			663.4	.40	.39		395	100	85			1
5			664.2	.60	.59		400	101	86			1
6			665.0	.64	.63		390	101	86			1
7			666.0	.55	.54		390	100	88			1
8			666.7	.60	.59		390	100	88			1
9			667.6	.60	.59		390	98	89			1
10			668.5	.58	.57		395	100	90			1
11			669.3	.64	.63		390	102	90			1
12			670.2	.64	.63		390	102	90			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1			671.0	.60	.59		400	104	94	250	60	1
2			671.9	.80	.78		390	106	93			1
3			672.9	.95	.92		395	108	94			1
4			674.0	.95	.92		395	109	94			1
5			675.1	1.10	1.05		395	110	95			1
6			676.1	.60	.59		390	112	96			1
7			677.0	.50	.49		390	112	97			1
8			677.9	1.10	1.05		390	113	98			1
9			678.9	1.0	.96		390	114	98			1
10			680.1	.95	.92		395	116	99			1
11			681.1	.85	.82		380	116	100			1
12			682.2	.95	.92		385	116	100			1
#1 1			683.2	.80	.78		380	96	96			2
2			684.3	.80	.78		380	98	96			2
3			685.2	.80	.78		385	100	96			2
4				—								
5			686.5	.1	.1		380	102	97			3
6			686.7	1.1	1.05		380	102	97			3
7			687.8	1.1	1.05		385	105	98			3
8			688.9	1.2	1.16		380	108	98			4

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			690.0	1.5	1.42		385	111	99	250	60	6
10			691.3	.95	.92		385	114	99			4
11			692.5	.85	.92		370	114	99			5
12			693.4	.85	.92		390	115	100			

[redacted] ENVIRONMENTAL [redacted] TECH [redacted] SYSTEMS [redacted]
Jackson, Mississippi

boiler #2

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.
Sampling Location Hattiesburg, Ms.
Date 5-20-76 Run No. 2b
Time Start 2:56 Time End 4:31
Sampling Time/Point 2 min
DB ____ °F, WB ____ °F, VP @ DP ____ "HG
Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg
Moisture ____ %, FDA ____, Gas Den. Fac. ____
Weather clear - warm
Temp. ____ °F, W/D ____, W/S ____
Sample Box No. 2 Meter Box No. 1936
Meter ΔH@ 1.90 Pitot Corr. Factor 0.83
Nozzle Dia. 3/4 in., Probe Len. 6 ft.
Probe Heater Set. ____ Nomograph Cf 1.16
Stack Dimensions ____ in
Stack Area ____ ft^2
Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____
Final Gas Meter Reading 775.071 → 39.366 ft^3
Initial Gas Meter Reading 735.705 ft^3
Condensate Increase in Impingers ____ ml
Moisture in Silica Gel ____ gm
Silica Gel Container No. F Filter No. 0/10

Orsat:

CO_2				
O_2				
CO				
N_2				
Excess Air				

Test Conducted by: Blunt / Wells

Remarks: Leak ck ok 2:44

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#4 1			735.7	0.1	0.1		380	101	101	250	60	1
2			736.1	0.25	0.25		380	102	102			1
3			736.7	~~0.15~~ 0.15	0.15		380	103	102			1
				0.15	0.15		380	104	102			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			737.7	0.1	0.1		395	105	102	250	60	1
6			738.1	0.1	0.1		395	105	102			1
7			738.4	0.1	0.1		390	105	102			1
8			738.8	—								
9			738.8	0.1	0.1		390	105	103			1
10			739.2	0.1	0.1		395	105	103			1
11			739.6	0.1	0.1		395	106	103			1
12			740.0	0.1	0.1		395	106	103			1
#3 1			740.5	0.55	0.54		410	108	103			1
2			741.3	0.90	0.87		410	110	103			1
3			742.3	0.90	0.87		400	112	104			1
4			743.3	0.70	0.68		390	115	104			2
5			744.3	0.70	0.68		390	116	104			2
6			745.3	1.0	0.96		390	118	105			4
7			746.3	0.30	0.30		390	118	105			1
8			747.0	0.25	0.25		390	118	106			1
9			747.6	0.25	0.25		390	117	106			1
10			748.3	0.45	0.44		385	116	106			1
11			749.0	0.80	0.77		385	118	106			3
12			749.9	1.10	1.05		385	118	106			4

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1			751.0	0.60	0.59		390	110	105	250	60	1
2			751.8	0.80	0.77		390	110	106			2
3			752.8	0.90	0.87		380	112	107			4
4			753.8	0.90	0.87		380	114	106			4
5			754.9	0.95	0.92		380	116	106			4
6			755.9	1.2	1.16		380	116	106			5
7			757.4	1.2	1.16		380	118	106			5
8			758.3	1.0	.96		385	118	106			4
9			759.3	1.0	.96		385	120	106			4
10				—								
11			760.5	1.5	1.42		395	122	106			6
12			761.7	1.5	1.42		395	122	106			6
#1 1			762.9	0.7	.68		390	118	107			2
2			763.9	0.8	.77		380	118	108			2
3			765.0	0.15	0.15		385	118	108			1
4			765.5	0.15	0.15		385	117	108			1
5			766.0	1.0	.96		385	116	108			4
6			767.0	1.2	1.16		385	116	108			6
7			768.2	1.2	1.16		385	118	108			6
8			769.3	1.2	1.16		385	118	108			6

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			770.5	1.5	1.42		380	~~118~~ 108	108	250	60	9
10			771.8	1.2	1.16		385	120	108			6
11			~~773~~ 773.0	0.8	0.77		385	122	108			4
12			774.2	0.8	0.77		385	123	108			2

ENVIRONMENTAL TECH SYSTEMS
Jackson, Mississippi

boiler #2

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.
Sampling Location Hattiesburg, Ms.
Date 5-21-76 Run No. 3b
Time Start 10:47 Time End 12:40
Sampling Time/Point 2 min
DB ____ °F, WB ____ °F, VP @ DP ____ "HG
Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg
Moisture ____ %, FDA ____, Gas Den. Fac. ____
Weather clear - warm
Temp. ____ °F, W/D ____, W/S ____
Sample Box No. 2 Meter Box No. 1936
Meter ΔH@ 1.9 Pitot Corr. Factor 0.83
Nozzle Dia. 3/4 in., Probe Len. 6 ft.
Probe Heater Set. ____ Nomograph Cf 1.16
Stack Dimensions ____ in
Stack Area ____ ft^2
Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____
Final Gas Meter Reading 855.166 → 38.896 ft³
Initial Gas Meter Reading 816.270 ft³
Condensate Increase in Impingers ____ ml
Moisture in Silica Gel ____ gm
Silica Gel Container No. D Filter No. 0115

Orsat:

CO_2					
O_2					
CO					
N_2					
Excess Air					

Test Conducted by: Blunt / Wells

Remarks: Leak ck ok 10:38

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#1 1			816.3	0.70	0.68		380	~~108~~ 98	97	250	60	2
2			817.1	0.65	0.64		380	100	98			2
3			818.1	—								
4			[illegible]	0.45	0.44		380	103	98			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) Calc.	Meter Orifice Press. Diff. ("H_2O) Actual	Stack Gas Temp. (°F)	Gas Sample Temp.@ Dry Gas Meter (°F) In	Gas Sample Temp.@ Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
5			818.9	1.1	1.05		380	105	98	250	60	4
6			820.0	1.5	1.42		380	110	98			10
7			821.2	1.5	1.42		380	112	98			11
8			822.5	1.2	1.16		385	116	100			8
9			823.7	0.90	0.87		385	118	100			4
10			824.8	0.70	0.68		390	118	100			2
11			825.8	0.70	0.68		390	118	102			2
12			826.8	0.70	0.68		390	118	102			2
#2 1			827.6	0.65	0.64		370	110	102			2
2			828.5	0.65	0.64		370	113	103			2
3			829.4	0.80	0.77		380	114	104			3
4			830.3	1.0	196		380	116	104			3
5				—			~~380~~	~~118~~	~~104~~			
6			831.7	0.45	.44		380	118	104			1
7			832.3	1.1	1.05		375	118	105			5
8			833.4	0.90	0.87		380	121	106			4
9			834.5	0.80	0.77		380	121	106			3
10			835.6	0.85	0.82		375	122	107			3
11			836.6	~~0.85~~ 1.0	~~0.82~~ 0.96		375	123	107			4
12			837.7	1.0	0.96		375	123	107			4

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#3 1			838.8	1.0	0.96		380	112	106	250	60	4
2			839.8	0.8	0.77		380	114	106			3
3			840.9	0.90	0.87		380	116	107			4
4			841.9	0.90	0.87		380	118	107			4
5			843.0	0.90	0.87		380	118	107			3
6			843.0	1.0	0.96		380	119	106			3
7			845.2	0.13	0.13		380	119	106			1
8			845.6	0.40	0.39		380	116	106			1
9			846.3	0.40	0.39		380	116	106			1
10			847.0	0.90	0.87		380	117	106			4
11			848.0	0.90	0.87		380	117	106			4
12			849.0	1.0	0.96		380	117	106			4
#4 1			850.2	0.2	0.2		~~380~~ 385	112	105			1
2			850.8	0.2	0.2		370	113	105			1
3			851.3	0.25	0.25		370	113	106			1
4			852.2	0.1	0.1		370	113	106			1
5			852.6	0.1	0.1		370	112	106			1
6			853.1	0.1	0.1		370	112	106			1
7			853.6	0.1	0.1		370	107	108			1
8			853.9	~~0~~								

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9				—						250	60	
10			853.9	0.1	0.1		390	116	104			1
11			854.2	0.1	0.1		390	116	104			1
12			854.6	0.15	0.15		390	116	104			1

IRON TAL TEC SY MS
Jackson, Mississippi

boiler #7

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.
Sampling Location Hattiesburg, Ms
Date 5-20-76 Run No. 1a
Time Start 12:05 Time End 1:50
Sampling Time/Point 2 min
DB ____ °F, WB ____ °F, VP @ DP ____ "HG
Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg
Moisture ____ %, FDA ____, Gas Den. Fac. ____
Weather clear-warm
Temp. ____ °F, W/D ____, W/S ____
Sample Box No. 1 Meter Box No. 1461
Meter ΔH@ 1.95 Pitot Corr. Factor 0.83
Nozzle Dia. 3/16 in., Probe Len. 6 ft.
Probe Heater Set. ____ Nomograph Cf 1.16
Stack Dimensions ____ in
Stack Area ____ ft^2
Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____
Final Gas Meter Reading 51.841 → 40.867 ft^3
Initial Gas Meter Reading 010.974 ft^3
Condensate Increase in Impingers ____ ml
Moisture in Silica Gel ____ gm
Silica Gel Container No. C Filter No. 0107

Orsat:

CO_2				
O_2				
CO				
N_2				
Excess Air				

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 12:07 pm

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) $\sqrt{\Delta H}$		Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#1			10.9	1.0	.96	1	380	102	100	250	60	2
2			12.0	1.0	.96	1	385	104	100			2
3			13.1	0.85	.82	.92	385	106	100			2
4			14.1	1.0	.96	1	380	107	101			2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) $\sqrt{H}$		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			15.2	1.2	1.16	1.09	390	108	98	250	60	1
6			16.2	1.2	1.16	1.09	390	110	99			1
7			17.3	1.6	1.51	1.26	420	113	103			1
8			18.7	1.6	1.51	1.26	400	115	104			1
9			19.9	1.3	1.26	1.14	410	116	104			1
10			21.0	1.0	.96	1	400	116	104			1
11			22.1	1.0	.96	1	390	116	105			1
12			23.1	1.0	.96	1	390	116	105			2
#2 1			24.1	1.1	1.05	1.05	385	114	106			2
2			25.1	1.1	1.05	1.05	385	114	106			2
3			26.4	1.1	1.05	1.05	385	115	106			2
4			27.4	1.1	1.05	1.05	380	115	108			2
5			28.5	1.2	1.16	1.09	390	116	108			2
6			29.7	~~0.1~~	~~10~~							
7			29.7	1.2	1.16	1.09	390	116	108			2
8			30.8	1.6	1.51	1.26	390	116	108			2
9			32.2	1.6	1.51	1.26	390	116	108			2
10			33.4	1.2	1.16	1.09	390	117	108			2
11			34.4	1.2	1.16	1.09	390	117	108			2
12			35.8	1.6	1.51	1	390	118	108			2

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#3 1			37.0	1.0	0.96	1	390	118	110	250	60	2
2			38.1	0.80	0.77	.89	395	119	111			2
3			39.0	0.90	0.87	.95	395	119	111			2
4			40.0	0.80	0.77	.89	395	119	111			2
5			40.9	0.80	0.77	.89	395	119	111			1
6			42.0	0.65	0.64	.81	390	120	112			1
7			43.0	1.10	1.05	1.05	390	120	112			1
8			44.0	0.25	0.25	.5	395	120	112			1
9			44.6	0.35	0.35	.59	395	120	112			1
10			45.4	0.30	0.30	.55	395	120	113			1
11			46.0	0.90	0.87	.95	395	120	114			1
12			46.9	0.80	0.77	.89	395	120	115			1
#f Pitot			47.9	—								
2				—								
3				—								
4			47.9	.10	.10	.32	395	118	115			1
5			48.2	.10	.10	.32	395	118	115			1
6			48.6	.10	.10	.32	395	117	115			1
7			48.0	.10	.10	.32	395	117	115			1
8			49.4	.30	.30	.55	395	117	115			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) $\sqrt{H}$		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			49.9	0.30	0.30	.55	390	118	115	250	60	1
10			50.6	0.10	0.10	.32	390	118	115			1
11			51.0	0.10	0.10	.32	390	118	115			1
12			51.4	0.10	0.10	.32	390	118	115			1

[redacted] Jackson, Mississippi boiler #1

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.

Sampling Location Hattiesburg, Ms.

Date 5-21-76 Run No. 2a

Time Start 8:23 Time End 10:12

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather ____

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 1 Meter Box No. 1461

Meter ΔH@ 1.95 Pitot Corr. Factor 0.93

Nozzle Dia. 3/16 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 130.721 - 36.884 ft^3

Initial Gas Meter Reading 93.837 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. A Filter No. 0112

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 8:10

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) Calc.	Meter Orifice Press. Diff. ("H_2O) Actual	Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F) In	Gas Sample Temp. @ Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
#1 1			93.8	1.0	.96	1	380	68	66	250	60	1
2			94.8	1.0	.96	1	380	71	65			1
3			95.7	1.0	.96	1	380	74	65			2
4			96.7	1.1	1.1	2	380	76	66			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) ΔH		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			97.2	1.1	1.05	1.05	385	78	67	250	60	1
6			98.3	1.1	1.05	1.05	385	80	69			1
7			99.2	1.0	.96	1	385	81	71			1
8			100.2	1.0	.96	1	385	83	73			1
9			101.2	.80	.77	.89	385	84	75			1
10			102.0	.80	.77	.89	385	86	76			1
11			102.9	.75	.73	.87	380	88	77			1
12			103.8	.75	.73	.87	380	90	78			1
#2 1			104.8	1.2	1.16	1.09	375	92	82			1
2			106.1	1.2	1.16	1.09	370	95	82			1
3			107.0	1.0	.96	1	375	98	84			1
4			108.1	1.0	.96	1	375	99	85			1
5			109.3	1.2	1.16	1.09	375	101	86			1
6			110.3	1.2	1.16	1.09	375	103	88			1
7			111.4	1.2	1.16	1.09	395	104	89			1
8			112.5	1.2	1.16	1.09	410	105	90			1
9			113.7	—								
10			113.7	1.5	1.42	1.22	400	106	92			1
11			114.9	1.5	1.42	1.22	400	108	92			1
12			116.1	1.5	1.42	1.22	400	110	93			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) Calc.	Meter Orifice Press. Diff. ("H_2O) Actual	Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF) In	Gas Sample Temp.@ Dry Gas Meter (^oF) Out	Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
#3 1			117.4	1.2	1.16	1.09	380	105	94	250	60	2
2			118.5	1.2	1.16	1.09	385	108	96			2
3			119.7	1.0	.96	1	385	108	98			2
4			120.7	1.0	.96	1	385	108	98			2
5			121.8	.75	.73	.87	385	109	98			2
6			122.7	.75	.73	.87	385	109	98			2
7			123.8	.75	.73	.87	385	109	98			2
~~8~~			~~124.7~~	~~.75~~	~~.73~~							
9			124.7	.25	.25	.5	385	109	98			1
10			125.3	.25	.25	.5	380	109	99			1
11			125.8	.25	.25	.5	380	109	99			1
12			126.4	1.0	.96	1	385	109	100			2
#4 1			127.4	0.1	0.1	.32	370	102	99			1
2			127.8	←			~~370~~	~~103~~	~~100~~			~~1~~
3				—								
4				←								
5			127.8	0.1	0.1	.32	370	103	100			1
6			128.2	0.1	0.1	.32	370	103	100			1
7			128.5	0.1	0.1	.32	370	103	100			1
8			128.9	0.1	0.1	.32	370	103	100			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			129.3	0.1	0.1	.32	375	104	100	250	60	1
10			129.6	0.1	0.1	.32	375	104	100			1
11			130.0	0.1	0.1	.32	375	104	100			1
12			130.4	0.1	0.1	.32	375	104	100			1

ENVIRONMENTAL PROTECTION SYSTEMS
Jackson, Mississippi

Boiler #1

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc

Sampling Location Hattiesburg, Ms.

Date 5-21-76 Run No. 3a

Time Start 1:00 Time End 2:45

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather clear warm

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 1 Meter Box No. 1461

Meter ΔH@ 1.95 Pitot Corr. Factor 0.83

Nozzle Dia. 3/16 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 212. ft^3

Initial Gas Meter Reading 171.944 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. ____ Filter No. 0114

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Kreuz

Remarks: Leak ck ok 12:50

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) $\sqrt{H}$ Calc.	Meter Orifice Press. Diff. ("H_2O) $\sqrt{H}$ Actual	Stack Gas Temp. (°F)	Gas Sample Temp.@Dry Gas Meter (°F) In	Gas Sample Temp.@Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
1			171.9	1.0	0.96	1	385	96	96	250	250	
2				1.0	0.96	1	385	96	96	)	)	
3				1.0	0.96	1	385	97	98	)	)	
4				0.1	0.1	1	385	98	98	)	)	

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5				1.1	1.05	1.05	385	99	98	250	60	
6				1.0	.96	1	385	102	98			
7				1.0	.96	1	385	104	98			
8				.9	.87	.95	385	106	99			
9				.8	.77	.89	385	108	99			
10				.8	.77	.89	380	110	99			
11				.75	.73	.87	380	112	99			
12				.75	.73	.87	380	114	100			
1				1.2	1.16	1.09	375	114	100			
2				1.2	1.16	1.09	375	115	100			
3				1.1	1.05	1.05	375	115	101			
4				1.0	.96	1	375	115	101			
5				1.1	1.05	1.05	370	115	101			
6				1.2	1.16	1.09	370	115	101			
7				1.2	1.16	1.09	375	116	101			
8				1.2	1.16	1.09	375	116	102			
9				—								
10				1.3	1.26	1.14	390	116	102			
11				1.5	1.42	1.27	400	116	102			
12				1.5	1.42	1.27	400	116	102			

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
1				1.2	1.16	1.09	390	116	103	250	60	
2				1.2	1.16	1.09	385	116	103			
3				1.0	.96	1	385	116	103			
4				1.0	.96	1	385	116	104			
5				0.8	.77	.89	385	116	104			
6				0.75	.73	.87	385	116	104			
7				~~0.~~								
8				0.25	.25	.5	385	116	105			
9				0.25	.25	.5	385	116	105			
10				0.25	.25	.5	385	116	105			
11				0.8	.77	.89	385	116	105			
12				1.0	.96	1	385	116	105			
1				0.1	0.1	.32	370	116	105			
2				—								
3				—								
4				—								
5				0.1	0.1	.32	390	115	105			
6				0.1	0.1	.32	390	115	105			
7				0.1	0.1	.32	390	115	105			
8				0.1	0.1	.32	390	115	105			

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9				0.1	0.1	.32	380	115	105	250	60	
10				0.1	0.1	.32	380	115	105	)	)	
11				0.1	0.1	.32	380	115	105	)	)	
12				0.1	0.1	.32	380	115	105	)	)	

[redacted] Jackson, Mississippi

Boiler #2

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.

Sampling Location Hattiesburg, Ms.

Date 5-20-76 Run No. 1b

Time Start 12:06 Time End 1:53

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.37 "Hg, Stack Press. 30.38 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather clear - warm

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 2 Meter Box No. 1936

Meter ΔH@ 1.95 Pitot Corr. Factor 0.83

Nozzle Dia. 3/16 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 735.415 ~~40.725~~ ft^3

Initial Gas Meter Reading 694.690 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. D Filter No. 0109

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Wells.

Remarks: Leak ck ok 12:07

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) $\sqrt{\Delta H}$ Calc.	Meter Orifice Press. Diff. ("H_2O) $\sqrt{\Delta H}$ Actual	Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F) In	Gas Sample Temp. @ Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
#1 1			~~694.7~~ ~~0.65~~	0.65	0.64	.81	395	102	98	250	60	1
2			695.5	0.70	0.69	.64	390	103	98	"	"	1
3			696.5	0.10	0.10	.32	390	104	98	"	"	1
4			696.9	0.80	0.78	.49	390	106	98			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			697.8	.80	.78	.89	390	110	100	250	60	1
6			699.0	1.2	1.16	1.09	395	112	100			1
7			700.1	1.6	1.51	1.26	400	115	100			1
8			701.3	1.3	1.26	1.14	390	116	101			2
9			702.7	0.9	0.87	.95	395	118	103			2
10			703.8	1.0	0.96	1	390	120	103			~~3~~ 2
11			704.8	0.9	~~0.87~~	.95	395	122	103			2
12			705.9	1.0	0.96	1	390	122	103			2
#2 1			707.0	0.65	0.64	.61	390	117	104			1
2			707.9	0.75	0.73	.87	410	119	104			1
3			708.9	0.90	0.87	.95	400	120	104			1
4			709.8	1.10	1.05	1.05	400	120	104			1
5			711.1	0.75	0.73	.87	390	120	106			1
6			712.0	0.55	0.54	.74	390	120	106			1
7			713.1	1.60	~~1.60~~ 1.51	1.26	390	120	106			1
8			714.1	1.0	0.96	1	390	120	106			1
9			715.3	1.0	0.96	1	390	~~120~~ 122	106			1
10			716.4	0.95	0.92	.97	390	122	106			1
11			717.4	1.0	0.96	1	390	122	106			1
12			718.5	1.0	0.96	1	390	122	106			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual #		In	Out			
#3 1			719.6	0.65	0.64	.61	395	122	110	250	60	1
2			720.6	0.90	0.88	.95	395	122	110			2
3			721.7	0.90	0.87	.95	395	122	110			2
4			722.7	0.80	0.77	.89	390	122	111			1
5			723.7	0.90	0.87	.95	390	124	111			1
6			724.8	0.90	0.87	.95	390	124	111			1
7			725.8	0.10	0.10	.32	390	126	112			1
8			726.3	0.30	0.30	.56	390	124	112			1
9			726.9	0.30	0.30	.56	390	124	112			1
10			727.7	0.40	0.40	.63	395	124	112			1
11			728.3	0.40	0.40	.63	395	124	112			1
12			729.1	0.40	0.40	.63	395	124	112			1
#4 1			729.8	0.30	0.30	.56	395	120	112			1
2			730.4	0.30	0.30	.56	395	120	112			1
3			731.1	0.25	0.25	.5	395	120	112			1
4			731.7	0.10	0.10	.32	395	120	112			1
5			732.1	0.10	0.10	.32	395	120	112			1
6			732.5	~~0.10~~	0.10	.32	395	120	112			1
7			733.0	0.10	0.10	.32	395	120	112			1
8			733.4	0.10	0.10	.32	390	120	112			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			733.8	0.10	0.10	.32	400	120	114	250	60	1
10			734.2	0.10	0.10	.32	400	120	114			1
11			734.6	0.10	0.10	.32	400	120	114			1
12			734.9	0.10	0.10	.32	410	120	114			1

[redacted] IRONMENTAL PROTECTION SYSTEMS
Jackson, Mississippi

Date 2

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc.

Sampling Location Hattiesburg, Ms

Date 5-21-76 Run No. 2 b

Time Start 8:24 Time End 10:15

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.23 "Hg, Stack Press. 30⅓ "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather ____

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 2 Meter Box No. 1936

Meter ΔH@ 1.9 Pitot Corr. Factor 0.83

Nozzle Dia. 3/16 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft^2

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 816.026 → 40.82 ft^3

Initial Gas Meter Reading 775.206 ft^3

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. B Filter No. 0111

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Wells

Remarks: Leak ck ok

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) Calc.	Meter Orifice Press. Diff. ("H_2O) Actual (ΔH)	Stack Gas Temp. (°F)	Gas Sample Temp. @ Dry Gas Meter (°F) In	Gas Sample Temp. @ Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
#4 1			775.2	.25	.25	.5	385	67	64	250	60	1
2			775.7	.40	.39	.63	385	68	64	)	)	1
3			776.4	.25	.25	.5	385	70	65	)	)	1
4			776.0	.10	.10	.32	385	72	66			1

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) ΔH		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5			~~774.5~~ 777.5	.1	.1	.32	380	74	66	250	60	1
6			777.9	.1	.1	.32	380	74	68			1
7			778.2	.1	.1	.32	380	76	70			1
8			778.6	—								
9			778.6	.1	.1	.32	380	79	72			1
10			779.0	.15	.15	.39	385	80	73			1
11			779.4	.30	.30	.55	380	82	74			1
12			780.0	.30	.30	.55	380	84	75			1
#3 1			780.7	.75	.73	.67	375	86	78			1
2			781.6	.85	.82	.92	385	90	79			2
3			782.7	.85	.82	.92	385	93	80			2
4			783.7	.85	.82	.92	385	95	81			2
5			784.6	.70	.68	.84	385	98	83			1
6			785.8	.90	.87	.95	380	100	84			1
7			786.7	.45	.44	.67	380	101	85			1
8			787.5	.20	.20	.45	380	101	86			1
9			788.0	.45	.44	.67	380	101	87			1
10			788.7	.85	.82	.92	385	101	87			1
11			789.9	.85	.82	.92	385	103	88			2
12			790.8	1.2	1.16	1.09	395	106	90			4

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1			791.9	~~.65~~ .65	.64	.61	400	106	92	250	60	1
2			792.9	.75	.73	.67	410	108	93			1
3			793.8	.75	.73	.67	400	108	93			1
4			794.9	1.0	.96	1	400	110	94			3
5			795.9	1.0	.96	1	400	112	94			3
6			796.9	1.0	.96	1	410	112	95			3
7			798.2	1.0	.96	1	410	112	95			3
8			799.2	1.0	.96	1	400	113	96			3
9			800.3	.75	.73	.67	390	114	97			~~3~~ 2
10			801.3	.75	.73	.67	390	114	98			~~3~~ 2
11			802.2	1.0	.96	1	385	114	98			3
12			803.4	1.2	1.16	1.09	385	114	98			3
#1 1			804.6	0.65	0.64	.61	390	108	99			~~3~~ 2
2			805.5	0.75	0.73	.67	395	110	100			2
3			806.4	——				~~###~~				
4			806.4	0.45	0.44	.67	380	111	100			1
5			807.3	1.0	.96	1	380	112	100			1
6			~~808.3~~ 808.3	1.2	1.16	1.09	380	114	100			4
7			809.6	1.5	1.42	1.22	380	116	102			6
8			810.8	1.0	.96	1	380	118	102			6

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9			812.0	0.80	0.77	.89	380	118	102	250	60	1
10			813.0	0.80	0.77	.89	380	118	102			1
11			813.9	0.80	0.77	.89	380	118	102			1
12			815.0	0.90	0.87	.95	380	118	102			1

[redacted]IRO[redacted]NTA[redacted]OTE[redacted]N S[redacted]EMS
Jackson, Mississippi

boiler 2

SOURCE SAMPLING FIELD DATA SHEET

Plant Hercules, Inc

Sampling Location Hattiesburg, Ms.

Date 5-21-76 Run No. 3b

Time Start 1:00 Time End 2:45

Sampling Time/Point 2 min

DB ____ °F, WB ____ °F, VP @ DP ____ "HG

Bar. Press. 30.23 "Hg, Stack Press. 30.24 "Hg

Moisture ____ %, FDA ____, Gas Den. Fac. ____

Weather clear--warm

Temp. ____ °F, W/D ____, W/S ____

Sample Box No. 2 Meter Box No. 1936

Meter ΔH@ 1.90 Pitot Corr. Factor 0.83

Nozzle Dia. 3/16 in., Probe Len. 6 ft.

Probe Heater Set. ____ Nomograph Cf 1.16

Stack Dimensions ____ in

Stack Area ____ ft²

Stack Height ____ ft

Sketch of Stack

Mat'l Processing Rate ____

Final Gas Meter Reading 895. ft³

Initial Gas Meter Reading 855.462 ft³

Condensate Increase in Impingers ____ ml

Moisture in Silica Gel ____ gm

Silica Gel Container No. ____ Filter No. 0116

Orsat: CO_2 ____

O_2 ____

CO ____

N_2 ____

Excess Air ____

Test Conducted by: Blunt / Wells

Remarks: Leak ck ok 12:50

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head ("H2O)	Meter Orifice Press. Diff. ("H2O) Calc.	Meter Orifice Press. Diff. ("H2O) Actual	Stack Gas Temp. (°F)	Gas Sample Temp.@Dry Gas Meter (°F) In	Gas Sample Temp.@Dry Gas Meter (°F) Out	Sample Box Temp. (°F)	Last Impinger Temp. (°F)	Vacuum on Sample Train ("Hg)
#4 1			855.4	.2	.2	.45	385	97	97	250	60	
2				.4	.39	.63	385	98	97			
3				.25	.25	.5	385	98	97			
4				.1	.1	.32	385	98	97			

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) ΔH		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
5				.1	.1	.32	385	98	97	250	60	
6				.1	.1	.32	385	99	97			
7				.1	.1	.32	385	99	97			
8				.1	.1	.32	385	99	98			
9				—								
10				.15	.15	.39	380	99	98			
11				.30	.3	.55	390	100	98			
12				.3	.3	.55	380	100	98			
#3 1				.75	.73	.87	390	101	98			
2				.75	.73	.87	390	102	98			
3				.85	.83	.92	390	104	99			
4				.85	.83	.92	390	105	99			
5				.90	.87	.95	390	105	99			
6				.4	.39	.63	395	106	99			
7				.25	.25	.5	395	106	100			
8				.45	.44	.67	395	106	100			
9				.45	.44	.67	395	106	100			
10				.85	.82	.92	390	107	100			
11				.85	.82	.92	390	107	100			
12				1.2	1.16	1.09	385	108	101			

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O)		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
#2 1				.70	.69	.84	400	109	101	250	60	
2				.75	.73	.87	400	110	101			
3				.75	.73	.87	400	110	102			
4				1.0	.96	1	400	111	102			
5				1.0	.96	1	410	112	102			
6				1.0	.96	1	410	112	102			
7				1.0	.96	1	400	113	103			
8				1.0	.96	1	400	115	103			
9				1.0	.96	1	390	117	104			
10				.75	.73	.87	390	118	105			
11				1.0	0.96	1	390	118	105			
12				1.2	1.16	1.09	390	118	105			
1				0.65	0.64	.81	380	118	105			
2				0.65	0.64	.81	380	118	105			
3				0.4	0.39	.63	380	118	105			
4				—								
5				1.0	.96	1	385	119	106			
6				1.2	1.16	1.09	385	119	106			
7				1.3	1.26	1.14	385	119	106			
8				1.3	1.26	1.14	385	119	106			

Port and Traverse Point No.	Distance From Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft^3)	Stack Velocity Head ("H_2O)	Meter Orifice Press. Diff. ("H_2O) $\sqrt{H}$		Stack Gas Temp. (^oF)	Gas Sample Temp.@ Dry Gas Meter (^oF)		Sample Box Temp. (^oF)	Last Impinger Temp. (^oF)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
9				0.80	0.77	.49	380	119	106	250	60	
10				0.80	0.77	.89	380	119	106			
11				0.80	0.77	.89	380	119	106			
12				0.90	0.87	.95	380	119	106			

Boiler # 1 3/8" nozzle

METHOD 5

Form RF-5

Pbar = 29.36

	Run #1	Run #2	Run #3
Average stack temperature; Ts(°R)	847.1	847.1	820
Average dry gas meter temperature: Tm(°R)			
Tm = $\frac{(\text{avg. temp. in}) + (\text{Avg. temp. out})}{2}$ =	555	570	568
Average orifice pressure drop: ΔH (Inches H_2O)			
From data sheet ΔH =	0.95	0.78	0.74
Gas volume through meter: Vm(ft^3) =	43.76	41.52	40.69
Dry gas volume: Vm_{std} (std. conditions, ft^3)			
$Vm_{std} = \left(17.71 \frac{°R}{\text{In. Hg}}\right) Vm \left(\frac{Pbar + \frac{\Delta H}{13.6}}{Tm}\right)$ =	42.50	39.25	38.42
Volume of water collected: Vlc(ml) =	28	27	24
Volume of water vapor: Vw_{std} (std. conditions, ft^3)			
$Vw_{std} = 0.0474 \frac{ft^3}{ml}$ Vlc =	1.33	1.28	1.14
Moisture content: Bwo (proportion, dimensionless)			
$Bwo = \frac{Vw_{std}}{Vm_{std} + Vw_{std}}$ =	0.0303	0.0316	0.0288

Pitot tube coefficient: Cp (from calibration)

$Cp_{(s)} = Cp_{(std)} \sqrt{\frac{\Delta P_{(std)}}{\Delta P_{(s)}}} =$ .83

Average square root of ΔP:

$(\sqrt{\Delta P})_{avg.}$ [redacted]

$(\sqrt{\Delta P})_{avg.} = \frac{\sum_{i=1}^{n} \Delta P}{n} =$

Run #1	Run #2	Run #3
0.97	0.89	0.83

Stack pressure: Ps (in. Hg)

Ps =

Run #1	Run #2	Run #3
30.38	30.38	30.24

Molecular wt. of stack gas:
Ms (lb/lb-mole) wet basis

Ms =

Run #1	Run #2	Run #3
29.01	29.00	29.03

Average stack gas velocity: Vs (f/s)

$(Vs)_{avg} = Kp\ Cp\ (\sqrt{\Delta P})_{avg.} \sqrt{\frac{(Ts)_{avg}}{Ps\ Ms}} =$

Run #1	Run #2	Run #3
67.47	61.91	58.89

Stack gas volumetric flow rate: Qs(ft^3/hr)

$Qs = 3600(1-Bwo)(Vs)(A)\left(\frac{T_{std}}{(Ts)_{avg}}\right)\left(\frac{Ps}{P_{std}}\right) =$

Run #1	Run #2	Run #3
(3194972.1)	(2927153.1)	(2792988.2

Acetone blank correction: Ac(mg)

$Ac = \frac{Rab}{Vag}\ Vaw =$

Run #1	Run #2	Run #3
____	____	____

Total particulate sample weight: Mn (mg)

$Mn = Mn_1 + Mn_2 - Ac =$

Run #1	Run #2	Run #3
243.2	240.2	225.7

Particulate concentration: C's
(gr./s.c.f.)

$C's = 0.0154 \frac{gr.}{mg.} \left(\frac{Mn}{Vm_{std}} \right) =$

Run #1	Run #2	Run #3
0.138	0.140	0.148

Conversion:

Convert C's to units comparable to the applicable regulation:

Calculation: (show units)

$C_s \times Q_s \times \frac{1}{7000} =$

Run #1	Run #2	Run #3
62.98	61.14	58.07

Isokinetic Variation: I

$$I = \frac{Ts \left(1.667 \frac{min.}{sec.} \right) \left[\left(0.00267 \frac{in.\ Hg\text{-}ft.^3}{ml.\text{-}^\circ R} \right) Vlc + \frac{Vm}{Tm} \left(Pbar + \frac{\Delta H}{13.6} \right) \right]}{\theta Vs\ Ps\ An} =$$

Run #1	Run #2	Run #3
98%	92%	92%

Comments:

(Add attachments as necessary)

Form RE-5

Boiler #2 3/8" Nozzle

METHOD 5

	Run #1	Run #2	Run #3
Average stack temperature; Ts(°R)	848	848	839
Average dry gas meter temperature: Tm(°R)			
Tm = $\frac{\text{(avg. temp. in)+(Avg. temp. out)}}{2}$ =	554	570	571
Average orifice pressure drop: ΔH (Inches H_2O)			
From data sheet ΔH =	0.67	0.66	0.64
Gas volume through meter: Vm(ft^3) =	40.70	39.31	38.90
Dry gas volume: Vm_{std} (std. conditions, ft^3)			
$Vm_{std} = \left(17.71 \frac{°R}{\text{In. Hg}}\right) Vm \left(\frac{Pbar + \frac{\Delta H}{13.6}}{Tm}\right)$ =	39.58	37.21	36.53
Volume of water collected: Vlc(ml) =	17	16	14
Volume of water vapor: Vw_{std} (std. conditions, ft^3)			
$Vw_{std} = 0.0474 \frac{ft^3}{ml} Vlc$ =	0.81	0.76	0.66
Moisture content: Bwo (proportion, dimensionless)			
$Bwo = \frac{Vw_{std}}{Vm_{std} + Vw_{std}}$ =	0.020	0.02	0.018

Pitot tube coefficient: Cp (from calibration)

$Cp_{(s)} = Cp_{(std)} \sqrt{\frac{\Delta P_{(std)}}{\Delta P_{(s)}}} =$ .83

Average square root of ΔP:

$(\sqrt{\Delta P})_{avg.}$ [illegible]

$(\sqrt{\Delta P})_{avg.} = \frac{\sum_{i=1}^{n} \Delta P}{n} =$

Run #1	Run #2	Run #3
0.79	0.74	0.78

Stack pressure: Ps (in. Hg)

Ps =

Run #1	Run #2	Run #3
30.38	30.38	30.24

Molecular wt. of stack gas:
Ms (lb/lb-mole) wet basis

Ms =

Run #1	Run #2	Run #3
29.13	29.13	29.16

Average stack gas velocity: Vs (f/s)

$(Vs)_{avg} = Kp\ Cp\ (\sqrt{\Delta P})_{avg.} \sqrt{\frac{(Ts)_{avg}}{Ps\ Ms}} =$

Run #1	Run #2	Run #3
54.97	51.48	54.06

Stack gas volumetric flow rate: Qs (ft^3/hr)

$Qs = 3600(1-Bwo)(Vs)(A)\left(\frac{T_{std}}{(Ts)_{avg}}\right)\left(\frac{Ps}{P_{std}}\right) =$

Run #1	Run #2	Run #3
(259971.9)	(24[illegible]9162)	306958

Acetone blank correction: Ac(mg)

$Ac = \frac{Rab}{Vag}\ Vaw =$

Run #1	Run #2	Run #3
____	____	____

Total particulate sample weight: Mn (mg)

$Mn = Mn_1 + Mn_2 - Ac =$

Run #1	Run #2	Run #3
425.2	156.6	290.9

Particulate concentration: C's
(gr./s.c.f.)

$C's = 0.0154 \frac{gr.}{mg.} \left(\frac{Mn}{Vm_{std}} \right) =$

Run #1	Run #2	Run #3
0.165	0.066	0.123

Conversion:

Convert C's to units comparable to the applicable regulation:

Calculation: (show units)

C's x QS x $\frac{1}{7000}$ =

Run #1	Run #2	Run #3
61.45	22.98	53.92

Isokinetic Variation: I

$$I = \frac{Ts \left(1.667 \frac{min.}{sec.} \right) \left[\left(0.00267 \frac{in.\ Hg\text{-}ft.^3}{ml.\text{-}^\circ R} \right) Vlc + \frac{Vm}{Tm} \left(Pbar + \frac{\Delta H}{13.6} \right) \right]}{\theta Vs\ Ps\ An} =$$

Run #1	Run #2	Run #3
106%	104%	98%

Comments:

(Add attachments as necessary)

ES.

Name: Hercules Inc. Address P.O. Box 1137 Burnside

EMS No. 11-071-0101 Plant Type: Resin Extraction & Cleaning

( ) Major ( ) Minor ( ) Industrial ( ) Commercial

					Source/Reference
Emission Point Description		Ref # 334			
Emission Point No.		001			
Emission Data	Stack				
Stack Height		40'			Sept 72 AQ for DTC
Assumed Stack Height					
Exit Gas Temperature		100°F			
Exit Diameter		2.33'			
Exit Velocity		7.1 FPS			
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM *	46.5	203.4		file
	SO_2				
	NO*				
	CO*				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO*				
	CO*				
	HC				
	Other Methyl Ethyl Ketone				
Current Potential	PM				
	SO_2				
	NO*				
	CO*				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO*						
	CO*						
	HC						
	Other						

UTM Zone 16 AQCR 005

UTM North 3469.2 Km Lat. 31° 20' "

UTM East 280.6 Km Long. 89° 18' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year
	24	7	52

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

:5

Name: _____ Address _____

EMS No. / / - / / / - / / / / Plant Type: _____

( ) Major ( ) Minor ( ) Industrial ( ) Commercial

					Source/Reference
Emission Point Description		Ref #5			
Emission Point No.		001			
Emission Data	Stack				
Stack Height		40'			Sept 72 Hpl for FTO
Assumed Stack Height					
Exit Gas Temperature		92°F			"
Exit Diameter		2.33'			"
Exit Velocity		11.0 fps			
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM *	46.5	204		File
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO_x				
	CO				
→	HC				
Phillips	Other (Test Data)				
Current Potential	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone _____ AQCR _____

UTM North _____ Km Lat. _____ ° ' "

UTM East _____ Km Long. _____ ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject _____

NSPS _____

NESHAPS _____

SCC Code _____ SIC Code _____

Area _____

Comments No emissions of primary pollutant according to file.

* using the allowable emission rate for the existing source

Name: [illegible] Inc. Address [illegible]

Page ____ of ____

ES

EMS No. 11-0-10-0-0-0-0-0-1 Plant Type: ____

( ) Major ( ) Minor ( ) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Tall Oil Plant (Separate Hy Oil Boiler)	
Emission Point No.	003	
Emission Data	Stack	
Stack Height	85'	Jan 74 API for TO
Assumed Stack Height		
Exit Gas Temperature	462°F	
Exit Diameter	4'	
Exit Velocity	37.6 fps	
Volumetric Flowrate	22,318 CFM	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	10.0	43.7	Jan '74	See Attached Calculations
	SO_2	88.8	388.7	"	
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM	0.2	0.8		
	SO_2	*	*		
	NO^x	3.2	13.7		
	CO	2.3	1.5		
	HC	*	2.2		
	Other				
Current Potential	PM	2.4	1.3		
	SO_2	*	0.1		
	NO^x	20.1	[illegible]		
	CO	2.8	[illegible]		
	HC	2.1	[illegible]		
	Other	-			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM	0.2	10.0	0.8	43.7	
	SO_2	*	88.8	*	388.7	
	NO^x	3.2		13.7		
	CO	2.3		1.5		
	HC	*		0.2		
	Other					

UTM Zone ____ AQCR ____

UTM North ____ Km Lat. ____ o ____ ' ____ "

UTM East ____ Km Long. ____ o ____ ' ____ "

Hr/Day	Days/Week	Weeks/Year

Name: Hercules Inc. Address

EMS No. 11/10-00010-0010011 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description		Herclor Plant			
Emission Point No.		202			
Emission Data	Stack	Flare			
Stack Height		100 ft			
Assumed Stack Height					
Exit Gas Temperature		1700°F			
Exit Diameter		0.167 ft			
Exit Velocity					
Volumetric Flowrate		202 scfm			
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

		Act.	All.	Act.	All.		
Applicable Baseline Emission Rate	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments ~~Insufficient data to estimate emissions~~ Insignificant emissions

003 Broach Hot Oil Boiler

Natural Gas Combustion

Capacity: 36 MM BTU/hr

Consumption: 158.4 MMCF/yr @ 1025 BTU/CF

8760 hr/yr

I. Allowable

PM

$$\frac{158.4\ MMCF/yr}{\frac{8760\ hr}{yr}} * 1025\ BTU/CF = Q = 18.5\ MMBTU/hr$$

if Q = 18.5 MMBTU/hr => E = 0.54 lb/MMBTU

∴ Allow = 10.0 lb/hr or 43.9 TPY

SO_2

use 4.8 lb/MMBTU

=> Allow = 88.8 lb/hr or 388.9 TPY

II Actual

158.4 MMCF/yr * $EF_{N.G.}$ as shown in EF table

III Potential

$$\left(\frac{36\ MMBTU/hr}{1025\ BTU/CF}\right) * EF_{N.G.}$$

above data taken from Jan '94 Apl for PTO

Emission Factors

I Natural Gas

from AP-42 (Sup E) Table 1.4-1

Pollutant	Emission Factor (EF) (lbs/MMCF)
PM	15 (median of range, 5
SO_x	0.6
NO_x	140 (median of range, 120
CO	17
HC	3

II #2 Fuel Oil (Distillate)

from AP-42 (Sup 3) - Table 1.3-1

Pollutant	Emission Factor (EF)* (lb/10^3 gal)
PM	2
SO_x	28.8[A.] (142)
NO_x	2.8
CO	0.63
HC	0.12

A. based on 0.2% Sulfur Content

B @ 1% Sulfur Content

* values used represent

ES

Name: Hercules Inc. Address _____ Page _____ of _____

EMS No. 1110-01810-c101c1011 Plant Type: _____
(X) Major ( ) Minor (X) Industrial ( ) Commercial

				Source/Reference
Emission Point Description	Tall Oil Plant Boilers			
Emission Point No.	004 (Boiler #1)			
Emission Data	Stack			
Stack Height	100'			San 74 Apl for PTO
Assumed Stack Height				↓
Exit Gas Temperature	463°			
Exit Diameter	4'			
Exit Velocity	29.6 fps			
Volumetric Flowrate	22,318 CFM			

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	23.8	104.1	Jan 74	See Attached Calculations ↓
	SO_2	250.5	1097	"	
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM	2.2	9.5	"	
	SO_2	35.2	154	"	
	NO^x	11.2	49.2	"	
	CO	0.7	3.0	"	
	HC	0.1	0.6	"	
	Other				
Current Potential	PM	10.7	46.9	"	
	SO_2	147.4	645.6	"	
	NO^x	44.2	193.6	"	
	CO	2.1	9.2	"	
	HC	0.4	1.8	"	
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM	2.2	23.8	9.5	104	"
	SO_2	35.2	250.5	154	1097	"
	NO^x	11.2		49.2		"
	CO	0.7		3.0		"
	HC	0.1		0.6		"
	Other					

UTM Zone _____ AQCR _____

UTM North _____ Km Lat. _____ o ' "

UTM East _____ Km Long. _____ o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject _____

NSPS _____

NESHAPS _____

SCC Code _____ SIC Code _____

Area _____

Comments NOT IN OPERATION NOW

ES

Name: Hercules Inc. Address _____ Page _____ of _____

EMS No. 1116-0180-C0101011 Plant Type: _____
(X) Major ( ) Minor (X) Industrial ( ) Commercial

				Source/Reference
Emission Point Description		Tall Oil Plant Boilers		
Emission Point No.		004 (Boiler #2)		
Emission Data		Stack		
Stack Height		100'		Jan 74 Apl for PTO
Assumed Stack Height				↓
Exit Gas Temperature		463°		
Exit Diameter		4'		↓
Exit Velocity		29.6 fps		
Volumetric Flowrate		22,318 CFM		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	23.8	104.1	Jan 74	See Attached Calculation
	SO_2	250.5	1097	"	↓
	NO^*				
	CO				
	HC				
	Other				
Current Actual	PM	2.2	9.5	"	
	SO_2	35.2	154	"	
	NO^*	11.2	49.2	"	
	CO	0.7	3.0	"	
	HC	0.1	0.6	"	
	Other				
Current Potential	PM	10.7	46.9	"	
	SO_2	147.4	645.6	"	
	NO^*	44.2	193.6	"	
	CO	2.1	9.2	"	
	HC	0.4	1.8	"	
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM	2.2	23.8	9.5	104	"	
	SO_2	35.2	250.5	154	1097	"	
	NO^*	11.2		49.2		"	
	CO	0.7		3.0		"	
	HC	0.1		0.6		"	
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

Tall Oil Plant Boilers 004 ← Data taken from Jan 74 Apl for PTO

two Indentical Units

Capacity: 64 MM BTU/hr

Consumption: Resin Pitch 7536 M lb/yr @ 16,800 BTU/lb & 0.26% S
Resin Oils 4455 M lb/yr @ 16,800 BTU/lb & 0.26% S
#6 Fuel Oil 693 M Gal/yr (8 lb/gal) @ 19000 BTU/lb & 2.23% S
Nat. Gas 146,698 MCF/yr @ 1025 BTU/CF

BTU Content:

7536 M lb/yr @ 16,800 BTU/lb	14.45	MM BTU/h
4455 M lb/yr @ 16,800 BTU/lb	8.54	"
693 M gal/yr @ 19,000 BTU/lb	12.02	"
146,698 MCF/yr @ 1025 BTU/CF	17.17	"
	52.18	MM BTU/h

I. Allowable Emissions

PM

Q = 52.18 MM BTU/hr => E = 0.46

=> Allow = 23.8 lb/hr or 104.1 TPY

SO_2 use 4.8 lb/MM BTU

=> Allow = 250.5 lb/hr or 1097 TPY

II Potential Emissions

assume #6 Fuel Oil only

(64 MM BTU/hr) (1 lb/19000 BTU) * $EF_{\#6\ oil}$

↳ See EF table attached

continued on back

Emission Factors

I Natural Gas

from AP-42 (Sup 8) Table 1.4-1

Pollutant	Emission Factor (EF) (lbs/MMCF)
PM	10 (median of range, 5-1
SO_x	[illegible]
NO_x	1[illegible]0 (median of range, 120-
CO	17
HC	8

II # 2 Fuel Oil (Distillate)

from AP-42 (Sup 8) - Table 1.3-1

Pollutant	Emission Factor (EF)* (lc/10^3 gal)
PM	2
SO_x	144(S)
NO_x	2.8
CO	0.63
HC	0.12

where S is the Sulfur Content in % by wt.

A. based on 0.2% Sulfur Content EF = 28.8

B @ .1% Sulfur Content EF = 142

Name: Hercules Inc. Address

EMS No. VIB-A-105-CRPI Plant Type:
(*) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: Delnav Plant (flare)	
Emission Point No.: 005	
Emission Data: Stack	
Stack Height: 100 ft	
Assumed Stack Height	
Exit Gas Temperature: 730°F	
Exit Diameter: 0.0417 ft	
Exit Velocity: 69 ft/sec	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2	2000 ppm			
	NO_x				
	CO				
	HC				
	Other				
Current Actual	PM				
	SO_2	* 25.4	* 155		
	NO_x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

ES

Name: Hercules Inc Address

EMS No. 11b-018100-0101C1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: Poly-Pale Plant	
Emission Point No.: 006	
Emission Data Stack: WATER SCRUBBER	
Stack Height: ft 35	
Assumed Stack Height	
Exit Gas Temperature: ambient	
Exit Diameter: ft .25	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: *Insignificant emissions from natural gas combustion
Insufficient data to determine process emissions

Name: Hercules Inc Address

EMS No. 11 b-01106-ac/cb/11 Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: Limiting Unit	
Emission Point No.: 007	
Emission Data: Stack	
Stack Height	
Assumed Stack Height	
Exit Gas Temperature	
Exit Diameter	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. - o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: Unit out of operation since 1974

Name: [illegible] Address:

EMS No. 110-21000-d-0001 Plant Type:

(*) Major ( ) Minor (*) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Rosin Shed	
Emission Point No.	008	
Emission Data	Stack	
Stack Height	ft 15	
Assumed Stack Height		
Exit Gas Temperature	ambient	
Exit Diameter	ft 1.5	
Exit Velocity		
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments ~~Insufficient~~ data for estimating emissions.

* Insignificant

-11-

Name: Hercules Inc. Address _____ Page _____ of _____

EMS No. 1110-08100-00101 Plant Type: _____
(/) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description		Combination Boiler #1			
Emission Point No.		009			
Emission Data	Stack				
Stack Height		200'			based on May 76 Stack test
Assumed Stack Height					
Exit Gas Temperature		378°			
Exit Diameter		4.6'			
Exit Velocity		62.8 fps			
Volumetric Flowrate		49,531.7 CFM			
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	127.4	557.7		
	SO_2				
	NO^*				
	CO				
	HC				
	Other				
Current Actual	PM	60.3	264.1		
	SO_2				
	NO^*				
	CO				
	HC				
	Other				
Current Potential	PM	60.3	264.1		
	SO_2				
	NO^*				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM	60.3	127.4	264.1	557.7		
	SO_2						
	NO^*						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments both units [illegible] exhaust through [illegible] stack

Note these two boilers now have a common [illegible]

data taken from May '95 Stack test

Combination Boiler #1 009

2971904.8 CF/hr @ 0.142 gr/DSCF
↑ test result

Actual

$E = (2971904.8\ CF/hr)(0.142\ gr/DSCF)(1\ lb/7000\ gr)$
$= 60.3\ lb/hr$ or $264.1\ TPY$

Allowable use 0.3 gr/DSCF

$E = (2971904.8\ CF/hr)(0.3\ gr/DSCF)(1\ lb/7000\ gr)$
$= 127.4\ lb/hr$ or $557.9\ TPY$

Potential = Actual (No Controls + Continuous Operation)

Boiler #2

2701827.5 CF/hr @ 0.116 gr/DSCF

Actual

$E = (2701827.5\ CF/hr)(0.116\ gr/DSCF)(1\ lb/7000\ gr)$
$= 49.2\ lb/hr$ or $215.5\ TPY$

Allowable use 0.3 gr/DSCF

$E = (2701827.5\ CF/hr)(0.3\ gr/DSCF)(1\ lb/7000\ gr)$
$= 115.8\ lb/hr$ or $507.2\ TPY$

Potential = Actual

No Controls - Continuous Operation

See Reverse

Name: Hercules Inc Address: Page ___ of 11

EMS No. 11b-01810b-c0c0b1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Combination Boiler #2	
Emission Point No.	009	
Emission Data	Stack	
Stack Height	300'	based on May 76
Assumed Stack Height		Stack Test
Exit Gas Temperature	385° F	↓
Exit Diameter	4.6'	
Exit Velocity	53.5 fps	
Volumetric Flowrate	45030.5 CFM	

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM	115.8	507.2	
	SO_2			
	NO^*			
	CO			
	HC			
	Other			
Current Actual	PM	49.2	215.5	
	SO_2			
	NO^*			
	CO			
	HC			
	Other			
Current Potential	PM	49.2	215.5	
	SO_2			
	NO^*			
	CO			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM	49.2	115.8	215.5	507.2	
	SO_2					
	NO^*					
	CO					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

ES

Name: Hercules Inc Address: Page ____ of ____

EMS No. 1116-0180D-C0100101 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

Source/Reference

Emission Point Description: Combination Boiler #3

Emission Point No.: 010

Emission Data Stack: includes Boiler #4

Stack Height: ft 225

Assumed Stack Height:

Exit Gas Temperature: 400 °F

Exit Diameter: ft 10

Exit Velocity: ft/sec 13.6

Volumetric Flowrate:

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	127.4	557.9		
	SO_2				
	NO^*				
	CO				
	HC				
	Other				
Current Actual	PM	69.1	302		
	SO_2				
	NO^*				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject:

NSPS:

NESHAPS:

SCC Code SIC Code

Area:

Comments: No data available for ~~[illegible]~~ emissions ~~[illegible]~~ comparible to Source #2 (emp't 009)

Name: [redacted] Inc. Address [redacted] Page ____ of ____

EMS No. 11-710-10001 Plant Type: ____
(X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description	Combination Boiler #4				
Emission Point No.	010				
Emission Data Stack	See Combination Boiler #3				
Stack Height					
Assumed Stack Height					
Exit Gas Temperature					
Exit Diameter					
Exit Velocity					
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

		Act.	All.	Act.	All.		
Applicable Baseline Emission Rate	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments No data available for determination of emissions but these are considered to be similar to Boilers #1 & 2 (see sheet)

EMS No. 11b-01300-10101 Plant Type:
( ) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Recovery Boiler #5	
Emission Point No.	011	
Emission Data	Stack	3/5/80
Stack Height	71'	Form 7-4 Pol for PTO
Assumed Stack Height		
Exit Gas Temperature	250°F	
Exit Diameter	3'	
Exit Velocity	53.3 Fps	
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	34.3	150.1	Jan 74	See Attached Calculations
	SO_2	333.3			
	NO^x				✓
	CO				
	HC				
	Other				
Current Actual	PM	3.6	37.7		
	SO_2	115.1	504.3		
	NO^x	39.8	174.3		
	CO	5.1	2.4		
	HC	0.4	1.8		
	Other				
Current Potential	PM	26.0	113.9		
	SO_2	359.3	1573.7		
	NO^x	107.8	472.2		
	CO	5.1	22.3		
	HC	1.0	4.4		
	Other				

Applicable Baseline Emission Rate		Act. lb/hr	All. lb/hr	Act. ton/yr	All. ton/yr
	PM	3.6	34.3	37.7	150.1
	SO_2	115.1	588.3	504.3	1201
	NO^x	39.8		174.3	
	CO	5.1		2.4	
	HC	0.4		1.8	
	Other				

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Pre Variance Emissions

Package Boiler #5 (011)

W/o Variance

Capacity: 156 MMBTU/hr

Consumption: 264 MMCF/yr @ 1025 BTU/CF N.G.

$2,880 \times 10^3$ gal/yr @ 19000 BTU/lb #6 Oil

8lb/gal + 2.23% S

8760 hr/yr

Actual

264 MMCF/yr * EF_{NG} ← See table

2880×10^3 gal/yr * $EF_{\#6\,oil}$

Allowable

264 MMCF/yr * 1025 BTU/CF 30.9 MMBTU/hr

2880×10^3 gal/yr * 19000 BTU/lb 50.0 MMBTU/hr

Q = 80.9 MMBTU/hr

PM

Q = 80.9 MMBTU/hr ⇒ E = 0.42

⇒ A = 34.3 lb/hr or 150.1 TPY

SO_2 use 4.8 lb/MMBTU

⇒ A = 388.3 lb/hr or 1700.8 TPY

Potential

assume all #6 Fuel Oil at rated capacity

$$\left[\frac{(156\ \text{MMBTU/hr})}{\left(\frac{19000\ \text{BTU}}{\text{lb}}\right)\left(\frac{8\ \text{lb}}{\text{gal}}\right)}\right] * EF_{\#6\,oil}$$

#6 Fuel Use Under Variance

Actual

$107.7\ MMCF/yr * EF_{N.G}$

$3936 \times 10^3\ gal * EF_{\#6\ Oil}$

Allowable + Potential

Same as previous calculations

Emission Factors

III #6 Fuel Oil (Residual)

Table 1.3-1 from AP-42 (Sup 8), Power Plant Use

Pollutant Type	Emission Factor (EF) (lb / 10^3 gal)
PM	10(S) + 3
SO_2	157 (S)
NO_x	105
CO	5
HC	1

where S is Sulfur in % by wt

IV Coal (Bituminous Coal)

Table 1.1-2 (AP-42, Sup 8)

Pollutant Type	Emission Factor (EF) lb / ton
PM	16A
SO_x	38S
NO_x	18
CO	—
HC	—

where: A is % by wt of Ash

S is % by wt of Sulfur

, above values for furnace size of >100 MM BTU/hr

ES

Name: Hercules Inc Address

EMS No. 11/0-delclo-clobtl/ Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

				Source/Reference
Emission Point Description		Package Boiler #5		
Emission Point No.		211		
Emission Data	Stack			
Stack Height		71'		Jan 74 Appl for PTO
Assumed Stack Height				
Exit Gas Temperature		320°F		
Exit Diameter		8'		
Exit Velocity		120.4 FPS (?)		
Volumetric Flowrate				

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM	34.3	150.1	Jan 77	See Hached Calculations
	SO_2	388.3	1700.8	"	
	NO				
	CO				
	HC				
	Other				
Current Actual	PM	11.5	50.3	"	
	SO_2	157.3	689.0	"	
	NO	49.3	216.0	"	
	CO	2.5	10.8	"	
	HC	0.5	2.1	"	
	Other				
Current Potential	PM	26.0	113.9	"	
	SO_2	359.3	1573.7	"	
	NO	107.8	472.2	"	
	CO	5.1	22.3	"	
	HC	1.0	4.4	"	
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM	11.5	34.3	50.3	150.1	"	
	SO_2	157.3	388.3	689.0	1701	"	
	NO	49.3		216.0		"	
	CO	2.5		10.8		"	
	HC	0.5		2.1		"	
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Emissions w/ Variance for increased [illegible] Fuel Oil [illegible]

Name: [illegible] Address:

ES

EMS No. 110-0806-0000011 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description	Pitch Blowing Facility
Emission Point No.	21
Emission Data Stack	Vents to wood waste boiler
Stack Height	
Assumed Stack Height	
Exit Gas Temperature	
Exit Diameter	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments* Insignificant emissions from natural gas fuel combustion
Insufficient data to estimate emissions.

Name: Hercules Inc Address

EMS No. 11b-d/d0b-0b/d/d/1 Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description	Pulverized Vinsol Mill				
Emission Point No.	013				
Emission Data	Stack				
Stack Height					
Assumed Stack Height					
Exit Gas Temperature					
Exit Diameter					
Exit Velocity					
Volumetric Flowrate					

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments No longer in operation according to Steve West (10/12/77)

Name: Hercules Inc. Address

25

EMS No. 1110-01-0100-010101 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Truline Flaking Belt & Pack	
Emission Point No.	014	
Emission Data Stack	Baghouse	
Stack Height	40 ft	
Assumed Stack Height		
Exit Gas Temperature	70 °F	
Exit Diameter		
Exit Velocity		
Volumetric Flowrate	2100 ~~ACFM~~	

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Actual	PM	~~*~~		
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.
	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments ~~Insufficient data to determine process emissions.~~

* ~~Insignificant emissions~~

ES

Name: Hercules Inc. Address

EMS No. 1/1/0-0/8/0/0-0/0/0/0/1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Hard Resins Area	
Emission Point No.	015	
Emission Data	Stack	
Stack Height	6 ft	
Assumed Stack Height		
Exit Gas Temperature	70°F	
Exit Diameter	1.5 ft	
Exit Velocity	[illegible] ft/sec	
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				
Current Actual	PM	<			
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^x						
	CO^x						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: Insignificant emissions from natural gas combustion. Insufficient data to determine process emissions if any. Applicant reports 'none detected'.

ES

Name: Hercules Inc. Address

EMS No. 1110-018010-000001 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

Source/Reference

Emission Point Description: Continuous esterification Unit

Emission Point No.: 016

Emission Data: Stack common vent after condenser

Stack Height: 65 ft

Assumed Stack Height:

Exit Gas Temperature: Ambient

Exit Diameter: 2.25

Exit Velocity:

Volumetric Flowrate:

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Actual	PM	t		
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM					
	SO_2					
	NO^*					
	CO^*					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: t Insignificant emissions ~~from~~ natural gas ~~combustion~~. Insufficient data to determine process emissions if any. Applicant reports 'none detected'.

Name: Hercules Inc. Address

EMS No. 1110-0180-0-0-0-0-0-1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

				Source/Reference
Emission Point Description		Metalyn Unit		
Emission Point No.		017		
Emission Data	Stack			
Stack Height				
Assumed Stack Height				
Exit Gas Temperature		NOT IN OPERATION		
Exit Diameter				
Exit Velocity				
Volumetric Flowrate				

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Insignificant emissions from natural gas combustion. Insufficient data to determine process emissions if any. Applicant reports 'none detected'.

Name: _____ Address _____

EMS No. / / - / / / - / / / / Plant Type: _____

( ) Major ( ) Minor ( ) Industrial ( ) Commercial

Source/Reference

Emission Point Description

Emission Point No.

Emission Data Stack

Stack Height

Assumed Stack Height

Exit Gas Temperature

Exit Diameter

Exit Velocity

Volumetric Flowrate

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO^x			
	CO			
	HC			
	Other			
Current Actual	PM			
	SO_2			
	NO^x			
	CO			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO^x			
	CO			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM					
	SO_2					
	NO^x					
	CO					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

Name: Hercules Inc. Address

EMS No. 110-0156-0101 Plant Type:

( ) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Flaking House at Bond Factory No. 3	
Emission Point No.	213	
Emission Data Stack	filter	scrubber
Stack Height	40'	6'
Assumed Stack Height		
Exit Gas Temperature	70°F	70°F
Exit Diameter	1'	2.5'
Exit Velocity	11.2	7.5
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments ~~Insufficient data~~

* Insignificant

Name: Hercules Inc. Address

EMS No. 1110-0810-0010-0001 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: Coal + Staybelite Plant	
Emission Point No.: 019	
Emission Data: Stack — no flow rate	
Stack Height: 20 ft	
Assumed Stack Height	
Exit Gas Temperature: ambient	
Exit Diameter: 2.17 ft	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO^x			
	CO			
	HC			
	Other			
Current Actual	PM	+		
	SO_2			
	NO^x			
	CO			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO^x			
	CO			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.
	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

AFS

Comments: Insignificant emissions from natural gas combustion. ~~Insufficient data to determine process emissions. Company applicant reports none detected.~~

ES

EMS No. 111-0004-00101 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description	Dist Plant				
Emission Point No.	021				
Emission Data	Stack				
Stack Height	50 ft				
Assumed Stack Height					
Exit Gas Temperature					
Exit Diameter	.28 ft				
Exit Velocity					
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				
Current Actual	PM	X			
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				
Applicable Baseline Emission Rate		Act. / All.	Act. / All.		
	PM				
	SO_2				
	NO^x				
	CO^x				
	HC				
	Other				

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Insignificant [illegible] there is no information in the file to the contrary.

ES

Name: Hercules Inc. Address

EMS No. 1110-018/06-01-0/01 Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Hydrogen Furnace	
Emission Point No.	020	
Emission Data	Stack	
Stack Height	45 ft	
Assumed Stack Height		
Exit Gas Temperature		
Exit Diameter	0.17 ft	
Exit Velocity		
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM	X			
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments *Inorganics - [illegible] combustion.

Name: Hercules Inc. Address

ES

EMS No. 1110-018/010-0/0/c/0/1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

				Source/Reference
Emission Point Description	Resin 731 Area			
Emission Point No.	022			
Emission Data	Stack			
Stack Height	20 ft			
Assumed Stack Height				
Exit Gas Temperature				
Exit Diameter	0.17 ft			
Exit Velocity				
Volumetric Flowrate				

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Actual	PM	+	-	
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM			-			
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: Insignificant emissions from natural gas combustion. ~~Insufficient data to determine process emissions~~ #2 if any. ~~Applicant reports 'none detected'~~.

Name: Hercules Inc. Address

ES

EMS No. 1110-018010-0001 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description	Stills + Dresinates Facility
Emission Point No.	023
Emission Data	Stack
Stack Height	ONE NO FLOW VENT
Assumed Stack Height	only omit steam
Exit Gas Temperature	
Exit Diameter	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^*				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: * Insignificant emissions from natural gas combustion. ~~If sufficient data to determine~~ NO process emissions ~~if any.~~ Applicant records 'none detected'.

Name: Hercules, Inc. Address

EMS No. 11110-08606-00000 Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

ES

	Source/Reference
Emission Point Description: Kymene Plant	
Emission Point No.: 024	
Emission Data: Stack	
Stack Height: 40 ft	
Assumed Stack Height	
Exit Gas Temperature: 70°F	
Exit Diameter: 2.67 ft	
Exit Velocity: 0.1 ft/sec	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO_x			
	CO			
	HC			
	Other			
Current Actual	PM	*		
	SO_2			
	NO_x			
	CO			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO_x			
	CO			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.
	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments * - emissions, TO

Name: _____ Address _____

EMS No. __/__-___/___-____/____ Plant Type: _____

( ) Major ( ) Minor ( ) Industrial ( ) Commercial

					Source/Reference
Emission Point Description					
Emission Point No.					
Emission Data	Stack				
Stack Height					
Assumed Stack Height					
Exit Gas Temperature					
Exit Diameter					
Exit Velocity					
Volumetric Flowrate					
Emission Rates		lb/hr		ton/yr	Date
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Applicable Baseline Emission Rate		Act.	All.	Act.	All.
	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

UTM Zone _____ AQCR _____

UTM North _____ Km Lat. _____ o ' "

UTM East _____ Km Long. _____ o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject _____

NSPS _____

NESHAPS _____

SCC Code _____ SIC Code _____

Area _____

Comments

Name: Hercules Inc. Address

EMS No. 1110-0810-0-0-0-0-0-11 Plant Type:

ES (X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description		Defoamer Plant			
Emission Point No.		025			
Emission Data	Stack				
Stack Height		Vents into			
Assumed Stack Height		a closed shed			
Exit Gas Temperature					
Exit Diameter					
Exit Velocity					
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM	*	-		
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

		Act.	All.	Act.	All.		
Applicable Baseline Emission Rate	PM			-			
	SO_2						
	NO^x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments * Insignificant emissions from natural gas combustion.

~~Insufficient data to determine~~ No process emissions if any. Applicant reports 'none detected'.

ES

Name: Hercules Inc. Address

EMS No. 1110-018/0/0-0/0/0/0/1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description	Resin Amine D Plant				
Emission Point No.	026				
Emission Data	Stack				
Stack Height					
Assumed Stack Height					
Exit Gas Temperature					
Exit Diameter					
Exit Velocity					
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

		Act.	All.	Act.	All.	
Applicable Baseline Emission Rate	PM					
	SO_2					
	NO^x					
	CO					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: ~~1~~ insignificant emissions from natural gas combustion. ~~It suffices data to determine~~ ~~if any~~. Applicant reports 'none detected'.

ES

Name: Hercules Inc. Address

EMS No. 1110-0180-0-0-0-0-1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

					Source/Reference
Emission Point Description	Rosin PS687 Plant				
Emission Point No.	037				
Emission Data	Stack				
Stack Height					
Assumed Stack Height					
Exit Gas Temperature					
Exit Diameter					
Exit Velocity					
Volumetric Flowrate					
Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

		Act.	All.	Act.	All.	
Applicable Baseline Emission Rate	PM					
	SO_2					
	NO^x					
	CO					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments * Insignificant emissions from natural gas combustion. Insufficient data to ~~determine~~ NO process emissions if ~~any~~. Applicant reports 'none detected'.

ES.

Name: _____ Address: _____

EMS No. 11D-C1P1o1o-d01o1o1 Plant Type: _____

(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: Polyrad-Polyol Unit	
Emission Point No.: 028	
Emission Data: Stack	
Stack Height: ONE NO FLOW VENT	
Assumed Stack Height	
Exit Gas Temperature	
Exit Diameter	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone _____ AQCR _____

UTM North _____ Km Lat. _____ o ' "

UTM East _____ Km Long. _____ o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject _____

NSPS _____

NESHAPS _____

SCC Code _____ SIC Code _____

Area _____

Comments Insufficient data - [illegible] Process emissions [illegible] Insignificant [illegible]

ES

Name: Hercules Inc. Address

EMS No. 11D-0130D-C10101 Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: 252 - Cymene Unit	
Emission Point No.: 002	
Emission Data: Stack	
Stack Height: CLOSED SYSTEM	
Assumed Stack Height: VENT	
Exit Gas Temperature	
Exit Diameter	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

Name: Hercules Inc Address:

EMS No. 11b-7800-00000 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Para-methane Unit	
Emission Point No.	030	
Emission Data	Stack	
Stack Height	CLOSED SYSTEM	
Assumed Stack Height	NO VENT	
Exit Gas Temperature		
Exit Diameter		
Exit Velocity		
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments

Name: Hercules Inc. Address

ES

EMS No. 1110-0810-0101011 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Para-Methane hydroperoxide facility	
Emission Point No.	231	
Emission Data Stack	ONE NO FLOW VENT	
Stack Height	30 ft	
Assumed Stack Height		
Exit Gas Temperature		
Exit Diameter	3.0 ft	
Exit Velocity		
Volumetric Flowrate		

Emission Rates		lb/hr		ton/yr		Date	
Current Allowable	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						
Current Actual	PM	X					
	SO_2						
	NO_x						
	CO						
	HC						
	Other						
Current Potential	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						
Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Insufficient data to determine if process is subject to PSD review.

+ INSIGNIFICANT

Name: Hercules Inc. Address

EMS No. 11b-CR10b-00001 Plant Type:

(x) Major ( ) Minor (X) Industrial ( ) Commercial

35

	Source/Reference
Emission Point Description	Sulfate Turpentine Refining Unit
Emission Point No.	032
Emission Data	Stack
Stack Height	50 ft
Assumed Stack Height	
Exit Gas Temperature	
Exit Diameter	2.17 ft
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Actual	PM	*			
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^*				
	CO^*				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^*						
	CO^*						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Insufficient data to [illegible] Process emissions and/or applicant [illegible] were not [illegible]. [illegible]

Name: Hercules Inc. Address

EMS No. 11-0800-00001 Plant Type:
(x) Major ( ) Minor (x) Industrial ( ) Commercial

Source/Reference

Emission Point Description: Synthetic Pine Oil Unit

Emission Point No.: 033

Emission Data: Stack CLOSED SYSTEM

Stack Height: NO VENT

Assumed Stack Height

Exit Gas Temperature

Exit Diameter

Exit Velocity

Volumetric Flowrate

Emission Rates		lb/hr		ton/yr		Date
Current Allowable	PM					
	SO_2					
	NO^*					
	CO					
	HC					
	Other					
Current Actual	PM					
	SO_2					
	NO^*					
	CO					
	HC					
	Other					
Current Potential	PM					
	SO_2					
	NO^*					
	CO					
	HC					
	Other					
Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM					
	SO_2					
	NO^*					
	CO					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: Insufficient information for estimation of fugitive emissions. - N/A. Applicant reports none detected.

ES

Name: Hercules Inc. Address

EMS No. 1/1/0-0/8/0/0-0/0/0/0/1 Plant Type:
(X) Major ( ) Minor (X) Industrial ( ) Commercial

Source/Reference

Emission Point Description: Column 5- Tall Oil Plant

Emission Point No.: 034

Emission Data: Stack

Stack Height: NOT IN

Assumed Stack Height: OPERATION

Exit Gas Temperature

Exit Diameter

Exit Velocity

Volumetric Flowrate

Emission Rates		lb/hr	ton/yr	Date
Current Allowable	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Actual	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			
Current Potential	PM			
	SO_2			
	NO^*			
	CO^*			
	HC			
	Other			

Applicable Baseline Emission Rate		Act.	All.	Act.	All.	
	PM					
	SO_2					
	NO^*					
	CO^*					
	HC					
	Other					

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: Insignificant emissions from natural gas combustion. Insufficient data to determine if source emits [illegible] if any. Applicant reports 'none detected'.

Name: [redacted]

EMS No. 1110-0180004 (1)(1)(1) Plant Type:

ES (X) Major ( ) Minor (X) Industrial ( ) Commercial

	Source/Reference
Emission Point Description: Paracol Plant	
Emission Point No.: 035	
Emission Data: Stack	
Stack Height: CLOSED SYSTEM NO VENT	
Assumed Stack Height	
Exit Gas Temperature	
Exit Diameter	
Exit Velocity	
Volumetric Flowrate	

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Actual	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO^x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO^x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. ° ' "

UTM East Km Long. ° ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments: Insufficient data to determine fugitive emissions, if any. Application reports 'none detected'.

Permit Status

Check the type of permit your facility currently has in effect. Facilities with multiple permits should list them separatley on the back of this sheet. Include the expiration date for any expired or existing permits.

( ) No Permit

( ) Expired Permit

(2) Tolerance Permits expire 7/31/75.

( ) Performance Evaluation Permit

( ) Construction Permit

(31) Operating Permits expire 2/6/77

( ) Variance

Air Pollution Control Equipment Maintenance Cost/Year
(Excluding Capital Cost)

Souree No.	Equipment Type	Maintenance Cost/Year
19, 20	Fly Ash Arrestors	6000
21, 22	" " "	6000
27	Flare tower	2000

Name: Hercules Inc Address

ES

EMS No. 110-0210-0010/1 Plant Type:

(X) Major ( ) Minor (X) Industrial ( ) Commercial

		Source/Reference
Emission Point Description	Carbon Regenerating Furnace	
Emission Point No.	038	
Emission Data	Stack	
Stack Height	41 FT	
Assumed Stack Height		
Exit Gas Temperature	170 °F	
Exit Diameter	2.75 ft	
Exit Velocity	49 ft/sec	
Volumetric Flowrate		

Emission Rates		lb/hr	ton/yr	Date	
Current Allowable	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Actual	PM	X			
	SO_2				
	NO_x				
	CO				
	HC				
	Other				
Current Potential	PM				
	SO_2				
	NO_x				
	CO				
	HC				
	Other				

Applicable Baseline Emission Rate		Act.	All.	Act.	All.		
	PM						
	SO_2						
	NO_x						
	CO						
	HC						
	Other						

UTM Zone AQCR

UTM North Km Lat. o ' "

UTM East Km Long. - o ' "

Operating Schedule	Hr/Day	Days/Week	Weeks/Year

PSD Review Subject

NSPS

NESHAPS

SCC Code SIC Code

Area

Comments Negligible emissions from natural gas combustion and [illegible]

AIR POLLUTANT EMISSIONS SURVEY

FOR OFFICE USE ONLY

Received By:
Reviewed By: Jesse Thompson
County: ~~Forrest~~
SIC Number: 2861
Coordinates: 280.3X3469.6

Firm Name: Hercules Incorporated 545-3450

Person To Contact Regarding This Report: Charles S. Jordan Title: Sr. Chemical Engineer Phone: ~~584-6411~~

Mailing Address: P. O. Box 1937

Plant Address: West Seventh Street

Plant Location: Lat. N 31° 20' Long. W 89° 18'

Nature of Business: (Products) Chemicals

Employees at Plant Location: 800 If Seasonal, Give Range 750-850

Approximate Land Area at Plant Location: 180 acres

Information is representative of calender year 1974 SIC Code 2861 (Major) 2879 & 2822 (Minor)

SECTION 1 - FUEL USE FOR GENERATION OF HEAT, STEAM, AND POWER

Normal Operating Schedule: 3-8 hr. shifts Hours per day 24 Days per week 7 Weeks per year 52

Seasonal and/or Peak Operation Period: (Specify) Continuous

Estimate of Percent of Total Fuel Consumed to Provide Space Heat: 1.2% (Doesn't include air conditioning).

Source No.	A Size of unit (input) (B) 10^6 Btu hr	B Type unit (C)	C Installation Date	D Fuel data (D) Type fuel (E)	E Amount per year (F)	F Heat content (G) Btu	G Percent sulfur (G-H)	H Percent ash (coal only) (G-H)
1	1.6	McKee	1940	Natural Gas	7,013 MCF	1,025/CF	0.00016	
2	1.6	"	1944	"	"	"	"	
3	1.6	"	1946	"	"	"	"	
4	1.6	"	1948	"	"	"	"	
5	1.6	"	1950	"	"	"	"	

Source No.	I Air cleaning equipment Type (I)	J Efficiency (J) %	K Estimate of contaminants (M) Type (K)	L Quantity (L)

Use Additional Sheets If Necessary

urce No.	A Size of unit (input) (B) 10^6 Btu hr	B Type unit (C)	C Installation Date	D Fuel data (D) Type fuel (E)	E Amount per year (F)	F Heat content (G) Btu	G Percent sulfur (G-H)	H Percent ash (coal only) (G-H)
6	1.6	McKee	1950	Natural Gas	7,013 MCF	1,025/CF	0.00016	
7	3.3	Foster Wheeler	1941	"	14,464 MCF	"	"	
8	5.0	"	1950	"	21,915 MCF	"	"	
9	5.0	"	1964	"	"	"	"	
0	5.0	"	1964	"	"	"	"	

Source No.	I Air cleaning equipment Type (I)	J Efficiency (J) %	K Estimate of contaminants (M) Type (K)	L Quantity (L)

Use Additional Sheets If Necessary

	A	B	C	D	E	F	G	H
ource No.	Size of unit (input) (B) 10^6 Btu hr	Type unit (C)	Installation Date	Fuel data (D) Type fuel (E)	Amount per year (F)	Heat content (G) Btu	Percent sulfur (G-H)	Percent ash (coal only) (G-H)
11	3.3	Struthers Wells	1965	Natural Gas	14,464 MCF	1,025/CF	0.00016	
12	3.3	"	1966	"	"	"	"	
13	8.3	"	1966	"	36,379 MCF	"	"	
14	8.3	"	1969	"	"	"	"	
15	13.3	Riley Stoker	1968	"	58,294 MCF	"	"	

	I	J	K	L
Source No.	Air cleaning equipment Type (I)	Efficiency (J) %	Estimate of contaminants (M) Type (K)	Quantity (L)

Use Additional Sheets If Necessary

ource No.	A Size of unit (input) (B) 10^6 Btu hr	B Type unit (C)	C Installation Date	D Fuel data (D) Type fuel (E)	E Amount per year (F)	F Heat content (G) Btu	G Percent sulfur (G-H)	H Percent ash (coal only) (G-H)
16	36	Broach	1968	Natural Gas	157,788 MCF	1,025 / CF	0.00016	
17	64	Riley Stoker	1968	Gas Oil	199,459 MCF 10,738 M lb	1,025 / CF 16,800 / lb	0.26	
18	64	"	1968	"	"	"	"	
19	138	Wood	1935	Gas Oil Wood	183,000 MCF 1,060 M lb 72,500 M lb.	1,025 / CF 16,800 / lb 8,340 / lb	0.00016 0.6 0.0	
20	138	"	1935	"	"	"	"	

Source No.	I Air cleaning equipment Type (I)	J Efficiency (J) %	K Estimate of contaminants (M) Type (K)	L Quantity (L)
19	Fly Ash Arrestors	92% Rated	Fly Ash, Sand	17.6 tons/yr.
20	"	"	"	"

Use Additional Sheets If Necessary

ource No.	A Size of unit (input) (B) 10^6 Btu hr	B Type unit (C)	C Installation Date	D Fuel data (D) Type fuel (E)	E Amount per year (F)	F Heat content (G) Btu	G Percent sulfur (G-H)	H Percent ash (coal only) (G-H)
21	138	Wood	1939	Gas Oil Wood	183,000 MCF 1,060 M lb 72,500 M lb.	1,025 / CF 16,800 / lb 8,340 / lb	0.00016 0.6 0.0	
22	138	"	1939		"	"	"	
23	156	Union Iron	1965	Gas Oil				

Source No.	I Air cleaning equipment Type (I)	J Efficiency (J) %	K Estimate of contaminants (M) Type (K)	L Quantity (L)
21	Fly Ash Arrestors	92% Rated	Fly Ash, Sand	17.6 tons/yr.
22	"	"	"	"

Use Additional Sheets If Necessary

SECTION II - REFUSE DISPOSAL

Refuse disposed of X On site and X Off site - Location of disposal site and/or name of hauler: Private Individuals

Normal on-site combustion operating schedule: None Hours per day _____ Days per week _____ Weeks per year _____

Seasonal and/or peak operation period: (Specify) Continuous

	A	B	C	D	E	F	G	H
	Waste material						Estimate of contaminants (M)	
Source No. (A)	Type (N)	Amount per year (F)	Method of disposal (See Code Below)	Incinerator capacity, lb/hr	Auxiliary fuel used (O)	Type and efficiency, air cleaning equipment (I-J)	Type (K)	Quantity per year (L)
24	Paper	913 tons/yr.	City pick up					
25	Rosin	730 tons/yr.	On site landfill					
26	Dirt	34,675 tons/yr.	Off site landfill					

METHOD OF DISPOSAL CODE:

1. Open-burning dump.
2. Sanitary landfill. (No burning)
3. Burned in boiler or furnace.
4. Incinerator, single chamber.
5. Incinerator, multiple chamber
6. Incinerator, rotary.
7. Conical metal burner.
8. Other (Specify)

Use Additional Sheets If Necessary

SECTION III - PROCESS EMISSIONS

Normal operating schedule: 3-8 hr. shifts Hours per day 24 Days per week 7 Weeks per year 52

Seasonal and/or peak operation period: Continuous

NOTE: For intermittent operations, indicate approximate frequency and duration so that estimates of yearly emissions may be obtained.

	A	B	C	D	E	F
Source No. (A)	Processes or operations releasing contaminants to atmosphere (A - P)	Installation Date	Materials processed and/or used at operations: Type (Q)	Materials processed and/or used at operations: Quantity per year (F)	Quantity of gas discharged from process or operation	Type and efficiency air cleaning equipment (I - J)
27	Delnav Manufacture (H_2S by-product)	1961	P_2S_5 Others	490 tons	141.3 tons of SO_2	Flare tower ($H_2S \rightarrow SO_2$)

SECTION III - PROCESS EMISSIONS (Continued)

	G	H	I
Source No. (A)	Estimate of contaminants (M)		Basis of estimate (R) (Please specify basis)
	Type (K)	Quantity per year (L)	
27	SO_2	141.3 tons	Calculated

SECTION IV - STACK DATA

SOURCES VENTED (S)	HEIGHT (Feet)	INSIDE DIAMETER (Feet)	EXIT GAS		
			Temperature of	Velocity (FPS)	Moisture (%)
19,20	200	10	445°F.	10.8	N.A.
21,22	225	10	445°F.	10.8	N.A.
27	100	0.167	N.A.	N.A.	N.A.

Any supplemental material or data considered pertinent (flow diagrams, reports, summaries, test results, maps) should be submitted with this form.

HERCULES, INC.

APP. NO	NAME OF PLANT	MAWPCC DECISION ON COMPLIANCE & PERMITTING
1	Millroom & Extractor House	Appears acceptable but will inspect.
2	Herclor Plant	Appears acceptable, will issue permit to operate.
3	Tall Oil Plant	Appears acceptable, will issue permit to operate.
4	Two Riley-Stoker, Union Iron Works, Type MH Steam Boilers	Appears acceptable, but will inspect. MAWPCC needs notification of standard soot-blowing schedule.
5	Delnav Plant	Will inspect. More engineering review necessary, particularly for SO_2 emissions.
6	Poly-Pale Plant	Will inspect before determining final permit desposition.
7	Liming Unit	Will inspect. Need information on expected future operation.
8	Rosin Shed	Will inspect.
9	Wood Boilers Nos. 1 & 2	Apparently out-of-compliance, need compliance schedule.
10	Wood Boilers Nos. 3 & 4	Apparently out-of-compliance, need compliance schedule.
11	Package Boiler No. 5, Power House	See No. 4 above.
12	Pitch-Blowing Facility	Will inspect. Need more information of frequency & duration of operation.
13	Pulverized Vinsol Mill	Permit decision delayed until future plant operation is determined & proper applications filed, if required.
14	Truline Flaking Belt & Packaging Area	Will inspect.
15	Hard Resins Area	Will inspect.
16	Continuous Esterfication Unit	Appears acceptable, will inspect.
17	Metalyn Unit	Appears acceptable, will inspect.
18	Flaking House-Hard Resins Area	Will inspect.

19	Foral & Staybelite Plant	Appears acceptable, will inspect.
20	Hydrogen Furnace	Appears acceptable, will issue permit to operate.
21	Pilot Plant	JMS Plant too large for permit exclusion, will probably issue short-term permit based on individual project lengths.
22	Resin 731 Unit	ODOR Appears acceptable, will inspect.
23	Stills & Dresinates Facility	ODOR Appears acceptable, will inspect.
24	Kymene Plant	Will inspect. FLU. ONLY
25	Defoamer Plant	Will inspect. [redacted] O.K.
26	Resin Amine D (R.A.D.) Plant	Appears acceptable, will inspect. MAY HAVE NH_3
27	Resin 1977 Plant	Appears acceptable, will inspect. EMN
28	Polyrad & Polyol Unit	Appears acceptable, will issue permit to operate.
29	Para-Cymene Unit	Appears acceptable, will issue permit to operate.
30	Para-Menthane Unit	Appears acceptable, will issue permit to operate.
31	Para-Menthane Hydroperoxide Facility	Will inspect. HAVE BLOWDOWN TANK, PROB. O.K.
32	Sulfate Turpentine Refining Unit	Will inspect. DEF. ODOR
33	Synthetic Pine Oil Facility	Appears acceptable, will issue permit to operate.
34	Column 5-Tall Oil Plant	Appears acceptable, will issue permit to operate.
35	Paracol Plant	Will inspect. PROB O.K.
36	Refuse Disposal	No permit required.

WBA

Air & Water Pollution Control Commission

STATE OF MISSISSIPPI

COMMISSIONERS
Ray Tribble
Chairman
Money
James W. Carraway
Vice Chairman
Bassfield
Board of Health
Joe D. Brown
Marine Conservation
Commission
W. J. Demoran
Charles W. Else
Yazoo City
Game & Fish Commission
Barry Q. Freeman
W. E. Gupton
Jackson

Glen Wood, Jr., Executive Director
P. O. Box 827 - Robert E. Lee Building
Jackson, Mississippi 39205

Telephones:
Administrative Offices 601-354-7513
Air Division 601-354-6783
Water Division 601-354-7661

COMMISSIONERS
Oil & Gas Board
Quincy R. Hodges
Hermit A. Jones
Canton
Board of Water
Commissioners
Jack Pepper

ASSOCIATE MEMBERS
State Park System
Dr. John M. King
A & I Board
Paul Burt
Geological Survey
W. H. Moore

January 3, 1973

Mr. Charles S. Jordan, III.
Hercules, Incorporated
P.O. Box 1937
Hattiesburg, Mississippi 39401

SUBJECT: Status of plants in Hercules complex

Dear Mr. Jordan:

Enclosed is a list of the 35 Hercules Plants showing the preliminary permit decisions that have been made following review of the report by Clark-Dietz & Associates.

Mr. Carey Stark, of this office, will contact you shortly, if he has not done so already, to schedule a visit to your facility. Following his visit we will issue Permits to Operate to all plants that qualify and will notify you of the plants that will require additional control.

If you have any additional questions please do not hesitate to contact us.

Very truly yours,

Wayne B. Anderson
Chief of Engineering
Division of Air Pollution Control

WBA:sb

cc: Jerry M. Stubberfield

John D. Davis, III
Clark Dietz & Associates
201 Barnett Building
Jackson, MS 39201

CLARK, DIETZ, AND ASSOCIATES — ENGINEERS, INC.

Consulting-Engineers

REPLY TO:

201 BARNETT BUILDING
JACKSON, MISSISSIPPI 39201
TELEPHONE 601-948-5948

November 15, 1973

Mr. Jerry M. Stubberfield, Chief
Division of Air Pollution Control
Mississippi Air & Water Pollution Control Commission
Post Office Box 827
Jackson, Mississippi 39205

Re: Hercules Incorporated
Applications for Permit to Operate

Dear Mr. Stubberfield:

Please find enclosed a copy of our Summary Report describing the emissions to the air from the Hercules Incorporated plant at Hattiesburg. This report is submitted by us on the request of Mr. Charles Jordan of Hercules Incorporated.

We hope there will be sufficient detail and description in this report to prove useful in making decisions regarding the granting of the Permits to Operate for the plants which are in compliance with State Regulations. If we may be of service to clarify any detail in the report, please call us at your convenience.

Should you feel we may be of some assistance at the plant site, we may possibly be able to serve in this manner. Any final plans concerning our on-site availability would be coordinated through Mr. Charles Jordan.

Should you have any questions concerning the enclosed report, please feel free to contact us.

Very truly yours,

CLARK, DIETZ & ASSOCIATES-
ENGINEERS, INC.

John D. Davis III, P.E.

JDD/jm

CC: Mr. Charles Jordan
Mr. Frank Gardner
Mr. James Read

HERCULES INCORPORATED

HATTIESBURG, MISSISSIPPI 39401

November 14, 1973

Mr. Jerry Stubblefield, Chief
Division of Air Pollution
Mississippi Air and Water Pollution Control Commission
P. O. Box 827
Jackson, Ms. 39205

Dear Jerry:

Regarding our 'phone conversation on Nov. 6, 1973; I would like to confirm our discussion concerning the status of our air permit applications and the use of the Clark, Dietz air quality summary of our Hattiesburg, Mississippi plant.

I hope we can supply you and your staff with a copy of the report prior to setting up a hearing before the Commission. I hope this would allow you to become more familiar with our Hattiesburg complex. Also, perhaps you, along with John Davis of Clark, Dietz, could visit our plant for a visual observation and discussion of the summary report prior to meeting with the Commission.

I trust this letter will be evidencing fulfillment of the computerized compliance schedule step reminder we received on Oct. 31, 1973, since our ultimate goal is to clarify the unusually difficult and complicated problems for which thirty-six Hercules Hattiesburg Plant applications for Permits to Operate have been submitted.

Very truly yours,

HERCULES INCORPORATED

BY: Charles S Jordan

Charles S. Jordan, III.

CSJ:ccm

584-6411

RECEIVED
NOV 1973
AIR & WATER POLLUTION
CONTROL COMMISSION
STATE OF MISSISSIPPI

HERCULES

- BEFORE ESTAB. INDIV C.S, NEED TO VISIT THE PLANT & VERIFY MINOR AGREEMENT WITH GD OBSERVATIONS.
- ALSO SUGGEST THAT WE GET OPINION AS TO COMPLETION DATE OR "PROOF OF COMPLIANCE" DATE HERCULES CAN MEET.

WRITE NOTE TO FILE THAT "SUMMARY REPORT OF AIR EMISSIONS" BY CLARK, DIETZ UPDATES INTO IN APPLICATIONS. SEVERAL APPLICATIONS ARE INCORRECT.

Notes on inspection by WBA CTS — Hercules Fde- Forrest.

Millroom + Extracter — solvent recycle

no pneumatic, all mech conveyors — ~15% moisture

Fugative dust + Dry weather

ketone MIBK extract + steam

Extract product sep from H_2O + goes to Light + Heavy split.

Light = turpentine etc which goes to still house

Rosin on ground.

Heavy = light + dark rosins

One vent H_2O + Oil scrubber.

Tall Oil - N.E.

Odor here →

Herclor - unsafe + uneconomical - N.E. Syn. Rubber

R.ley Stoker Boilers - N.V.E. Soot blow 2-3 min tid

Poly Pale — Acid Dimerization — common vent 20'x2' scrubber 1" Raching

Liming Unit - No run recently — & nat gas boilers

Heat treat bleach.

Rosin Shed - N.E. — Flake Belt - Little used

in process

Wood Boilers. 1-4 — Package #5

Pitch Blowing — no vent air goes to Fire box

PJ Mill - closed.

Tray Ln. Flds + packaging vent beans installed.

Hercules

Hard Resins - odors removed, not treated
to be corrected - odors, bad sweet, acrid,

Cond. Ester - Vents NE

Metalene - Vents NE

Flake House - ~~Dust to~~ Baghouse Fugative -

Stabelyte - NE except H_2

Fural - NE

H_2 Furnace - ~~NE~~ Combustion Prod.

Pilot Plant -

Dowtherm - 36 boilers - Nat. Gas only.

731 - closed system, vacuum

Presonate - ~~closed system, vacuum~~ Rosin & caustic soap

Disproportionate - uses carbon slurry

Kymene - possible dust, conveyor & bag Filter

Hercules

Paracol –

DeFoamer – Silica [redacted] drying –
dust bag – single bag bag


Terps still – Bad odor – open d. tch.
No odors from vapors?

Dolnar – H_2S flare P_2S_5 – Stink.
Closed process N_2 blanket

Para Menthane – Hydro peroxide – Blow down tank vent

Resin 1977 [redacted] – Hydrogenation over Pd. H_2 purge

Rosanmine – H_2 + NH_3




HATTIESBURG PLANT

HERCULES INCORPORATED

HATTIESBURG, MISSISSIPPI

SCALE - 1" = 600'


N
TO MERIDIAN
PINE BELT REGIONAL AIRPORT 3 MILES
TO MERIDIAN
TO JACKSON
I.C.R.R.
US 49
I-59
RAWLS SPRINGS
GLENDALE
BOWIE R.
LEAF R.
US 11
SOUTHERN R.R.
PETAL
HERCULES
W. 7TH ST.
I.C.R.R.
HARDY ST.
US 98
TO COLUMBIA
CITY LIMITS
PALMER'S CROSSING
US 49
I.C.R.R.
US 11
I-59
TO NEW ORLEANS
TO NEW ORLEANS
US 98
TO MOBILE
TO GULFPORT
HATTIESBURG, MISSISSIPPI
1 0 1
SCALE OF MILES
LEGEND
MOTELS–
1. HOLIDAY INN, NORTH
2. LA GRACE
3. BLUE GABLES
4. RED CARPET INN
5. SOUTHERNAIRE
6. HOLIDAY INN, SOUTH
7. CARRIAGE INN
8. HIWAY HOST
9. WAGON WHEEL
10. RAMADA INN
11. HOWARD JOHNSON
TRANSPORATION–
T1. SOUTHERN R.R. STATION
T2. BUS STATION
T3. MUNICIPAL AIRPORT
SOUTHERN AIRWAYS–
PINEBELT AIRPORT
RECREATION–
R1. KAMPER PARK & ZOO
R2. PINEVIEW PARK
R3. HATTIESBURG COUNTRY CLUB
R4. USM GOLF COURSE
R5. WEST HILLS COUNTRY CLUB
HIGHER EDUCATION–
E1. UNIVERSITY OF SOUTHERN MISSISSIPPI
E2. WILLIAM CAREY COLLEGE

HERCULES

APPROPRIATION REQUEST

FACE SHEET

DATE MARCH 19, 1973 APPROPRIATION NO. 042333

TITLE UTILITIES UTILIZATION AMOUNT $92,000

PLANT HATTIESBURG - EXTRACTOR HOUSE READY FOR USE OCTOBER, 1973

DEPT. ORGANICS PHYSICAL COMPLETION NOVEMBER, 19

FORECAST AMOUNT $98,000 FORECAST GROUP D ASSET PRODUCT CODE 0211

STATE: 1. Why is project needed?
2. What is proposed?
3. How will project pay off?
4. Basis: Profit ☐, Savings ☒, Other ☐

1. The steadily increasing cost of energy has made it imperative that energy be conserved by every economical means.

2. It is proposed to install one new No. 1 crude rosin solution preheater and one new pre-evaporator in the Extractor House to utilize the energy presently lost from condensing extractor stripping steam.

3. This project will pay off by utilizing this energy to increase the concentration of No. 1 crude rosin solution, thus reducing the 90 lb. steam requirements for evaporation at the Refinery. Savings after taxes will amount to $18,754, or a 20.38% return on investment.

Cam RAF CB ucr PBH

Checked in Engineering Department for Form, Accounting Aspects, and Rules Compliance.

DATE

Engineering Department has responsibility in this project. Chief Engineer's approval of engineering adequacy and estimated expenditures is required.

CHIEF ENGINEER DATE

Approved L. T. Zingery 3-20-73
MANAGER DATE

S. Fenelon 5/17/73
DATE

Approved or Authorized Robert J. Leahy 5/24/73
DEPARTMENT HEAD DATE

Authorized by: _____
DATE

Authorized by: Executive Committee
Board of Directors

SECRETARY DATE

Five copies of Appropriation Request to be submitted to Engineering Department

HERCULES

APPROPRIATION REQUEST

REASON SHEET

2

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

STATE: 1. Present facilities.
2. Why they are inadequate.
3. What is proposed under this project.
4. Are all necessary auxiliary and pollution abatement facilities included.
5. To what other capital expenditures will this project commit us.
6. What facilities are to be abandoned, and proposed disposition.

1. Present facilities include one fresh solvent heater and one pre-evaporator which use extractor stripping steam for concentration of No. 1 crude rosin solution and for preheating MIBK. These units use only 60% of the available solvent stripping steam from the extractors.

2. These facilities are inadequate because they do not utilize all the available stripping steam. The No. 1 crude rosin solution is concentrated to approximately 13% in the pre-evaporator, resulting in increased usage of 90 lb. steam at the Refinery.

3. It is proposed that a new No. 1 crude rosin solution preheater and pre-evaporator be installed to utilize the remaining stripping steam to concentrate the No. 1 crude rosin to approximately 30%, thus reducing the usage of 90 lb. steam at the Refinery.

4. All necessary auxiliary and pollution abatement facilities are included in this project.

5. This project will not commit us to any other capital expenditures.

6. No facilities are to be abandoned under this project.

Written by H. M. Macoy Date 3-19-73

HERCULES

APPROPRIATION REQUEST

SAVINGS

3

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

Product Wood Unit Tons

	Unit Cost if Project Is Not Authorized	Unit Cost if Project Is Authorized	Savings Due to Project
Operating Labor	1.846	1.846	-
Repairs Labor	0.186	0.192	(.006)
Maintenance Materials	0.139	0.145	(.006)
Contract Maintenance	0.002	0.002	-
Maintenance Services	0.053	0.053	-
Direct Superintendence	0.282	0.282	-
Chemical Control	0.304	0.304	-
Expense	0.014	0.014	-
Power	3.736	3.570	0.166
Containers	-	-	-
Packaging, Storing & Shipping	-	-	-
Works Accident	-	-	-
Plant Overhead	0.115	0.115	-
Wage Benefits Charged to Cost	0.007	0.007	-
Wages Benefits Charged to Indirect Expense	N/C	N/C	-
Total Operating Cost	6.684	6.516	0.154

Purchased Ingredients	Unit	Quantity	Price	Memo.*			
-							
Internal Ingredients*							
Total Ingredient Cost							
Total Unit Cost, ex Depreciation				(1)			
Total Production (~~1,000 units~~)				(2)	288,365		XXXX
Total Mill Cost, ex Depreciation (~~$1,000~~)				(1 X 2)			44,408
Depreciation Set Aside (~~$1,000~~)				(Normally 7½% of Project Amount)	XXXX	XXXX	6,900

*Internal ingredients to be calculated at sales or market value. Memo. column is to reflect mill cost of internal ingredients. Difference in total net sales or market value of internal ingredients and total mill cost is $_____

Savings Due to Project ($1,000)	37,508
Less Taxes of 50 %	18,754
Savings After Taxes (~~$1,000~~)	18,754
Project Amount (~~$1,000~~)	92,000
Return on Investment (%)	20.38

Written by H. M. McCoy Date 3-19-73

If the project under consideration does not lend itself to a presentation on a unit cost basis please use total dollar expenditures in lieu of unit cost of manufacture.

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

3A

STRIPPING STEAM DATA
EXTRACTOR HOUSE

BTU/Hr. Available - 21,102,500

Equipment Name	Present Usage (BTU/Hr.)	Proposed Usage (BTU/Hr.)
No. 1 Pre-evaporator	7,700,000	5,434,952
No. 2 Pre-evaporator	-	5,623,596
Drop Solution Preheater	-	2,600,000
Solvent Heater	6,140,000	6,140,000
	13,840,000	19,798,548

Increased Usage = 5,958,548 BTU/Hr.

Per cent Utilization of Stripping Steam = 93.3%

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

SUPPLEMENTARY SAVINGS SHEET

Repairs Labor

Present Method

From 12/72 Cost Sheet, R/L = $53,674
Wood Production = 288,365 Tons
Unit Cost = $0.186/Ton

Proposed Method

Estimated Increase in R/L by Percentage of Proposed Material Cost:

$61,949 (new material cost) x 0.03 = $1,858
Proposed R/L = $55,532
Proposed Unit Cost = $0.192/Ton

Maintenance Materials

Present Method

From 12/72 Cost Sheet, M/M = $40,168
Wood Production = 288,365 Tons
Unit Cost = $0.139/Ton

Proposed Method

Estimated Increase in M/M by Percentage of Proposed Material Cost:

$61,949 (new material cost) x 0.03 = $1,858
Proposed M/M = $42,026
Proposed Unit Cost = $0.145/Ton

Power

Present Method

From 12/72 Cost Sheet, Power = $1,077,232
Wood Production = 288,365 Tons
Unit Cost = $3.736/Ton

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

SUPPLEMENTARY SAVINGS SHEET (Cont'd) 3C

Power (Cont'd)

Proposed Method

Estimated power savings based on recovery of 5,958,548 BTU/hr. from extractor stripping steam thus reducing the amount of 90 lb. steam required for evaporation of rosin drop solution.

Heat Recovered = 5,958,548 BTU/Hr.
Heating Value = 886 BTU/Lb. 90 psig Steam
Cost to Manf. = 8,000 Hrs./Yr. (Estimated number of hours excess stripping steam is available)

Therefore, Gross Annual Savings =

5,958,548 BTU/Hr. x 1 lb./886 BTU x 0.00096$/Lb. x 8,000 Hrs./Yr.

= $51,650

By reducing 90 lb. steam usage by 5,958,548 BTU/Hr. or 6,725 Lbs./Hr. the power generation of the steam turbine will be reduced by 597,778 KWH/Yr: Purchase of this power will result in an additional annual cost of $3,826.

Calculations:

6,725 Lbs./Hr. x 8,000 Hrs./Yr. = 53,800,000 Lbs./Yr.

Power Decrease = 53,800,000 Lbs./Yr. ÷ 90 Lbs./KWH
= 597,778 KWH/Yr.

Cost to Purchase = 597,778 KWH/Yr. x $0.0064/KWH
= $3,826

Net Annual Power Savings =

$51,650 - $3,826 = $47,824

Therefore,

Proposed Power Cost = $1,029,408/Yr.
Proposed Unit Cost = 3.570$/Ton

HERCULES

APPROPRIATION REQUEST

ESTIMATE

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	SUMMARY			
	D & M (9911-0)	$	$ 400	$ 400
	Relocation of Facilities -			
	Dismantling Costs (9923-0)		450	450
	Reinstallation Costs (9925-0)	175	650	825
	Extractor House -			
	Foundations (2005-3)	100	250	350
	Building (2005-4)	2,655	2,300	4,955
	Equipment (2005-5)	44,070	2,975	47,045
	Piping (2005-6)	10,710	6,500	17,210
	Electrical (2005-7)	355	150	505
	Instrumentation (2005-8)	2,884	450	3,334
		$60,949	$14,125	$75,074
	Sales & Use Tax (9939-0)			1,000
	E & S (9982-0)			7,608
	10% Contingencies			8,318
				$92,000

Estimated by H. M. Macay Date 3-19-73

I.

HERCULES

APPROPRIATION REQUEST

ESTIMATE

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	D & M (9911-0)			
	Dismantle building siding		$ 400	$ 400
			$ 400	$ 400
	Relocation of Facilities - Dismantling Costs (9923-0)			
	Remove building windows		$ 200	$ 200
	Remove pipe support		100	100
	Remove instrument air piping		150	150
			$ 450	$ 450
	Relocation of Facilities - Reinstallation Costs (9925-0)			
	Reinstall building windows	$ 50	$ 200	$ 250
	Reinstall pipe support	75	250	325
	Reinstall instrument air piping	50	200	250
		$ 175	$ 650	$ 825
	Extractor House - Foundations (2005-3)			
3	Cu. yds. Concrete in place for foundations	$ 100	$ 250	$ 350
		$ 100	$ 250	$ 350
	Extractor House - Building (2005-4)			
6000	Lbs. Structural steel, erected	$ 600	$1,000	$ 1,600
60	Ft. Pipe and fittings for handrails	75	200	275

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Extractor House - Building (2005-4) (Cont'd)			
440	Sq. ft. Grating, cut lengths	$ 1,280	$ 450	$ 1,730
	Building siding	500	400	900
	Building roof	200	250	450
		$ 2,655	$2,300	$ 4,955
	Extractor House - Equipment (2005-5)			
1	2500 sq. ft. Heat exchanger	$38,360	$ 500	$38,860
	Remodel 493 sq. ft. heat exchanger	1,200	1,500	2,700
1	316 S.S. Condensate egg	1,900	300	2,200
1	Whirl-A-Way separator Dyna-Therm Model RLH-150-12, carbon steel shell; 304 S.S. element	1,530	200	1,730
1	Goulds pump Model 3196, 316 S.S., 160 GPM @ 61 ft. head complete with driver	905	100	1,005
	Insulate heat exchangers and condensate egg (1-1/2" thick)	175	375	550
		$44,070	$2,975	$47,045
	Extractor House - Piping (2005-6)			
40	Ft. 8" pipe Sch. 10 T-304L S.S.	$ 613	$	$ 613
40	Ft. 6" pipe Sch. 10 T-304L S.S.	448		448
80	Ft. 2" pipe Sch. 10 T-304L S.S.	348		348
40	Ft. 8" pipe Sch. 40 steel	189		189
80	Ft. 4" pipe Sch. 40 steel	165		165

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Extractor House - Piping (2005-6) (Cont'd)			
	T-304L S.S. fittings Sch. 10	$ 848	$	$ 848
	Carbon steel fittings, Sch. 40	351		351
	150 Lb. Carbon steel S.O. flanges	745		745
1	47" x 24" C.S. 90° reducing ell	700		700
1	8" T-316 S.S. gate valve, flanged	985		985
3	6" T-316 S.S. gate valves, flanged	1,554		1,554
6	2" T-316 S.S. gate valves, flanged	768		768
9	4" Steel gate valves - flanged	1,544		1,544
1	3" Steel gate valves - flanged	147		147
2	1" Steel gate valves - flanged	150		150
3	3/4" Steel gate valves - flanged	180		180
	Pipe hangers and misc. fittings	500		500
	Insulation	475	1,100	1,575
	Piping labor		5,400	5,400
		$10,710	$6,500	$17,210
	Extractor House - Electrical (2005-7)			
1	Size 1 combination starter	$ 220	$	$ 220
1	Pushbutton control station	35		35
	Wire, conduit and fittings	100		100
	Electrical labor		150	150
		$ 355	$ 150	$ 505

Estimated by _____ Date _____

HER. 17155 REV. 7-69

HERCULES

APPROPRIATION REQUEST

ESTIMATE

DATE MARCH 19, 1973 APPROPRIATION NO.

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

ANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Extractor House - Instrumentation (2005-8)			
1	D/P cell transmitter	$ 390	$	$ 390
1	Flow controller	495		495
1	4" C.I. body, 316 S.S. trim, control valve	646		646
1	14" No. 12802 Masoneilan level control	544		544
1	1" C.I. body, 316 S.S. trim, control valve	234		234
1	Orifice plate - 316 S.S.	35		35
1	Pr. 8" - 300 lb. 316 S.S. orifice flanges	300		300
2	Temperature indicators	60		60
1	Pressure gauge 0-60 psig	40		40
1	Pressure gauge 0-20 psig	40		40
	Tubing, fittings and valves	100		100
	Instrumentation labor		450	450
		$ 2,884	$ 450	$ 3,334

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

DISTRIBUTION

DATE May 31, 1973 APPROPRIATION NO. 042 333

TITLE UTILITIES UTILIZATION PLANT HATTIESBURG

CHANGES IN PLANT VALUE

1. Under this project we propose to remove or abandon the following: (Building and/or A & E)			
ACCOUNT 2005			
Building Material		500.	
Building Labor		400.	
		900	
Appraisal Overhead		88.	
			$ 988.
2. Estimated cost to remove, alter, relocate, etc.			
D & M	400.		
Constructi on Overhead	33.		
		433.	
Relocation of Facilities	1,275.		$ 1,815.
Construction Overhead	107.		
3. Totals (Items 1 and 2)		1,382.	$ 2,803.
4. Items to be salvaged			$
5. Values to be charged off (Item 3 less Item 4)			$ 2,803.

DISTRIBUTION OF CHARGES


A—Charge to Expense	$ 1,382.
B—Charge to Depreciation	$ 1,421.
C—Charge to Works Accident	$
Totals A, B, C (Same as Item 5 above)	$ 2,803.
Amount of Appropriation	$ 92,000.
Change in Gross Plant Investment (Asset Product Code 0211, Asset Product Name PRIMARY)	$ 89,197.

JHM

Note: Use "Distribution of Assets by Product" sheet if more than one Asset Product Code is required.

HER 17158 REV 3-70

CHKD BY _____ DATE _____ EATINGTON, NEVADA JOB NO. _____



	E-101		E-102		E-103		S-104	S-105	T-106	T-107	P-
	Pre-Heater		Pre-Evap. #1		Pre-Evap. #2		SPTR.	SPTR.	Egg	Egg	Pu
	Shell	Tubes	Shell	Tubes	Shell	Tubes					
Des. Pr.-PSIG	150	150	150	50	150	150	150	150	150	150	15
Des. Temp.-°F	365	365	365	210	365	365	365	365	365	365	36
Material	316	430	316	430	316L	430	C.S.-S.S.	C.S.-S.S.	316	316	31
Size	24"x10'-7"	493 Ft²	42"x12'	1700 Ft²	47"x12'	2500 Ft²	6'-6"x8'-0"	—	24"x40"	24"x40"	16
BTU/HR	2,600,000		5,434,952		5,520,096		—	—	—	—	-


Note : Piping Not Numbered Is Existing.

Note : The Following Is Existing Equipment : E-102 ; T-106

Key : Rosin-Mixk
Steam-Mixk

042-2005-11055-2HM

B-1



PLAN

SCALE — 1" = 10'-0"

012-2005-21056-1HM-0

BY H.M.MACOY DATE 2-15-73
CHKD. BY ..... DATE .....
SUBJECT UTILITIES UTILIZATION
EXTRACTOR HOUSE
SHEET NO. 1 OF 1
JOB NO. .....

HERCULES

APPROPRIATION REQUEST

FACE SHEET

DATE OCTOBER 13, 1971 APPROPRIATION NO. 042314

TITLE CONDENSATE COLLECTION AMOUNT $46,300

PLANT HATTIESBURG - COMMON READY FOR USE

DEPT. PINE & PAPER CHEMICALS PHYSICAL COMPLETION April, 1972

FORECAST AMOUNT NONE FORECAST GROUP B ASSET PRODUCT CODE 0925

STATE: 1. Why is project needed? 2. What is proposed? 3. How will project pay off? 4. Basis: Profit ☐, Savings ☒, Other ☐

ppc

1. A project is needed because the existing condensate collection system is inadequate.

2. It is proposed that necessary additions to the existing condensate collection system for the main plant area be made, that the collection tank at the Power House be replaced, and that facilities for collecting condensate in the Tall Oil area be installed.

3. This project will pay off by improving feed water quality as well as reducing the water pumping costs and the chemical treatment costs of steam produced at the Power House and at the Tall Oil boilers. It will also reduce fuel costs in the Tall Oil area. Savings after taxes will amount to $23,180, or a 50.1% return. This project will also increase the total capacity of the Tall Oil boilers.

R.S.George 10/29

Checked in Engineering Department for Form, Accounting Aspects, and Rules Compliance.
F. B. Kendall 10/19/71
DATE

Engineering Department has no responsibility in this project. Chief Engineer's approval of engineering adequacy and estimated expenditures is not required.
D. H. Little 10/21/71
CHIEF ENGINEER DATE

Approved D D Kingery 10-15-71
MANAGER DATE

E. L. Jones 11/1/71 DATE
Approved or Authorized
DEPARTMENT HEAD DATE

Authorized by:
DATE

Authorized by: Executive Committee Board of Directors
SECRETARY DATE

Five copies of Appropriation Request ...

November 4, 1971

ASSIGNED PROJECT ACCOUNTS

TITLE: CONDENSATE COLLECTION PROJECT NUMBER: 042 314

PLANT: HATTIESBURG DEPARTMENT: P. & P. C.

*700-042314-2044-3 - PROCESS BUILDING - POLY PALE - FOUNDATIONS

5 - - EQUIPMENT

6 - - PIPING

7 - - ELECTRICAL

8 - - INSTRUMENTATION

8502-3 - BOILER HOUSE - INCLUDING FUEL BIN - FOUNDATIONS

4 - - BUILDING

5 - - EQUIPMENT

6 - - PIPING

8 - - INSTRUMENTATIOI

8505-8 - BOILER HOUSE - TALL OIL - INSTRUMENTATION

8701-6 - O. S. STEAM LINES - PIPING

9911-0 - D. & M.

9923-0 - RELOCATION OF FACILITIES - DISMANTLING COSTS

9925-0 - RELOCATION OF FACILITIES - REINSTALLATION COSTS

9939-0 - SALES AND USE TAXES

9982-0 - E. & S. (Plant)

*MLCO codes, as described in Engineering Department Notice 5.1.4, are to be used in conjunction with the assigned Project Account Codes.

HERCULES

APPROPRIATION REQUEST

REASON SHEET

042314

2

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

STATE: 1. Present facilities.
2. Why they are inadequate.
3. What is proposed under this project.
4. Are all necessary auxiliary and pollution abatement facilities included.
5. To what other capital expenditures will this project commit us.
6. What facilities are to be abandoned, and proposed disposition.

1. Present facilities: Present facilities include area condensate headers and three main return headers which return condensate to a collection tank at the Power House and many area headers which dump condensate to the uncontaminated sewer system. The existing arrangement returns only enough condensate to form 38.3% of the feedwater to the Power House boilers and does not return any condensate to the Tall Oil boilers.

2. Why they are inadequate: These facilities are inadequate because lost condensate increases fuel costs, maintenance costs, chemical treatment cost, and water pumping costs. The Power House boiler feedwater could be up to 60% condensate; the Tall Oil boilers can use all of the returnable condensate. The arrangement of the Power House collection tank and feedwater pumps is such that the feedwater temperature must be limited to 200° F. This collection tank has deteriorated to the point that it is not suitable for the proposed modifications.

3. What is proposed under this project: It is proposed that (a) new return headers be installed in the main plant area between the collection tank and area headers in order to obtain 58% condensate in the feedwater, (b) the Tall Oil condensate header be tied into the deaerator to return all available condensate, (c) the Power House collection tank be replaced with a new elevated tank, (d) the Power House feedwater pumps be relocated, and (e) ultraviolet organic monitors be installed in the Tall Oil and Power House condensate systems to warn of contamination.

4. Are all necessary auxiliary and pollution abatement facilities included: All necessary auxiliary and pollution abatement facilities are included.

5. To what other capital expenditures will this project commit us: This project will not commit us to any other capital expenditures.

6. What facilities are to be abandoned, and proposed disposition: The existing collection tank will be removed and scrapped.

5167
1971
EIVED

Written by W A Mason Date 10/13/71

042314

CONDENSATE RETURN DATA
(LB./HR.)

Area	Condensate Now Returned	To Be Returned After Project	Increase Due To Project
Main Plant:			
Extractor	1,450	13,500	12,050
Pexite	24,000	24,000	-
Refinery	17,500	17,500	-
Still House	15,500	15,500	-
Poly-pale	10,500	13,500	3,000
Terpene Derivatives	16,400	16,400	-
Power House	9,800	9,800	-
731	-	9,500	9,500
Paste Size Tanks	-	9,500	9,500
Staybelite	-	6,400	6,400
Hard Resins	-	7,200	7,200
Rosin Shed	5,700	5,700	-
Poly-pale Tracks	-	4,500	4,500
Foral	-	2,300	2,300
Terpin Hydrate	-	1,250	1,250
Totals	100,850	156,550	55,700
% Recovered*	38.3%	59.4%	21.1%
Tall Oil:	-	21,210	21,210
% Recovered**	0%	25.8%	25.8%

Notes: * Per cent of Power House Gross Steam Production
** Per cent of Tall Oil Boilers Useful Steam Production

HERCULES

APPROPRIATION REQUEST

SAVINGS

042314

3

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

Product Steam Unit Million Pounds

	Unit Cost if Project Is Not Authorized	Unit Cost if Project Is Authorized	Savings Due to Project
Operating Labor	57.22	57.22	-
Repairs Labor	31.41	31.45	(.04)
Maintenance Materials	16.53	16.75	(.22)
Contract Maintenance	1.57	1.57	-
Maintenance Services .36 (R/L + R/M)	11.40	11.49	(.09)
Direct Superintendence	5.79	5.79	-
Chemical Control	.94	.94	-
Expense	2.06	2.06	-
Power	29.72	31.01	(1.29)
Containers			
Packaging, Storing & Shipping			
Works Accident			
Plant Overhead	3.24	3.24	-
Wage Benefits Charged to Cost	11.39	11.39	-
Wages Benefits Charged to Indirect Expense	-	-	-
Total Operating Cost	171.27	172.91	(1.64)

Purchased Ingredients	Unit	Quantity	Price	Memo.*			
Water Treatment Chem.					12.04	8.32	3.72
Sulphuric Acid	#	23.6/17.1	.014		.33	.24	.09
Natural Gas	MCF	583.97	.3868		225.88	225.88	-
#5 Fuel Oil	Gal.	315.0/143.2	.08723		27.48	12.49	14.99
Internal Ingredients*							
Spent Chips Burned	Ton	153.97	1.86		286.36	286.36	-
By Products Burned	1000#	11.69	6.70		78.32	78.32	-
Light Ends Burned	"	.113	6.70		.76	.76	-
Total Ingredient Cost					631.17	612.37	18.80
Total Unit Cost, ex Depreciation				(1)	802.44	785.28	17.16
Total Production (~~1,000 units~~)				(2)	2904	2904	XXXX
Total Mill Cost, ex Depreciation ($1,000)				(1X2)	2,330,286	2,280,453	49,833
Depreciation Set Aside ($1,000)				(Normally 7½% of Project Amount)	XXXX	XXXX	3,473

*Internal ingredients to be calculated at sales or market value. Memo. column is to reflect mill cost of internal ingredients. Difference in total net sales or market value of internal ingredients and total mill cost is $_____

Savings Due to Project (~~$1,000~~)x	$46,360
Less Taxes of 50 %	23,180
Savings After Taxes (~~$1,000~~)x	23,180
Project Amount (~~$1,000~~)x	46,300
Return on Investment (%)	50.1%
Cash Flow	$26,653

Written by W B Mason Date 10/13/71

If the project under consideration does not lend itself to a presentation on a unit cost basis please use total dollar expenditures in lieu of unit cost of manufacture.

SUPPLEMENTARY SAVINGS SHEET

0423

Product: Steam
Unit: Million Pounds

	Unit Cost (#/Unit)					
	Tall Oil			Power House		
	Current	After Project	Savings	Current	After Project	Savings
Operating Labor	51.28	51.28		59.18	59.18	
Repairs Labor	10.88	11.03	(.15)	38.19	38.19	
Maintenance Materials	12.36	12.51	(.15)	17.91	18.15	(.24
Contract Maintenance				2.09	2.09	
Maintenance Services	3.96	4.06	(.10)	13.85	13.94	(.09
Direct Superintendence	5.77	5.77		5.80	5.80	
Chemical Control	3.80	3.80				
Expense	2.62	2.62		1.87	1.87	
Power	30.10	35.96	(5.86)	29.59	29.37	.22
Overhead	13.06	13.06				
Wage Benefits	8.38	8.40	(.02)	12.38	12.38	
Total Operating Cost	142.21	148.49	(6.28)	180.86	180.97	(.11
Treatment Chemicals	22.96	17.04	5.92	8.44	5.44	3.00
Sulphuric Acid	1.34	.99	.35			
Natural Gas	230.09	233.06	(2.97)	224.49	223.51	.98
#5 Fuel Oil (Note 1)		(4.58)	4.58			
#5 Fuel Oil	110.68	54.90	55.78			
Spent Chip Value				380.90	380.90	
By Products Burned	286.80	286.80		9.50	9.50	
Light Ends Burned	3.05	3.05				
Total Ingredient Cost	654.92	591.26	63.66	623.33	619.35	3.98
Total Unit Cost	797.13	739.75	57.38	804.19	800.32	3.87
Production (Units/Year)	721	721		2183	2183	
Savings (Note 2)			40,210			9,623

Notes:

1. The #5 Fuel Oil savings of $4.58/MM# steam shown in the Tall Oil column is separate as it is the result of reduced natural gas usage at the Power House. The natural gas saved will be used in the Tall Oil boilers, thus reducing fuel oil usage.

2. The total savings figures are $/year, and the fuel oil savings explained in Note 1. have been credited to the Power House.

3. Individual returns for each area are 349% at Tall Oil and 8.1% at the Power House, after depreciation and taxes.

SUPPLEMENTARY SAVINGS SHEET

04227

Tall Oil Steam Data (#/Hr.)

Gross Production		96,772
Used in Boilers*		14,516
Net Useful Production		82,256
To Main Plant	25,741	
Lost to Process	30,000	
Other Losses	5,305	
Unreturnable Condensate	61,046	61,046
Net Condensate Available		21,210

* The steam used in the boilers is the sum of three flows:

1. Steam to turbine pump drives which exhausts to the deaerator at 5 psig.
2. Purge steam to the deaerator at 300 psig.
3. Purge steam to the preheater at 300 psig.

At the above flow rates, the horsepower required by the booster and feed pumps equals 99.6 HP. From the turbine performance curves, the steam input equals 5600#/hr.

The feedwater at the deaerator is at 210° F. From heat balance calculations, the purge steam to the deaerator equals 5656#/hr.

The steam flow to the preheater then equals 3260#/hr. by mass balance.

With return of 21,210#/hr. of condensate and the use of electric drives in the pumps, the following changes occur:

1. Exhaust steam flow decreased by 5600#/hr.
2. Purge steam flow increased by X#/hr.
3. Feedwater flow decreased by (5600 - X) #/hr.
4. Make-up water flow decreased by 21,210#/hr.

Heat balance calculations show that X = -89#/hr.

Summary

Flow Stream	Heat Content BTU/#	Flow #/Hr. W/O Condensate	Flow #/Hr. With Condensate
Feedwater at 210° F.	178.06	96,772	91,083
Preheater Purge Steam	1203.5	3,260	3,260
Deaerator Purge Steam	1203.5	5,656	5,567
Exhaust Steam	1156.1	5,600	0
Condensate	310.56	0	21,210
Make-up Water	48.02	82,256	61,046
Useful Steam	1203.5	82,256	82,256

Recovered Heat = 21,210 (310.56 - 48.02)
= 5,568,500 BTU/hr.
= 67.7 BTU/# of Useful Steam

SUPPLEMENTARY SAVINGS SHEET

042311

Savings - Tall Oil

The recovered heat will reduce fuel consumption (specifically #5 fuel oil) required to produce the same amount of useful steam.

Overall boiler efficiency	=	.7562
#5 Fuel oil heat content	=	140,000 BTU/gallon
Fuel oil saved	=	$\frac{67.7 \text{ BTU/\# useful steam}}{.7562 \times 140{,}000 \text{ BTU/gallon}} \times 10^6$
	=	639.5 gallons/MM# useful steam
Fuel oil cost	=	$.08723/gallon
Fuel savings	=	$55.78/MM pounds of useful steam

The reduction of make-up water flow will reduce the chemical treatment cost, the sulphuric acid cost and the water pumping power cost which is contained in the Power cost.

Chemical savings	=	$22.96/MM\# $\times \frac{21{,}210\text{\#/hr.}}{82{,}256\text{\#/hr.}}$	=	$5.92/MM#
Sulphuric savings	=	$1.34/MM\# $\times \frac{21{,}210\text{\#/hr.}}{82{,}256\text{\#/hr.}}$	=	$ .35/MM#
Power savings	=	$1.039/MM\# $\times \frac{21{,}210\text{\#/hr.}}{82{,}256\text{\#/hr.}}$	=	$ .27/MM#

The use of the electric drives on the booster and feed pumps will increase power costs at the flow rates with condensate return, required horsepower = 97.7.

$$\text{Cost} = \frac{97.7 \text{ HP} \times .7457 \text{ KW/HP} \times \$.006926/\text{KWH}}{82{,}256\text{\#/hr.} \times 10^{-6} \text{MM\#/\#}} = \$6.13/\text{MM\#}$$

Power House Steam Data (#/Hr.)

Gross Production*	263,261
Used in Boilers*	14,057
Net Useful Production*	249,204
Condensate Now Returned	100,850
Make-up Flow	148,354
Condensate to be Returned	55,700
Make-up Flow After Project	92,654

* These figures will not change with this project and no fuel savings will be realized as the heat added by the increase of condensate will result in reduced usage of exhaust steam from the steam driven air compressors.

Savings resulting from the reduced make-up water flow are as follows:

Chemical treatment savings	=	$8.00/MM\# $\times \frac{55{,}700}{148{,}354}$
	=	$3.00/MM#
Power savings	=	$1.039/MM\# $\times \frac{55{,}700}{249{,}204}$
	=	$.22/MM#

042314

Miscellaneous Savings in Power House

The use of more condensate and less make-up in the feed to the boilers can reasonably be expected to improve performance and reduce maintenance due to the poor quality of the make-up water.

Expected savings and average costs are:

Savings Due To:	Labor	Material	Fuel
a) One less tube failure/year of #5 boiler	$165	$ 55	$ 406*
b) One less tube failure/year in each wood burning boiler	222	10	36**
c) Two less shutdowns/year of a boiler to clean the economizer	288	60	18**
d) A 2% increase in economizer efficiency	____	____	1,680
Totals	$675	$125	$2,140

* Cost based upon burning more natural gas in the wood burning boilers at a lower efficiency to make up lost production and extra fuel for heat up.

** Extra fuel required for heat up.

Cost of Pumping Raw Water

Raw water must be pumped by both river pumps and service water pumps.

$$BHP = \frac{(Q\ GPM)\ (H\ Ft.)\ (S.G.)}{3960\ (E)}$$

For river pumps: H avg. = 180' and E avg. = 80%
For service pumps: H avg. = 142' and E avg. = 82%

Let Q = 2.0006 GPM = 1000#/hr.

$$BHP = \frac{2.0006 \times 180 \times 1}{3960 \times .80} + \frac{2.0006 \times 142 \times 1}{3960 \times .82}$$

$$= .1137 + .0875 = .2012\ HP/1000\#$$

Cost = .2012 HP/1000#/hr. x .7457 KW/HP x $.006926/KWH

= $.001039/1000#

= $1.039/MM#

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	SUMMARY			
	D & M (9911-0)	$	$ 500	$ 500
	Relocation of Facilities -			
	Dismantling (9923-0)		520	520
	Reinstallation (9925-0)	140	1,060	1,200
	Poly-pale Process Building -			
	Foundations (2044-3)	40	80	120
	Equipment (2044-5)	1,150	110	1,260
	Piping (2044-6)	330	320	650
	Electrical (2044-7)	290	60	350
	Instrumentation (2044-8)	1,250	170	1,420
	Boiler House -			
	Foundations (8502-3)	80	160	240
	Building (8502-4)	200	400	600
	Equipment (8502-5)	6,780	720	7,500
	Piping (8502-6)	2,600	1,800	4,400
	Instrumentation (8502-8)	3,790	800	4,590
	Tall Oil Boiler House - Instrumentation (8505-8)	2,860	640	3,500
	Outside Steam Lines - Piping (8701-6)	5,640	5,300	10,940
	Sales & Use Tax (9939-0)	500		500
		$25,650	$12,640	$38,290

Estimated by WBT/wm Date 10/13/71

I.

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	SUMMARY (Cont'd)			
	E & S (9982-0)	$25,650	$12,640	$38,290
	10% Contingencies			3,820
				4,190
				$46,300

Estimated by W B Mason Date 10/13/71

II.

F. 17155 20M 3-65 13866
PRINTED IN U.S.A.

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	D & M (9911-0)			
	Remove hot well tank and foundation		$ 500	$ 500
			$ 500	$ 500
	Relocation of Facilities - Dismantling (9923-0)			
	Remove hot well tank instrumentation		$ 40	$ 40
	Remove four existing pumps		160	160
	Disconnect and dismantle piping to hot well tank		320	320
			$ 520	$ 520
	Relocation of Facilities - Reinstallation (9925-0)			
	Reinstall hot well tank instrumentation	$ 10	$ 60	$ 70
	Pour new foundations and reinstall four pumps	120	600	720
	Rework and reinstall usable valves and sections of pipe in piping to new condensate tank	10	400	410
		$ 140	$1,060	$ 1,200
	Poly-pale Process Building - Foundations (2044-3)			
1	Cu. yd. Concrete in place for foundations	$ 40	$ 80	$ 120
		$ 40	$ 80	$ 120
	Poly-pale Process Building - Equipment (2044-5)			
1	Centrifugal pump, steel casing, stainless steel impeller w/1 HP motor	$ 600	$ 50	$ 650

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Poly-pale Process Building - Equipment (2044-5) (Cont'd)			
1	100 Gallon steel condensate receiver	$ 550	$ 60	$ 610
		$ 1,150	$ 110	$ 1,260
	Poly-pale Process Building - Piping (2044-6)			
100	Ft. 2" Sch. 40 carbon steel pipe w/fittings and flanges	$ 110	$	$ 110
40	Ft. 1" Sch. 40 carbon steel pipe w/fittings and flanges	40		40
1	2", 200# Screwed carbon steel gate valve	50		50
5	1", 200# Screwed carbon steel gate valves	110		110
	Misc. piping materials	20		20
	Piping labor		320	320
		$ 330	$ 320	$ 650
	Poly-pale Process Building - Electrical (2044-7)			
1	Size 1 combination starter	$ 220	$ 20	$ 240
	Pushbutton, wire, conduit and fittings	70	40	110
		$ 290	$ 60	$ 350
	Poly-pale Process Building - Instrumentation (2044-8)			
1	Masoneilan Model 12803 level controller	$ 760	$ 60	$ 820

Estimated by _____ Date _____

NER. 17155 20M 3-65 13866
PRINTED IN U.S.A.

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Poly-pale Process Building - Instrumentation (2044-8) (Cont'd)			
1	1" Annin Model 2660 control valve, C.S.	$ 450	$ 30	$ 480
	Misc. tubing fittings and supports	40	80	120
		$ 1,250	$ 170	$ 1,420
	Boiler House - Foundations (8502-3)			
1.5	Cu. yds. Concrete in place for tank support foundation	$ 60	$ 120	$ 180
.5	Cu. yd. Concrete in place for separator foundation	20	40	60
		$ 80	$ 160	$ 240
	Boiler House - Building (8502-4)			
2000	Lbs. Steel, erected, for tank support	$ 200	$ 400	$ 600
		$ 200	$ 400	$ 600
	Boiler House - Equipment (8502-5)			
1	7500 Gallon, 10' dia. x 12' carbon steel tank with dished heads	$ 6,200	$ 400	$ 6,600
1	Tangential steam/condensate separator fabricated from 8" and 12" carbon steel pipe	300	200	500
1	12" x 12' long pipe for tank vent with 4" flanged water inlet at center and internal distribution plates	280	120	400
		$ 6,780	$ 720	$ 7,500

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Boiler House - Piping (8502-6)			
200	Ft. Carbon steel pipe, various sizes, for condensate tank inlet and outlet lines and condensate dump line	$ 520	$	$ 520
	Carbon steel weld fittings and slip-on flanges	580		580
5	4", 150# Flanged carbon steel gate valves	840		840
2	3", 150# Flanged carbon steel gate valves	300		300
1	6", 150# flange insert check valves, C.S.	100		100
2	4", 150# flange insert check valves, C.S.	120		120
2	3", 150# flange insert check valves, C.S.	90		90
	Misc. piping materials and welding supplies	50		50
	Piping labor		1,800	1,800
		$ 2,600	$1,800	$ 4,400
	Boiler House - Instrumentation (8502-8)			
1	Model 130 Aqualert detection system	$ 1,500	$	$ 1,500
4	ASCO 8315C2, 3-way solenoid valves	380		380
4	Constant flow purgemeters	280		280
4	Strainers	50		50
1	Sample cooler	80		80
1	Rotameter	120		120
1	Bimetal thermometer	30		30

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Boiler House - Instrumentation (8502-8) (Cont'd)			
1	Flow switch	$ 80	$	$ 80
1	Temperature switch	20		20
1	Stepping switch	50		50
2	Time delay relays	70		70
4	Alarm relays	50		50
1	Hoffman NEMA 4 enclosure	40		40
1	BETA 8-point alarm annunciator	500		500
	Armored gage glass for tank	320		320
	Sample piping	100		100
	Misc. wire and conduit	120		120
	Instrumentation labor		800	800
		$ 3,790	$ 800	$ 4,590
	Tall Oil - Boiler House - Instrumentation (8505-8)			
1	Model 130 Aqualert detection system	$ 1,500	$	$ 1,500
1	Constant flow purgemeter	70		70
1	Strainer	10		10
1	Sample cooler	80		80
1	Rotameter	120		120
1	Bimetal thermometer	30		30

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

042314

DATE OCTOBER 13, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Tall Oil - Boiler House - Instrumentation (8505-8) (Cont'd)			
1	Flow switch	$ 80	$	$ 80
1	Temperature switch	20		20
1	Clearview 4-point alarm unit	240		240
2	Ramcon valve actuators w/solenoid pilots	380		380
1	Selector switch	30		30
1	Power supply for alarms	120		120
	Misc. wire and conduit	120		120
	Sample piping	60		60
	Instrument labor		640	640
		$ 2,860	$ 640	$ 3,500
	Outside Steam Lines - Piping (8701-6)			
160	Ft. 4" Sch. 40 carbon steel pipe	$ 260	$	$ 260
1240	Ft. 3" Sch. 40 carbon steel pipe	1,260		1,260
840	Ft. 2" Sch. 40 carbon steel pipe	570		570
100	Ft. 1" Sch. 40 carbon steel pipe	40		40
	3" and 4" Sch. 40 carbon steel weld fittings and 150# flanges	640		640
	1" and 2" Forged steel screwed fittings and unions	380		380
1	4", 150# flanged carbon steel gate valve	170		170

Estimated by _____ Date _____

HERCULES

APPROPRIATION REQUEST

ESTIMATE

DATE OCTOBER 13, 1971 APPROPRIATION NO. 042314

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

QUANTITY	DESCRIPTION	MATERIAL	LABOR	TOTAL
	Outside Steam Lines - Piping (8701-6) (Cont'd)			
6	3", 150# Flanged carbon steel gate valves	$ 880	$	$ 880
11	2", 200# Screwed carbon steel gate valves	550		550
2	1", 200# Screwed carbon steel gate valves	50		50
	Misc. piping materials and welding supplies	200		200
	Piping labor		4,800	4,800
160	Ft. 4" Sch. 40 carbon steel pipe	260		260
	4" Weld fittings and flanges	120		120
2	4" Carbon steel butterfly valves w/stainless shaft and disc	260		260
	Piping labor		500	500
		$ 5,640	$5,300	$10,940

Estimated by _____ Date _____

ER. 17155 20M 3-65 13866

HERCULES

APPROPRIATION REQUEST

DISTRIBUTION

042314

DATE OCTOBER 19, 1971 APPROPRIATION NO.

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

CHANGES IN PLANT VALUE

1. Under this project we propose to remove or abandon the following: (Building and/or A & E)

Account 9100			
Unit #1973 - Tank, Steel. Hot Well. 7x26. Acq-47. Scrap.		$1,293.	
Equipment, Labor		198.	
		$1,491.	
Appraisal Overhead		167.	
			$ 1,658.

2. Estimated cost to remove, alter, relocate, etc.

D & M	$500.		
Construction Overhead	100.	$ 600.	
Relocation of Facilities	$1,720.		
Construction Overhead	344.	2,064.	$ 2,664.

3. Totals (Items 1 and 2)	$ 4,322.
4. Items to be salvaged	$
5. Values to be charged off (Item 3 less Item 4)	$ 4,322.

DISTRIBUTION OF CHARGES

A—Charge to Expense	$ 2,064.
B—Charge to Depreciation	$ 2,258.
C—Charge to Works Accident	$
Totals A, B, C (Same as Item 5 above)	$ 4,322.
Amount of Appropriation	$46,300.
Change in Gross Plant Investment (Asset Product Code / Asset Product Name)	$41,978.

Note: Use "Distribution of Assets by Product" sheet if more than one Asset Product Code is required.

WEC/elp

HERCULES

APPROPRIATION REQUEST

DISTRIBUTION OF ASSETS BY PRODUCT

42314

DATE NOVEMBER 2, 1971 APPROPRIATION NO. ~~042312~~

TITLE CONDENSATE COLLECTION PLANT HATTIESBURG

ASSET PRODUCT CODE	ASSET PRODUCT NAME	AMOUNT	% OF TOTAL
0217	Poly-Pale	$ 4,948.	10.7
0925	Power	27,107.	58.5
0950	Common	14,245.	30.8
	TOTAL CHANGE IN GROSS INVESTMENT	$46,300.	100.0%

Notes: This form to be used only when more than one asset product code is required.

If project contains more than ten asset product codes, minor value products should be accumulated and coded to Asset Product Code 975, "Reclassified Assets."

RPC/elp

196

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft²/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL 10^6 (BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	HAND CALCULATED EMISSIONS (tons/year) SO_2	HAND CALCULATED EMISSIONS (tons/year) CO	HAND CALCULATED EMISSIONS (tons/year) HC	HAND CALCULATED EMISSIONS (tons/year) NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private 1; Local 2; State 3; Federal 4; Utilities 5.
(c) Type → Process 1; Fuel Combustion 2; Solid Waste Disposal 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

7

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL 10^6 (BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	SO_2	CO	HC	NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP. (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
3	0	0	5	2	8	1	9											A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL 10^6 (BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																	B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	SO_2	CO	HC	NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

POINT SOURCE DATA FORM

APCO (DUR) 193
3/71

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
10	2	0	5	0	1			2	3	1	1	8760	100					A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal./year)	(d) EF	DISTILLATE OIL (10^3 Gal./year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
10				15														B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	HAND CALCULATED EMISSIONS (tons/year) SO_2	HAND CALCULATED EMISSIONS (tons/year) CO	HAND CALCULATED EMISSIONS (tons/year) HC	HAND CALCULATED EMISSIONS (tons/year) NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
10											11.3						C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	SO_2	CO	HC	NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP. (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	HAND CALCULATED EMISSIONS (tons/year) SO_2	HAND CALCULATED EMISSIONS (tons/year) CO	HAND CALCULATED EMISSIONS (tons/year) HC	HAND CALCULATED EMISSIONS (tons/year) NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

POINT SOURCE DATA FORM

APCO (DUR) 193
3/71

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
1 2 3	4 5 6	7 8 9	10 11 12	13 14	15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30	31 32 33 34 35 36	37 38 39 40 41 42	43	44	45	46 47 48 49	50 51 52	53 54 55	56 57 58	59 60 61	62 63 64 65 66	67 68 69 70	A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
1 2 3	4 5 6 7 8 9 10 11 12 13 14 15	16 17 18 19 20 21 22 23 24 25 26 27	28 29 30 31 32 33 34 35 36 37 38 39	40 41 42 43 44 45	46	47 48 49 50 51 52	53	54 55 56 57 58 59	60	61 62 63 64 65 66	67	68 69 70 71 72 73	74 75 76 77 78 79	80 81 82 83 84 85	86 87 88 89 90 91	92 93 94 95 96 97	B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	HAND CALCULATED EMISSIONS (tons/year) SO_2	HAND CALCULATED EMISSIONS (tons/year) CO	HAND CALCULATED EMISSIONS (tons/year) HC	HAND CALCULATED EMISSIONS (tons/year) NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
1 2 3	4 5 6	7 8 9	10 11 12	13 14 15	16 17 18	19 20 21	22 23 24	25 26 27	28 29 30 31 32 33 34 35 36 37 38 39	40 41 42 43 44 45	46 47 48 49 50 51	52 53 54 55 56 57	58 59 60 61 62 63	64 65 66 67 68 69	70 71 72 73 74 75	76 77 78 79 80 81	82 83 84 85 86 87	C

SOURCE NUMBER	COMMENTS (a)	
1 2 3	4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79	80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft²/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	SO_2	CO	HC	NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP. (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^2/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	HAND CALCULATED EMISSIONS (tons/year) SO_2	HAND CALCULATED EMISSIONS (tons/year) CO	HAND CALCULATED EMISSIONS (tons/year) HC	HAND CALCULATED EMISSIONS (tons/year) NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

APCO (DUR) 193
3/71

POINT SOURCE DATA FORM

SOURCE NUMBER	REGION	SIC	SITE	PROCESS CODE	DESCRIPTIVE NAME (a)	COORDINATES KM X	COORDINATES KM Y	POLITICAL JURISDICTION	OWNER (b)	TYPE (c)	OPERATING (hours/year)	STACK PARAMETERS HEIGHT (ft.)	STACK PARAMETERS DIA. (ft.)	STACK PARAMETERS TEMP (°F)	STACK PARAMETERS VELOCITY (ft/sec)	MAXIMUM GAS VELOCITY (ACFM)	PLUME RISE (ft^7/sec)	
																		A

SOURCE NUMBER	MAXIMUM PROCESS WEIGHT RATE (lb/hr)	NORMAL PROCESS WEIGHT RATE (lb/hr)	COMMENTS (a)	MAXIMUM BOILER CAPACITY (10^6 BTU/hr)	(d) EF	COAL (tons/year)	(d) EF	RESIDUAL OIL (10^3 Gal/year)	(d) EF	DISTILLATE OIL (10^3 Gal/year)	(d) EF	NATURAL GAS (10^6 CF/year)	HEAT CONTENT COAL (10^6 BTU/ton)	HEAT CONTENT RESIDUAL OIL (10^3 BTU/Gal.)	HEAT CONTENT DIST. OIL (10^3 BTU/Gal.)	HEAT CONTENT NATURAL GAS (BTU/CF)	
																		B

SOURCE NUMBER	% ASH COAL	SULFUR CONTENT COAL	SULFUR CONTENT RESID.	SULFUR CONTENT DIST.	SULFUR CONTENT NAT. GAS	CONTROL EFFICIENCY PART	CONTROL EFFICIENCY SO_2	DEVICE INDENT	COMMENTS (a)	HAND CALCULATED EMISSIONS (tons/year) PART.	SO_2	CO	HC	NO_2	ALLOWABLE EMISSIONS PART	ALLOWABLE EMISSIONS SO_2	
																	C

SOURCE NUMBER	COMMENTS (a)	
		D

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(a) Letters and numbers may be put in these columns
(b) Owner → Private = 1; Local = 2; State = 3; Federal = 4; Utilities = 5.
(c) Type → Process = 1; Fuel Combustion = 2; Solid Waste Disposal = 3.
(d) EF → refers to emission factor set number associated with emission factors on emission factor sheet.

All decimal points are implied and are signified by a ▼ between columns.

HERCULES (BOILERS), HATTIESBURG (TSP/SO2), 1-14-1977

METEOROLOGICAL INPUT DATA FOR THE ANNUAL SEASON

MIXING DEPTH = 1000. METERS
AMBIENT TEMPERATURE = 289. DEGREES,KELVIN
AMBIENT PRESSURE = 1013. MILLIBARS

STABILITY CLASS 1

	WINDSPEED CLASS					
WIND DIRECTION	1	2	3	4	5	6
N	0.0002	0.0004	0.0	0.0	0.0	0.0
NNE	0.0002	0.0007	0.0	0.0	0.0	0.0
NE	0.0001	0.0	0.0	0.0	0.0	0.0
ENE	0.0002	0.0003	0.0	0.0	0.0	0.0
E	0.0001	0.0001	0.0	0.0	0.0	0.0
ESE	0.0001	0.0004	0.0	0.0	0.0	0.0
SE	0.0001	0.0001	0.0	0.0	0.0	0.0
SSE	0.0001	0.0002	0.0	0.0	0.0	0.0
S	0.0000	0.0002	0.0	0.0	0.0	0.0
SSW	0.0001	0.0003	0.0	0.0	0.0	0.0
SW	0.0001	0.0003	0.0	0.0	0.0	0.0
WSW	0.0000	0.0001	0.0	0.0	0.0	0.0
W	0.0001	0.0008	0.0	0.0	0.0	0.0
WNW	0.0001	0.0004	0.0	0.0	0.0	0.0
NW	0.0000	0.0001	0.0	0.0	0.0	0.0
NNW	0.0002	0.0006	0.0	0.0	0.0	0.0

HERCULES (BOILERS), HATTIESBURG (TSP/SO2), 1-14-1977 DEC

SOURCE DATA

SOURCE NUMBER	SOURCE LOCATION (KILOMETERS)		SOURCE AREA SQUARE	ANNUAL SOURCE EMISSION RATE (TONS/DAY)		STACK DATA			
	HORIZONTAL	VERTICAL	KILOMETERS	SO2	PART	HT (M)	DIAM (M)	VEL (M/SEC)	TEMP (DEG.K)
1	7.5	7.5	0.0	0.302	0.640	61.0	1.4	17.7	466.

HERCULES (BOILERS), HATTIESBURG (TSP/SO2), 1-14-1977 DEC

SOURCE CONTRIBUTIONS TO FIVE MAXIMUM RECEPTORS

ANNUAL SO2

MICROGRAMS PER CUBIC METER

SOURCE	RECEPTOR 131	RECEPTOR 116	RECEPTOR 126	RECEPTOR 132	RECEPTOR 130
1	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
	0.0965	0.0918	0.0915	0.0875	0.0871
BACK-GROUND	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %
	0.	0.	0.	0.	0.
TOTAL	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %
	0.0965	0.0918	0.0915	0.0875	0.0871

HERCULES (BOILERS), HATTIESBURG (TSP/SO2), 1-14-1977 DEC

SOURCE CONTRIBUTIONS TO FIVE MAXIMUM RECEPTORS

ANNUAL PARTICULATES

MICROGRAMS PER CUBIC METER

SOURCE	RECEPTOR 131	RECEPTOR 116	RECEPTOR 126	RECEPTOR 132	RECEPTOR 130
1	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
	0.2045	0.1945	0.1940	0.1854	0.1847
BACK-GROUND	0.0 %	0.0 %	0.0 %	0.0 %	0.0 %
	0.	0.	0.	0.	0.
TOTAL	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %
	0.2045	0.1945	0.1940	0.1854	0.1847

AVERAGE CONCENTRATIONS FOR 12 HOURS.

RECEPTOR NUMBERS

1.	2.	3.	4.	5.	6.	7.	8.
0.001	0.045	0.338	0.484	0.538	0.538	0.717	0.483

TOTAL CONCENTRATION (MG/M**3)

11. 180. 1.0 5 425. 292.0 1019.0

* * * * R E C E P T O R N U M B E R S * * * *

1. 2. 3. 4. 5. 6. 7. 8.

TOTAL CONCENTRATION (UG/M**3)

0.000 0.016 0.365 0.884 1.277 1.483 1.577 1.605

* * * * I N T E G R A T I O N * * * *

12. 180. 1.0 6 425. 292.0 1019.0

* * * * R E C E P T O R N U M B E R S * * * *

1. 2. 3. 4. 5. 6. 7. 8.

TOTAL CONCENTRATION (UG/M**3)

0.0 0.000 0.001 0.019 0.069 0.150 0.248 0.343

STOCK FORM NO 6481 - 1 SAVE

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.000	0.016	0.345	0.884	1.277	1.461	1.577	1.605

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
6.	180.	1.9	6	1450.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.0	0.060	0.001	0.015	0.060	0.114	0.2**	0.***

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
7.	180.	1.9	1	425.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
4.144	2.135	1.366	1.019	0.820	0.686	0.607	0.528

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
8.	180.	2.8	2	425.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
1.111	2.582	1.222	0.838	0.663	0.554	0.488	0.424

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
9.	180.	2.8	3	425.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.218	3.178	1.952	1.209	0.819	0.607	0.487	0.416

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
10.	180.	4.8	4	425.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.000	1.243	1.***	1.***	1.***	1.***	1.***	0.***

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)

HERCULES INC. HATTIESBURG (SO2), 1-14-1977 DEC

3.

* * * S O U R C E S * * *

NO.	Q (G/SEC)	HS (M)	TS (DEG-K)	VS (M/SEC)	DS (M)	VE (M**3/SEC)	B (KM)	E (KM)
1.	1.60	61.0	466.0	17.7	1.40	0.0	7.500	6.500

* * * R E C E P T O R S * * *

NO.	XREC (KM)	YREC (KM)	Z (M)
1.	7.500	8.000	2.0
2.	7.500	9.000	2.0
3.	7.500	10.000	2.0
4.	7.500	11.000	2.0
5.	7.500	12.000	2.0
6.	7.500	13.000	2.0
7.	7.500	14.000	2.0
8.	7.500	15.000	2.0

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
1.	180.	1.9	1	1450.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.194	0.706	0.480	0.299	0.240	0.203	0.175	0.154

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
2.	180.	2.8	2	1450.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
1.111	2.582	1.146	0.619	0.384	0.261	0.190	0.147

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
3.	180.	3.8	3	1450.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.218	3.178	1.452	1.208	0.811	0.591	0.437	0.341

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
4.	180.	4.8	4	1450.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)							
0.000	1.268	1.890	1.755	1.499	1.247	1.078	0.921

* * * M E T E O R O L O G Y * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)

11.	180.	1.4	5	425.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.

TOTAL CONCENTRATION (UG/M**3)

0.000	0.405	8.103	22.319	32.256	37.402	39.829	40.419

* * * R E C E P T O R D A T A * * *

NO.	THETA(DEG)	U (M/SEC)	KST	HE (M)	T (DEG-K)	P (MB)
12.	180.	1.9	6	425.	292.0	1018.0

* * * R E C E P T O R N U M B E R * * *

1.	2.	3.	4.	5.	6.	7.	8.

TOTAL CONCENTRATION (UG/M**3)

0.0	0.000	0.034	0.452	1.748	3.775	6.256	8.670

| | | |

HERCULES INC. PATTERSON (TSP). 1-14-1977 DEC

*** SOURCE ***

NO.	Q (G/SEC)	HB (M)	TS (DEG-K)	VS (M/SEC)	D(M)	VE(M**3/SEC)	R (KM)	S (KM)
1.	40.40	61.0	466.0	17.7	1.40	0.0	7.500	7.500

*** APPLIERS ***

NO.	XREC(KM)	SREC(KM)	Z (M)
1.	7.500	8.000	2.0
2.	7.500	9.000	2.0
3.	7.500	10.000	2.0
4.	7.500	11.000	2.0
5.	7.500	12.000	2.0
6.	7.500	13.000	2.0
7.	7.500	14.000	2.0
8.	7.500	15.000	2.0

*** METEOROLOGY ***

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
1.	180.	1.9	1	1450.	292.0	1018.0

	1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)	105.907	17.787	10.107	7.542	6.067	5.102	4.419	3.905

*** METEOROLOGY ***

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
2.	180.	2.8	2	1450.	292.0	1018.0

*** RECEPTOR NUMBER ***

	1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)	28.049	65.188	28.939	15.640	9.707	6.595	4.803	3.723

*** METEOROLOGY ***

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
3.	180.	3.8	3	1450.	292.0	1018.0

*** RECEPTOR NUMBER ***

	1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)	5.499	80.249	49.281	30.508	20.474	14.668	11.036	8.519

*** METEOROLOGY ***

NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
4.	180.	4.8	4	1450.	292.0	1018.0


*** RECEPTOR NUMBER ***


	1.	2.	3.	4.	5.	6.	7.	8.
TOTAL CONCENTRATION (UG/M**3)	0.807	42.024	47.715	44.410	37.444	31.996	27.224	23.402


*** METEOROLOGY ***


NO.	THETA(DEG)	U (M/SEC)	KST	HL (M)	T (DEG-K)	P (MB)
5.	180.	1.9	5	1450.	292.0	1018.0

1.	2.	3.	4.	5.	6.	7.	8.
INITIAL CONCENTRATION (UG/ML**3)							
0.015	1.642	8.244	12.464	13.580	13.534	14.043	12.454





ENLARGED SECTION
TUBES STAGGERED AS SHOWN
REMOTE WALL BLOWN TREE LINE
BOILER ROOM FLOOR EL. 9'-0"
BOILER ROOM FLOOR EL.
ENLARGED






CROSS SECTION - FOR BOILER

NO 4291 W




PROJ. NO.	DATE	REVISIONS	REVISED BY	CHECKED BY	APPROVED BY





RETAINING WALL

Nozzles Not Existing



Existing Overfire Nozzles

NO.	TITLE
62983-W	GENERAL ARRGT. ELEVATIONS
62984-W	GENERAL ARRGT. PLANS
63017-W	DUCTWORK DETAILS
63018-W	DUCTWORK DETAILS

REFERENCE DRAWINGS

THIS PRINT IS THE PROPERTY OF HERCULES POWDER COMPANY AND IS LOANED UPON THE UNDERSTANDING THAT IT WILL NOT BE COPIED, TRACED OR REPRODUCED IN ANY MANNER WHATSOEVER. RETURN OF PRINT MUST BE MADE TO HERCULES POWDER COMPANY.

PLANT HATTIESBURG

BLD'G BOILER HOUSE

BOILERS No 1-2 & 4

ALTERATIONS TO INCREASE CAPACITY & EFFICIENCY

GENERAL ARRANGEMENT

CROSS SECTION

SCALE 1/2" = 1'-0" DATE 8-18-48

DRAWN BY N.G.LIND

CHECKED BY [illegible]

APPROVAL [illegible]

APPROVAL [illegible]

APPROVALS

HERCULES POWDER CO.


WILMINGTON, DELAWARE

BLD'G NO. 11

PROJECT 1831

DRAWING NO. 62917-W

No. 62917-W



NO.	TITLE
62983-W	DUCTWORK - DETAILS
62983-W	DUCTWORK - DETAILS
62984-W	GENERAL ARRGT - PLANS
62983-W	GENERAL ARRGT - ELEVATIONS

REFERENCE DRAWINGS

THIS PRINT IS THE PROPERTY OF HERCULES POWDER COMPANY AND IS LOANED UPON THE UNDERSTANDING THAT IT WILL NOT BE COPIED, TRACED OR REPRODUCED IN ANY MANNER WHATSOEVER. RETURN OF PRINT MUST BE MADE TO HERCULES POWDER COMPANY.

PLANT HATTIESBURG
BLD'G BOILER HOUSE
BOILERS NO 1-2 & 4
ALTERATIONS TO INCREASE CAPACITY & EFFICIENCY
GENERAL ARRANGEMENT
CROSS SECTION

SCALE 1/2" = 1'-0" DATE 8-18-48
DRAWN BY N.G.LIND
CHECKED BY ✓
APPROVAL
APPROVAL
APPROVALS

HERCULES POWDER CO.
WILMINGTON, DELAWARE

BLD'G NO. 11
PROJECT 12824
DRAWING NO. 62917-W