

MISSISSIPPI STATE DEPARTMENT OF HEALTH <sup>2016</sup> MAY 31 AM 11:29  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2015

City of Grenada

Public Water Supply Name

0220003-0220004-0220005-0220007-0220036-0220062  
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 05/16/2016 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: 05/16/2016

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_\_/\_\_\_\_/\_\_\_\_

- As a URL (Provide URL \_\_\_\_\_)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_/\_\_\_\_/\_\_\_\_ 116 South Main St

CCR was posted in public places. *(Attach list of locations)* Date Posted: 05/15/2016

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

\_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Billy J. Collier-Mayson  
Name/Title (President, Mayor, Owner, etc.)

May 26 2016  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:

**CCR Due to MSDH & Customers by July 1, 2016!**

water.reports@msdh.ms.gov

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Wilcox, Middle Wilcox and Lower Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Grenada have received lower to higher susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Dale Ratliff at 662-227-3415. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at 6:00 PM at City Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#:0220003		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2014*	.5	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

13. Chromium	N	2014*	9.4	8.7 - 9.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.19	.176 - .19	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2014*	5.5	4.2 - 5.5	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

### Disinfection By-Products

81. HAA5	N	2015	7	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2015	14.06	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1.1	1 - 1.2	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 220062		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2014*	.0104	.0043 - .0104	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	5.3	4.8 - 5.3	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.132	.127 - .132	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
82. TTHM [Total trihalomethanes]	N	2014*	2.64	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1.2	1 - 1.3	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of Grenada works around the clock to provide top quality water to every tap. We have four certified operators on staff, who would be pleased to answer any and all customer questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

10. Barium	N	2014*	.176	.076 – .176	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	5.6	4 – 5.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/16	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.157	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

81. HAA5	N	2014*	9	1 - 9	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	6.53	.5 – 6.53	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1	.70- 1.60	ppm	0	MDRL = 4	Water additive used to control microbes

### Unregulated Contaminants

Strontium	N	2013*	.507	.194-.507	UG/L	0.3	MRL 0.3	Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formerly used in medicines and as a germicide
-----------	---	-------	------	-----------	------	-----	---------	--

**PWS ID#: 220004**

### TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	-------------------	------	-----	--------------------------------

### Inorganic Contaminants

10. Barium	N	2014*	.0195	.0148- .0195	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	7.4	6.7 – 7.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.172	.143 – 1.72	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

81. HAA5	N	2014*	13	10 - 13	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	4.49	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1.2	1 – 1.3	ppm	0	MDRL = 4	Water additive used to control microbes

**PWS ID#: 220005**

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2014*	.0268	.0258 - .0268	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	1.2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
Chlorine	N	2015	1.1	1 - 1.3	ppm	0	MDRL = 4	Water additive used to control microbes

**PWS ID#: 220007**

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2014*	1	.6 - 1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014*	.0295	.0282 - .0295	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	10.8	7.1 - 10.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.231	.223 - .231	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2014*	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	6.51	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1	8 - 1.1	ppm	0	MDRL = 4	Water additive used to control microbes

**PWS ID#: 220036**

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2014*	1.5	1.2 - 1.5	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014*	.0264	.0208 - .0264	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits



RECEIVED - WATER SUPPLY  
*City of Grenada*  
 2016 MAY 31 AM 11:29

116 Main St.  
 Grenada, Mississippi 38901

ROBERT EUGENE MARTIN  
 380 BELL ST  
 GRENADA, MS 38901

DAYS OF OPERATION MON-FRI 8:00 AM- 5:00 PM  
 PHONE: 662-227-3400  
 FAX: 662-226-0561  
 AFTER HOURS/EMERGENCIES: 662-227-3415  
 QUESTIONS: WATERBILLING@CITYOFGRENADA.MS

ACCOUNT NUMBER	12040681
BILLING DATE	05/16/16
PREVIOUS BILL	\$29.15
PAYMENTS	\$0.00
BALANCE FORWARD	\$29.15
CURRENT CHARGES	\$24.15
<b>TOTAL DUE</b>	<b>\$53.30</b>
<b>DATE DUE</b>	<b>05/31/16</b>
<b>AMOUNT DUE IF PAID AFTER DUE DATE</b> Includes \$5.00 Penalty	<b>\$58.30</b>
<b>CUT OFF DATE</b> Account subject to disconnection and \$35 Admin Fee	<b>06/07/2016</b>

SERVICE ADDRESS		380 BELL ST		
SERVICE	PREVIOUS READING	CURRENT READING	READ DATE	CONSUMPTION
WATER	35460	36400	05/10/2016	940

DETAIL OF CHARGES	
SERVICE PERIOD	AMOUNT
04/13 - 05/10	
WATER	\$6.65
SEWER	\$4.50
GARBAGE	\$13.00
<b>TOTAL CURRENT CHARGES</b>	<b>\$24.15</b>

**IMPORTANT INFORMATION**

**FAILURE TO RECEIVE THE BILL DOES NOT EXCUSE SERVICE DISCONNECTION**

**PAYMENT OPTIONS**

- BY MAIL (ONLY SEND CHECK OR MONEY ORDER)
- AFTER HOURS BOX LOCATED AT CITY HALL (ONLY CHECK OR MONEY ORDER - DO NOT PAY IN CASH). CITY IS NOT RESPONSIBLE FOR LOST CASH. PAYMENTS ARE APPLIED TO YOUR ACCOUNT THE NEXT BUSINESS DAY.

**IMPORTANT MESSAGE**

Visit us on the web at – [www.cityofgrenada.ms](http://www.cityofgrenada.ms)

PLEASE DETACH AND RETURN BOTTOM PORTION IF PAYING BY MAIL. PLEASE DO NOT STAPLE OR FOLD. PLEASE WRITE YOUR ACCOUNT NUMBER ON YOUR CHECK. TO BETTER ASSIST YOU, PLEASE BRING YOUR COMPLETE BILL WHEN PAYING IN PERSON.

Check here for E-Billing Form on Reverse side



116 Main St.  
 Grenada, Mississippi 38901

RETURN SERVICE REQUESTED



245 1 AV 0.376

Robert Eugene Martin  
 380 Bell St  
 Grenada MS 38901-3004

BILL DATE	ACCOUNT NUMBER	DATE DUE
05/16/16	12040681	05/31/16
PREVIOUS BALANCE	BALANCE FORWARD	TOTAL DUE
\$29.15	\$29.15	\$53.30
<b>AMOUNT DUE IF PAID AFTER DUE DATE</b> Includes \$5.00 Penalty		<b>\$58.30</b>
<b>CUT OFF DATE</b> Account subject to disconnection and \$35 Admin Fee		<b>06/07/2016</b>

Amount Enclosed \$ \_\_\_\_\_

Please remit and make checks in US funds payable to:

**CITY OF GRENADA - WATER DEPT**  
**116 MAIN ST**  
**GRENADA MS 38901-2622**

