

Installation of Anodes for UST tanks

To install anodes to repair tank cathodic protection, you **MUST** be following the direction of a qualified corrosion expert, unless you can prove you are following applicable guidelines for repair. If the corrosion expert is not on site directing the activities, the contractor must have a technician or installer license in order to add the anodes. (Only exception to this would be if corrosion expert provides documentation that he will be responsible for any damage done by the unlicensed contractor.) If the corrosion expert is on site directing activities, then no license is required. If anodes are added improperly (such as performing the work without utilizing a corrosion expert), then the contractor may be fined and/or restricted from performing future repairs and/or cathodic protection tests.



Mike Pigford

3/5/19