UST Compliance Manager Training



Mississippi Department of Environmental Quality www.mdeq.ms.gov

Underground Storage Tank (UST) System



Why are we here?

In 2005 when EPA established the Energy Act which required such things as Secondary Containment and Delivery Prohibition



It also required Operator Training In 2018 MDEQ adopted new regulations required by the EPA.

This course is designed to bring you the most up to date information.

Topics

- Who is responsible?
- Timeline for repairs
- Financial Responsibility
- Notification Requirements
- Release Reporting
- What to do after release reported.
- Record Keeping
- Types of USTs:
 - Permanent Closure Requirements
 - Temporary Closure Requirements
 - Currently In Use (active) Requirements
 - Spill Buckets
 - Overfill Devices
 - Monthly Walk-through inspections

- Release (Leak) Detection
 - Types & typical reports
- Recap of testing required by leak detection method
- Recap of monthly reports required by leak detection method
- Types of Piping
- Requirements for Pressurized pipes
 - Line Leak Detectors
 - Shear Valves
- Release Prevention
 - Cathodic Protection
 - Product Compatibility
- UST Emergency Response
- UST Operations Clerk Training

What is Operator Training?

It is a program designed to ensure there are knowledgeable people working at each UST facility that understand operating and maintaining UST systems



Different Levels of Operator Training

- <u>Compliance Manager</u> a person having daily on-site responsibility for the operation and maintenance of UST systems.
 - Usually manages paperwork.
 - Trains store clerks.
 - Notifies the tank owner of issues.
- <u>UST Operations Clerk</u> a person on-duty at a service station that has the primary responsibility for operating the dispensers
 - Responds to emergencies.
 - Monitoring system for alarms
 - Minor cleanup

You can be both the Compliance Manager & Operations Clerk at your store.

How do you get trained?

Compliance Manager

- MDEQ Class with examination
- Third Party Course

Operations Clerk

- Trained by the Compliance Manager
- On-line training courses

Why is it important?



Petroleum products and gas are dangerous!

And your customers can be even more dangerous



Need to know what to do & how to respond.





- What else is there?
- MDEQ requirements for Compliance.
- If you're NOT compliant MDEQ can:
 - Can issue penalties of up to \$25,000 per day.
 - Can place your tanks on delivery prohibition (no fuel deliveries)
 - May not reimburse you with Trust Fund monies for cleanup of leaks.

Who is responsible for the tanks?

The Tank Owner

The Tank Owner

The Tank Owner

This includes all aspects of:

- Notification to MDEQ
- Leak Detection
- Making sure required testing is done.
- Making sure repairs are made in a timely manner.
- Paying tank fees.

Can it not be the tank owner responsible?

 For MDEQ, the tank owner is Ultimately responsible to ensure that leasee or compliance manager or operator of facilities maintain compliance.

NO

 If you do lease stores, require documents from lease to be submitted monthly to you to ensure requirements are met.

Could other parties be liable? (property owner, store clerk, fuel suppliers)

Yes

A few tips for compliance....

- Check your mail and email.
- Update mailing address if needed.
- Stay In contact with us.
- Each letter has a contact name or email.
- Call and email the person on letter.
- Follow instructions on letters.
- Keep good records...
 - Get them from your contractor quickly
 - Keep copies in a safe place

 Pay attention in this class. You need to know what to do.



What is your UST contractor responsible for?

- Licensure
- Install & test per manufacturer requirements
- Notification to tank owner

Required to notify the tank owner when failures occur in writing. Maybe..

- on Invoice
- actual test results
- just a piece of paper.
- this form
- From there it is TANK OWNERS responsibility to report to MDEQ and address failures.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY Notification of UST System Failures to Tank Owner

	UST Facility		Person Identifying Failures
Faidthy Mix	me MORO Fa	cRay ID #	interior's Name
Physical A	ATTON		dame of Societaranan
Metho	d of Notification: Onsite Facility Staff	T Em	all 🗆 Mail 🗆 Fax 🗆 Other:
	Onsite Facility	Staff Re	ceiving Notification
NAME	SIGNATURE (Not Required)	report to	reiving this notification I was notified of the need to provide the the current "Responsible Party" of this facility <u>IMMEDIATELY</u> .
Failed	Specialty Tests	1	Specify Issue
121	Precision Tank Tightness Test	1	
(-12)	Precision Line Tightness Test		
10	Tank Secondary Integrity Text	18	
60	Pipe Secondary Integrity Test		
10	Secondary Containment Sump Integrity Test		
10	Cathodic Protection Test		
10	60 day Rectifier Log	1	
10	Temporarily Out of Use Tanks Impection		
(0)	UST System Compatibility Inspection	1	
10	Soil Sampling Results		
10	Other:	1	
	Annual Tests		Specify Issue
100	Spill Bucket integrity Test		
10	Overfill Device Inspection	1	
10	Shear (Impact) Valve Test	6	
19	Line Leak Detector Test		
[[]]	Autometic Tank Gauge Inspection	10	
10	Secondary Containment Sump Impection		
	Interstitial Sensor Test	1	12 14 12
M	onthly Monitoring for Leak Detection	12	Specify Issue
1.12	Manitoring Well results		
10	ATG 0.2 gph leak test results (tank)	1	
	Electronic LLD 0.2 gph leak test results (pipe)		
10	Visual Interstitial Monitoring Results		
14	Electronic Interstitial Monitoring Results		
1	Monthly Waik Through Inspection	12	Specify Issue
101	Spill Bucket Impection		
	Overfil Prevention (Fill Pipe) Impection		
1.12	Others		

PO BOX 2281, JACKSON, NS, 39225; PHONE (601) 961-5171; FAX (601) 961-5030; www.mdeg.ma.gov 5/201

What is timeframe for repairs?

90 days for failed annual tests.

90 days for failed cathodic protection or sump integrity tests
 **No need to report these to MDEQ if they can be repaired & retested in 90 days.
 If you see, you'll exceed 90 days please email <u>wmccain@mdeq.ms.gov</u> to report.
 Should you exceed this timeframe without reporting you can expect a penalty.

Immediate action is needed for:

- Leaks (Suspected or Confirmed)
- Failed or Inconclusive Tank or Line Tightness tests
 **Need to report to MDEQ within 24 hours of discovery.

When your contractor does work at your facility you need to ensure payment, get paperwork, report and begin repairs as needed.

Why is compliance important to you?

The main reason is:

Financial Responsibility

Required for all tank owners by federal regulation for the operation of petroleum Underground Storage Tanks.

Each Facility must have insurance for:
\$1,500,000 for cleanup activities
\$1,000,000 for third party damages

Ways to meet

 Pollution Insurance Self Insurance (\$10 million company) Guarantee Surety Bond Irrevocable Letter of Credit Trust Fund

The Mississippi Groundwater Protection (Trust Fund)

Is the most common resource used for financial responsibility.

- no deductible for the tank owner
- no premiums to be paid by the tank owner
- requires substantial compliance with all UST regulations

for the Trust Fund

UST owners that have made a <u>good faith</u> effort to comply with the UST regulations are eligible for the Trust Fund

- Proper registration of USTs
- Pay tank fees
- Maintain compliance with regulations

This is why you want to be in compliance with UST regulations.

It is free insurance for cleanup of leaks as long as you try to do the right thing.

MDEQ can deny you access to use the fund. You may be liable for millions in cleanup costs should a leak occur.

Notification Requirements

- Installation of New UST Equipment
- Change of Equipment
 - Temporary Closure
 - Type of product stored
- Change of Ownership
- Repair or Replacement of Equipment
- Permanent Closure of USTs
- Suspected or Confirmed Releases



Initial Notification: Installation of New Equipment

- Must notify at least
 prior to installing any new
 - Tank
 - Pipe
 - Dispenser
 - Submersible Pump

 "Notice of planned UST system modification / installation" form.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY NOTICE OF PLANNED UST SYSTEM MODIFICATION / INSTALLATION

This form must be submitted to MDEQ 30 days prior to beginning any planned installation of a tank, pipe, submersible pump or dispenser that is part of an underground storage tank (UST) system.

Repairs and or modifications to existing UST systems that occur as a result of some unforeseen event (e.g. an accident or storm damage) do not require that this form be submitted before the repairs can be conducted.

UST Facility			MDEQ Certified UST Installer				
Facility Mone		MDEO Facility (D.#	UST knobelier's Name	MORO	Certification		
Physical Addams			Company	1			
City	Courte	State	City	State			
		MS					
UST Owner			UST Indeler's Signature	Contra .			
Date(s) of Planne	d installation:		•				
	Planned US	ST System Modifie	cation / Installation		Gecondary Curtaining Required		
New tanks; pi	oing, submersible pu	mps, dispensers at a r	www.facility (indicate number of n	ew tanks)	YES		
New tanks ad	ded to an existing fai	citity (indicate number	of new tanks)	21-226	YES 1		
New tanks at a	an existing facility to	replace existing tanks	(indicate number of new tanks		YES 1		
New piping at	existing facility to re-	place existing piping (complete repipe from the tank to	the dispensers)	YES '		
New piping added at an existing facility to extend existing piping (new dispenser islands added)							
New piping at	an existing facility to	partially replace (repa	iir) existing piping		NO ¹		
New dispense	New dispensers to replace existing dispensers (existing piping modified)						
New dispense	rs to replace existing	dispensers (existing p	sping not modified)	8	NO 3		
New submers	ble pumps to replac	e existing STP's (exist	ing piping modified)	13	YES '		
New submers	bile pumps to replac	e existing STP's (exist	ing piping not modified)	piping not modified)			
Cther (specify)				2		
 All new tai installed w musit be si meet the s If an exist meet the s If you are the piping flex come 	Ns. pipes, dispense here previously there conductly contained ing piping system is in econdary containme able to install a new components, you an ctors, ells, tees, unic	rs and submersible pur e was none or are repl	mps installed on or after October acting an existing tank, pipe, disp ntly a portion of the existing pipin ble pump to replace an existing of containment sumps. Piping con valves that routinely contain prod	1, 2008, whether senser or submers ig, the piping does one without chang roonents include a luct.	they are able pump not have ing any of all piping.		
	ACA STORATS INTERNET	NEX20220000000200		2510			
Comments							

PO BOX 2261 JACKSON, MS 38225 PHONE (601) 961-5171 PAX (601) 961-5083 http:// www.deg.state.ms.us 1

After Install: Installation of New Equipment

 New equipment must be registered with MDEQ within of bringing the UST system into use

 "Notification of Underground Storage Tanks" Form

MS	Return Completed Form To:	Mississippi Dept. of Environmental Quality eted Office of Pollution Control – UST Branch P.O. Box 2261 Jackson, MS 39225					de une arky) d:
This law		ted and a finished with	Instru	ctions	NAME OF TAXABLE		
 Type or 	print in ink all item	in "except" Signafure" in	Sections VII and	prig an underspound alonage IX.	ans (up) in	O LUHE	
 Complet 	a each section of	this form that applies to	the type of notife	cation you are automitting.			
			L Type of L	JS1 Facility			
C Retail	13 Industrial	D Federal Military	D Federal No	n-Military 🖸 Statis Gov	wroment	Local Gov	Inemment
CI Chilly	Li ram		SLI Tryacke (man	aponer D Other (spe	acity)	*	
Owner Marine	II. Owne	rship of Tanks		III. LO	ocation of	Lanks.	MERCIE North
and a state of				Designed and the second se			
and second				A Charles interest in 10 year lot at			
Cat		3584	Zip Costs	City (revenue) If rick within city layers)	-	MC	U CHM
						mo	
Pearle		Fau	10 D	Course	Plane	5 - 258	
E-mail		7.0		Faat Braid (RP, Taxon, Shell, Mc.)	i 02 0	Nutlicate Total	
						Murshaw of LEVTs at	
	15.7	Contrate		11 T.	an of black	Transformer,	
Each facility	is recurred to have	a laned UST Comp	stance Manager	V. 19	DE OL NUM	incarron)	
Class A/B C	Operator) Includ	te the UST Compliance	e Menager and	New UST facility			
UST Compliance	Marger			New USTs added to an e	konating facility		
M				CI New USTa	II replace	e axisting US	STa
ML. Phase		Small		New piping	D replace	e existing pip	ang.
				D New dispensets	II replace	e existing de	pensets
Officer Property				C New autometable pumps	C replace	e existing pu	mpa
ME				New spill buckets	II replace	e existing ap	èl buckete
Les.				New overfit prevention	🗆 replace	e existing ov	erfill prevents
Phille		Seat		Change in tank status (o	omplete Numb	er 1 of Section	on VIII only)
				D Other (specify)			
l		VI.	Financial	Responsibility			
Select a met	word growing how	you have met the finance	cial suporability	requiriments in accordance	with UST-2 Su	apart H	
D State True	it Fund (motor fue	i tanka only) 🛛 🕄	Self Insurance	Private Insurance	🖽 Gammer	tee or Sunst	ly Bonid
		VII. Certificat	IOD (Read and	sign after completing all s	ections.)		
i certify under	r penalty of law th	at I have personally exe d three technologies	errined and are fa	mikar with the information sut	terretitied in this :	and all attact	hed document
ta brue, accur	ale, and complete	n andere mannatalen sinna L	manny response	and an operating the monthle	ort, resiliers th	at the suppli	
Name and Title of	A TRU OPPRE GROWING	printe.	Signature	ef UST Owner		. 1	use Started
Annu -						-	

Change in Equipment

Must be reported to the MDEQ within of the change of UST equipment

Use "Notification of Underground Storage Tanks" Form



What is a change in equipment?

- When you start or stop using a tank it should be registered as either:
 - Temporarily out of use
 - Currently in use
- Change of product or grade of fuel stored
 - greater than 20% biodiesel
 - greater than 10% ethanol

Repairs or replacements that occur due to an emergency situation

Initial Notification: Permanent Closure

The tank owner must submit

" Form at least 30 days prior to the scheduled tank closure

to Permanent M

To Jack	on. MS 38225-	2261			Date Roc	erved by MEIE	a		
Co	mplete and re	tum thia	form within the	rty (30) days	prior to perm	nationity dos	aing tank sy	abant.	
I, Los	cation of Tan	k System	1			II. Owners!	hip of Tank	System	
Name				Nor	10				
Address'				4.00	inese .				
Plate 20.	1122	106		-		122	2222	12	_
City	CDL	rity		City.		- 3	tate:	ZPI	_
		HL D	ate of Sche	duled Ten	k System C	losure			
Month:		_ (Day:			Year			
WEIGHT 2		-31				1.21	2. <u></u>		
	IV. Type	e of Pe	rmanent C	losure					
Tank & Plong Ramoval			Tire & Pe	ins Claure	n Place		Type o	Changes in P	100
Tank Removal Only	11		Tank Close	in Place	Cheby -	[02]	Rand		1
Pieros flamoval Only			Pipen Cla	tare in Place	Only _	1501	Concrete	. S	11-
. and restored and		-	1 the distance				Virgin Dri	ing Mud -	
W8 any new undergrou	nd Tanka -	-	Piping -	be	installect at t	his tacility?	Approved	"loan"	1
	٧.	Underg	ground Sto	rage Tani	k System	Informatio	10		
1									
Plate of	Tank	. 1	2	3	4	5	8	2	-
Te	reatiseation.		4	-	1		-	1	-
	gasoine		1	-	10	1	1	1	
Substance stored Incoughout history of the tank (check all that apply)	diesei			1	1		1	1	1
	used oil	_		1		1. C	-	+	-
	kerceane		3	2	12		12		1
	other	-	S	21	8		2	10	6
	0.00000 -21		in an	Seco	200 - 100	22	0.1	200	10.
			VI. Con	tractor inf	ormation				
Name of Company Pe	arforming Cio	sure:							
Name of Induktion Pr	welling buckli	ED to E	Anna anantha	Cines 1977	26				
Married Individual Ca	Contractory with	ALL BY	Sermanentry	CRUME DO 1	·	alasta R			
Mississippi DEQ US I	Centrication	Numbe	n <u></u>	_	E	xpiration UV	ate:	_	_
			VII. Sam	pling Req	uirements				
All controlleds must be	nardormad in	annet	State with the	Medicala	Departme	at of Easter	dimental C	hinlin/e Ory	ioroi
Storage Tank Guidelin	nes for the P	ermaner	tt Clesure of	Petroleum	Undergrou	nd Storage	Tanks.	Autory's Crit	aci (ji
		_							
Product Store	d in Lank	100	Solin	Modial Convertient	101	BTEX	(EPA Mot	be Parform	82
Conjular Malanda Con Co	10000000		COULD I	Contraction		DALLA	free or might	to Date over 10	a stati
Waste Oil, Diesi	s, Kerdsene		Soil 0	r Gloundwi	nar	PAHIER	A MILTIO	IS 8100, 82	nuc,
Other than	above		Soli a	r Groundwa	ner	Cont	act Office	of Pollution	Con
e New york and a second			VIII. C	Owner Agre	ement	The second		and the	
Oath: I certify that the	e information	listed at	bove is true	and correct	to the best	of by belief	and know	nedge.	

Final Notification: Permanent Closure

- <u>The tank owner</u> must submit:
 - Closure Report
 - sample results

within 60 days of completing the UST Closure

 If all appears well, MDEQ will issue a final "no further action" needed letter.

Completed Off Form PO	Ice of Pollution Cont Max 2265	not	Fa	cility LD de Riece	2 No.	٥			
Loca	tion of Tank Sys	tem	110		Ownership	of Tank S	System		
Manta			Name			100 C 100 C 100 C 100 C			
Name			Name_		_	_	-	-	
Address	12.0	0202	Addres	s		-	144	_	
City	Cou	unty	City_	_		State	ZIP		
	TYPE OF	UNDERGROUND S	TORAGE TA	NK SYS	TEM CLOSU	RE			
Tank and piping n Tank removal only Piping removal on	emoval 1	Fank and piping closur Fank closure in place Piping closure in place	ne în place only only		Were any n Was any nev Number of a	ew tanks in w piping in ctive tanks	nstalled? stalled? s remaining		
Description	of Undergro	und Storage Ta	nks (Comp	lete fo	r each clos	ed tank a	t this loc	ation.)	
. Tank Informa	ition		Tank No.	Tank N	in. Tank Np.	Tank Na.	Tank No.	Tank 5	
			a terrariti a		Contraction of the second	and the second s	10000000		
Estimated age of	f tank in years.		22	-	4 4		h	1	
Substance store	d in tank:		-	-	-				
I Tank Clorus	n Information			-	3 3	-	<u></u>	-	
L. Tank Gigsur	e monitation	and the last of the second state of the	_				-	_	
Date tankinining	was permanently	ricepipeig (nervouryy).		-	1	-			
If closed in pla concrete, dril	ice. list the iner ling mud approved	t material used (sar d foam material).	nd,			6		9	
Note: All backfi be handled in the Mississippi Environmental C Guidelines for Closure of UST	li naterials must accordance with Department of Juality's (MDEQ) the Permanent Systems.	Disposed of in lar Returned to excar Stockpiled on site Aerating on site Aerating off site	ndtiil		Submit the locardinates 1. Lab analyt 2. Sample C 3. Site Drawi 4. Waste r water or bac	e foliow on with this local results hain-of-Cu ing manifests kfill materia	the sup Closure f s of sample stody if tank s als are disp	ng Ndges, bosed	
III. Site Assess	ment information	on							
Date samples we Was there any so Was there any fre	re collected. (mm/ 8 staining apparen e product noted?	dd/yy) £7	Was g Depth Were vis	rounde to grou lible ho	ater encounte ndwater (fleet) les in tanks/pi	red (yesin) ping7	0)		
To be complete	d by the tank o	wner: (Please print o	type all but	signatu	re)	Date:			
Dath: I certify t	that the informa	tion concerning cl	losure is tru	e to th	e best of m	v belief a	ind know	iedos.	
Owner's Name			Owner's	Signa	ture:				
		ertified by MDEQ to	Permanen	tly Clo	Contractor	Date: s Signatu	re:		
To be complete Name of person	certified by MDE	a to croserremove:	MUEQ Centified Contractor's Signature:						
To be complete Name of person MDEQ Certified (certified by MDE	u to closerremove:	MDEQ	ertifica	tion No.:	-985A1727C3	222.4		

Certificate of Operation

Must be posted in the store.

Should:

- Be used by Delivery Drivers.
- Indicate correct tank size.
- Indicate correct fuel stored.
- Indicate correct tank status:
 - Currently In Use (stores fuel)
 - Temporarily out of Use (No Fuel Stored)

CERTIFICATE OF OPERATION

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY UNDERGROUND STORAGE TANKS

MDEQ UST FACILITY ID NUMBER:

This certifies that the referenced facility is registered and has paid all annual tank regulatory fees. No certification of substantial compliance is indicated.

REGISTERED UST OWNER

John Doe (Example)

FACILITY NAME & ADDRESS

Registered Name of Facility Registered Physical Address of Facility

Tank Number	Compartment Number	Tank Status	Capacity (Gallons)	Substance Stored	Fuel Type
3 4 5 6	1 1 1	Currently In Use Currently In Use Currently In Use Currently In Use	15000 8000 8000 15000	Gasoline Gasoline Diesel Diesel	Regular E10 Regular Off-Road (Exempt) Highway (Taxed)

CERTIFICATE EXPIRES:

DATE CERTIFICATE ISSUED: 1/26/2022

Sym Chamberg

LYNN CHAMBERS, UST BRANCH CHIEF

JUNE 30, 2022

This certificate automatically renews upon payment of annual tank regulatory fees.

THIS CERTIFICATE MUST BE POSTED AT THE FACILITY

Change in Ownership

The consistence tank owner (i.e. old tank owner) is responsible for notifying the new owner of the requirement to notify MDEQ of the Change in Ownership within **30 days**.

We encourage completion of a Change of Ownership Form during the purchasing process

As the current owner, you can notify MDEQ directly by sending copy of the legal doc to <u>krobinson@mdeq.ms.gov</u>

Change in Ownership

 Form <u>should</u> be signed by the new tank owner

 Required to provide copy of legal document to MDEQ that indicates transfer of ownership occurred.

MS	Return Completed Form To:	Mississip Office of P.O. Box Jackson,	(State use only) ID # Date Recorded:				
-			Ins	tructions	1.000	1. 0.007	1
A copy of a	legal documentation of	thansler of own	enship of the un	stange in ownership or undergrout	automited to	NDEO.	*
Examples	include: the occurrently	dead, bill of wate	warranty dea	d atch Charge is persenting and	not be proce	aread witho	out stocuments
1 Sall	I. Ownersh	ip of Tanks	an on mean	II. Lo	cation of	Tanks	State States
Na Charler Hart	a from our or other particular	a new provider .		Party Sara			mag to a
diry Address				Physical Address (P.O. Box rultwo	upped sites		12
<u>.</u>		State	Ju fiede	Elw.		Saw	30.000e
				in the second se		MS	
inte		File		Caulty	Physic		•
nal .		NE.		Fast Brood (SP Easter, Stud. etc.)	2775	Indicate 7	chii .
						LEATe at	
als of formellar of	d overwrately, of tarwa (frank)	ept assaultant		NOTE. If any changes to	the UST sys	tern have	occurred duri
				ownership transfer, you m	ust complete	a a Notific	ation for UST
_			omoliance	Manager Information			
ach facility a	a recurred to have a t	named UST Com	plance Manao	or (Class AB Operator). Please h	al licenaed o	imilarce	manager belo
el Ceruteres	Marge			Ptune	- Grant		
OT Carphene	mape			Prupe	- Ena	0.1	
-		IV	Property	Owner Information			
1 Mark V o	constitution in the	some as the fire	the company	Ropey Ourse Sales			
Not requ	ined to complete this	section. Contin	tue to section	VI.			
1214		744		dillig Aldere			
				. 22			
100		2		1.0%		10.00	Dy Date
			M. Finance	of Freezenski liter		1	
elact a met	hod abowing how w	a base met the	Inincial response	as responsibility	anina with the	ST-2 5464	art H
Blate Trus	I Fund (motor fuel ta	anics only)	D Belf Ineur	ance D Private Insurance		Quaterile	e or Sunety B
2	VII. C	ertification (Read and	sign after completing al	I section:	5.)	
		all the state	Contraction of		all shows	Sec. 16	- STATE OF STREET
certify unde	ar penalty of law the	t I have person winguity of two	ally exercised as individuals	and am temiliar with the inform immediately responsible for oth	ation submi atring the m	formation	and all atta
ubmitted inf	omation is true, acc	urale, and comp	pinte.	and a serie of the			
tarte and Trite of	Little (of many plants) and the		Sign	dure of URT Cherner		. Owne	Signat
7							
fuervae in rea	restatute will be of the	Housed by MD	EQ staff within	a lease documentation of transfer	al ognature	of the un-	betterund stre

What legal documentation?

- Bill of sale
- Warranty deed
- Property deed

You should have "tanks" specifically referenced in whatever document you use to clearly show that transfer of ownership occurred.

MDEQ will not process "change of ownership" without a copy of the legal document.

What is NOT accepted:

Lease agreement does NOT count.

Notification of Suspected or Confirmed Releases

All confirmed or suspected releases must be <u>reported</u> to MDEQ within of discovery

(Tank Owner Responsibility)

Release Reporting

Two types:

Suspected Releases

Confirmed Releases



Suspected Releases

- Leak Detection Failures
- Unusual Operating Conditions
- Some Testing Failures
- Environmental Conditions

Anything that makes you "suspect" a release into the ground.

	06-28+01 1:05 PM	h in
11	SYSTEM STATUS REFORT	
1	T 1:LOW PRODUCT ALARM	
	1 1:DELIVERY NEEDED T 2:LEAK ALARM	D
180	T 3:LOW PRODUCT ALARM T 3:DELIVERY NEEDED	
IN NO	INVENTORY REPORT	
Contraction of the second	T 1:DIESEL VOLUME = 914 GALS ULLAGE = 9086 GALS 90% ULLAGE= 8086 GALS TC VOLUME = 908 GALS HEIGHT = 14.12 INCHES UNTER VOL = 41 GALS	

Examples of Suspected Releases:

- Leak detection failures:
 - ATG in alarm showing failed periodic leak test and no passing test within previous 30 days.
 - SIR records indicating a failed test or two consecutive inconclusive results.
 - Water in the interstice of a Double Walled tank.
 - High vapors recorded in monitoring wells.
 - Fuel observed in containment sump.

• Failed tests:

- line tightness test or tank tightness test.
- Line leak detectors in slow flow OR frequent slow flow...
- Water in your tank......

More Examples:

- Electronic sump sensor alarms that cannot be checked for fuel or water within 24 hours of discovery.
- Unusual operating conditions:
 - Customer complaints about pumps pumping slower than normal.
 - Unexplainable presence or sudden appearance of water in the tank.
- Environmental Conditions
 - Strong lingering smell of gas in the building

NOT a suspected release

A wetted connection under dispenser
– NOT

A small customer overfill (Under 25 gallons)

• An old oil stain on the concrete
Confirmed Releases

- Product observed in monitoring wells.
- Surface spills (greater than 25 gallons)
- Fuel dripping from UST component directly into the soil.
- Discovery of product or vapors in utility lines, sewers, or soil.



Release Reporting – to who at MDEQ?

- Report to MDEQ within 24 hours
 - Recommend email to:
 - Brittany Jamison (bjamison@mdeq.ms.gov)
- Take the immediate and appropriate action to prevent further release
- Identify and stop any fire, explosion or vapor hazards

We will cover what to do in more detail in the clerk training session.

Submit a written report to MDEQ in 10 days

What happens after a release is reported?

- Tank owner to submit "confirmation of release & initial abatement activities" form.
- Basically, telling us what you saw and what you did about it.
- Submit records requested by MDEQ clean up division.
- MDEQ will proceed with cleanup, monitor records for a period of time, and may require additional testing to be done.

Confirmation of a Release & Initial Abatement Activities - Page 1of 2

Submission of this completed form maste the report requirements for summarizing the initial abatement steps taken for a release as required in the Underground Storage Tank (UST) Regulations Section 200.62. Please submit this torn within 10 days after the release confirmation by mailing to the address below, fasting to (601) 901-6003, or e-realing to the attention of the appropriate UST project manager or to Pleather

			Location of UST System						
Contest		Fallity Marthus	Pality Methodus Number						
Talik Owner		Native							
A401444		Address							
Cay 1	ian 29.	Chy	Chy Eastly						
Plane runder		Para tatler							
		Release Information							
DATE DISCOVERED	DATE REPORTED TO	C HOED ESTIMATED VO	LUME LOST. DATE O	OF LAST PTT (attach results)					
G Tank Closure. / GW/Soil sample Inventory Shorts	Attach a copy of laborate s. Attach copy of laborate age. Attach copy of reco	ory results. Results atory results. Results ords.							
Tank Closure. / GWiSol sample Inventory Shorts MDEQ Inspects Vapors in builds Visually found: [Office:	Attach a copy of laborate s. Attach copy of labora ige. Attach copy of reco in. Inspector/Findings ings, manways, etc. Loc Surface sheen, []]float	ory results. Results atory results. Results ords. ation of vapors: ting petroleum, [] distre	sted vegetation. Loca	ion					
Control of Market Tank Closure. / GWi'Soil sample Inventory Shorts MDEQ Inspectik Visually found: [Other: Oth	Attach a copy of laborate s. Attach copy of laborate s. Attach copy of laborate age. Attach copy of reco in Inspector/Findings: hgs, marways, etc. Loc surface sheen, []float Source of RELEASE Draw Draw Doment Do	ory results. Results atory results. Results ords. sation of vapors: ting petroleum,distre CAUSE OF RELEASE: Dispit Donertii Demage Correcter Duringer Duringer Duringer Dotert	ased vegetation. Loca Type contramention Disactive Disac	6on EXTENT OF RELEASE Track Pt Proing Trach Dispond Carathactor Escavation Escavation					
Control of the second	Attach a copy of laborate s. Attach copy of laborate s. Attach copy of laborate age. Attach copy of reco in Inspector/Findings: hgs, marways, etc. Loc gsurface sheen, []float Source of RELEASE []Tava []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Datase []Courts []Courts []Courts []Datase []Courts []Datase []Courts []Court	ory results. Results atory results. Results ords. 	ased vegetation. Loca Type contramention Proting Protect Discolers Discol	Son EXTENT OF RELEASE Track Pi Proing Trunch Departure Area Departure Are					

Record Keeping

The Tank Owner

Who is responsible?

Not MDEQ Not the store clerk Not the Certified Contractor

Tip: (For annual or 3 year testing records) MDEQ recommends participation in the UST Compliance Assistance Program

MDEQ Compliance Assistance Program (CAP)

- Participation is voluntary
- MDEQ acts as a third party
- MDEQ tells you what and when to test
- You will receive
 - A summary sheet of all tests required and when they are due.
 60-90 days before due date
- In order to participate you have to:
 - Send the yellow sheet back to MDEQ with the new test dates (date tests were done on).
 - That way MDEQ can remind you the next year.

Please note: CAP program currently does not account for new 2018 regulations. This does not mean you don't have to do them.

What Records must be kept?

- Tank Installation Equipment Records
- Equipment Upgrade Records
- UST Repair Records
- Permanent Closure Reports
- Monthly Leak Detection Records
- Monthly Walk-Through Records

- Annual Testing Records
 - Spill bucket
 - Overfill prevention
 - Automatic Line Leak Detector
 - Shear Valves
 - Equipment inspection
 - Automatic Tank Gauge inspection
 - Sensor test
 - Sump inspection
- 3 year tests
 - Cathodic Protection
 - Sump integrity

Keep copies of the last 2 annual tests

• Overfill device inspections

Spill bucket tests

- Line Leak Detector tests
- Secondary containment
 Sump Inspections
- Inspection of Temporarily out of Use tanks

- Shear valve Tests
- Electronic Sensor Tests
- Automatic Tank Gauge
 Inspections
- Precision tightness tests
- Annual Inspection of handheld leak detection equipment.

Keep copies of leak detection records for a minimum of 2 years

Examples Include:

- Monthly Monitoring well records
- Monthly Interstitial monitoring records that may include:
 - visual inspections
 - sensor status reports & alarm history reports
 - reconciliation of all sensor alarms.
 - Water disposal or pump out records
- Monthly ATG reports for 0.2 for tanks.
- Monthly ATG reports for 0.2 leak tests for pipes.
- Statistical Inventory Reconciliation reports

Keep copies of monthly walk-through inspection reports for a minimum of 2 years

New: Monthly Walk-Through inspections

Monthly walk-through inspection form will require review of monthly leak detection records.

The monthly walk-through inspection form should aid you in meeting the 24 hour reporting requirement.

What about three-year tests?

Cathodic Protection

- For impressed current systems,
 - the last 2 years of 60 day rectifier logs
 - the last 2 impressed current cathodic protection evaluations
- For galvanic systems,
 - the last 2 galvanic cathodic protection evaluations

Secondary Containment Sump Integrity tests (Interstitial Monitoring)

- the last 2 "routine" secondary containment sump Integrity tests.
- all sump tests performed due to:
 - A release investigation.
 - A sump repair / replacement

Permanent Closure Reports

 Maintain Permanent Closure Reports for 3 years after USTs are closed

• Keep:

- site investigations
- sampling results conducted at closure
- Copy of No further action letter

until the property is sold



How do you know what records your supposed to have?

- Use MDEQs online database.
- https://www.mdeq.ms.gov/water/ groundwater-assessment-andremediation/undergroundstorage-tanks/musterweb/
- Inspection Compliance Requirements
- Type in ID number and hit enter
- Should pop up file showing records needed.

Facility ID:	
(Input Facility ID Number into t	he field above and hit Enter to download single facility information as a csv
Delivery Prohibition Lis	t _(CSV)
Facilities & Owners in V	iolation_(csv)
Scheduled Inspections	(csv (Click here to download 05:00am data)
Owners (Tank Count > 5	i) (csv)
Preliminary Subsurface	Investigation (PSI) letters to Tank Owners (CSV)
Leaking UST (LUST) Info	ormation (csv)
LUST Status Count Rep	ort (LSR) _(csv)
Inspection Compliance	Requirements
Facility ID:	
(Input Facility ID Number into t	he field above and hit Enter to download single facility information)
Current CAP Summary	PDF
Facility ID:	
() 	

(Input Facility ID Number into the field above and hit Enter to download single facility pdf) ***Under Construction 16Aug2021*

If you are experiencing Trouble please let us know

You can also check "registration" under UST facilities & owner Information.

Types of USTs

• Currently in use:

✓ The tank is active and actively storing fuel greater than 1 inch.

✓ UST Owner is still responsible for UST

• Temporarily Out of Use Indefinitely (TOSI):

✓ Tank remains in the ground
 ✓ The tank and piping can be brought back into use
 ✓ UST Owner is still responsible for UST

Permanently Out of Use:

Tank is removed from the ground, or
 the tank and piping are closed where they can never be brought back into use
 UST Owner is no longer responsible for the physical UST

Requirements for each varies. Let's discuss them one by one.

What is permanent closure?

system is the permanent elimination from service of a UST system by:

- Removal from ground
- Closure in place by filling with an inert solid material (approval for this type closure must be granted from MDEQ)



Permanent Closure Procedure

 Follow the "Guidelines for the Permanent Closure of Petroleum UST System"

Requires Mississippi UST

- Conduct soil and groundwater sampling as required.
- Contractor should give you:
 - copy of Closure Report
 - Sample Results
 - Chain of Custody form
 - Other documents

that should be sent to MDEQ within 60 days.



After the Permanent Closure

Keep copy of your **"No Further Action"** letter from MDEQ.

Tank Fees NO LONGER billed annually

Keep copies of closure records until the property is sold

All is done.



Temporary Closure

Tank fees still billed annually.

Annual Inspection to verify:

- Fuel removed to Less than 1 inch.
- Vent lines open
- Piping secure & capped.
 (Dispenser still in place)
- Maintain corrosion protection
- Site assessment.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY ANNUAL INSPECTION OF TEMPORARILY OUT OF USE UST SYSTEMS

> This > trop > Tan > Only	form may be u ection is requir ks must contain must be perfor y edequate Sol	dilized to document in ed by 10/5/2019 and e t loss then 1 inch fael, med within 1 year of by I Sampling and Analysi	spection of terr ivery year (1) t corrosion prote coming Temp te Results may	porarily o hereafter action mu orarily Ou be used	ut of use I st be man t of Use. for Perma	UST syst tained, a nent Clos	ens. nd a site sure of US	aasessment ST systems.	Deb	of Inspection		
		UST Facility			and the second	Per	son Co	nducting	Test			
Facility	Kama		MOIDO Reciti	h0+ h	respector's N	lame						
Physics	Address			c	-					i i		
City		County	ļ	State th MS	tapactur's S	işrətərə			Dub			
USTON	1910	UST Own	r Permanent Ma	ding Add	020		USTOW	ter Phone Stat	ndeter car	Email address		
		то	SI UST Sy	stem In	spectio	n Resu	its					
Reaso	on for Test	Routine Inspect	ion 🗌 Re-In	spection	(after faile	ed inspec	tion)] Other				
	Com	ponent ID (tank, pipe)										
	Date comport	ent was taken out of	service			8	- 3			- 100		
	Tank is Accessible?			1 Ye	No No	Ves	No No	Ves	No	Yes No		
4	Tank contains less than 1 inch fuel?			Ye	s 🗋 No	Yes	No No	Yes 🗌	No	Yes No		
AN)	If no, how much fuel? (Inches)			0.000	1997	2014 - C	as - 3	665 - 11976	18	9 N		
*	How much water is in the tank? (Inches)				100	Sec.	1212	80. 1110	- 3	tere est		
	Vent pipes appear open and functional			- U Ye	is 🗌 No	Ves Yes	No No	Yes 🗆	No	Yes No		
	Piping is securely capped at the dispenser?			U Ye	H No	Yes	No No	Yes 🗌	No	Yes No		
NG	All piping adequa	and/or pipe termination tely protected from co	ons appear presion?	DW	is 🗌 No	Vei Vei	No D	Yes 🗆	No	Ves No		
did	Method of Corresion Protection used (Sump, Boots, Cathodic Protection, Not buried, NON-metallic, Other: (specify))								8			
2	Pass	or Fail (Visual Insp	vection)						- 19			
20	List the date	that the last cathodic	protection sur	vey was	performed	1 on if a	oplicable	ATE DATE	- 22			
Prodic	Cathodic Protection Survey performed by (if applicable				IDIA): COMPANY / HONIDUAL							
200	60 Day Rectifier Log is being maintained?(if applicable				cable) Yes No BY WHOM?							
	Select One	Allowable h	Aethods			d						
IN		Soil Sampling a	nd Analysis	- S - I	Have results been sent to MDEQ?				Yes No			
ME		Water Sampling	and Analysis	10 1	Have results been sent to Mi			IDEQ7	Yes No			
SSES8	Ground Water Monthly Monitoring (Delays the requirement to perform site assessment 1			Ha Ha	Have all Suspected/Confirmed releases Deen reported to MDEQ?							

(Minimum of 1 month required.) Attach all monthly records to this form.

Commenta:

PRODUCED BY THE MISSISSPPI DEPT OF ENVIRONMENTAL QUALITY, OFFICE OF POLLUTION CONTROL, UST BRANCH PO BOX 2261, JACKSON, MS, 26725; PHONE (601) 951-5171; FAX (501) 951-5093; www.indeg.ma.gov

Temporary Closure Site Assessments

 Within 12 months (of registering as Temporarily out of Use) the facility must have a site assessment done for contamination or begin the permanent closure process.

What are allowable site assessments?

- Soil sampling and analysis.
- Ground Water sampling and analysis.
- Minimum of 1 month Groundwater or vapor monitoring during annual inspection of TOSI tank / pipe.
- Other MDEQ approved methods

Importance of Proper Temporary Closure

"According to eyewitness reports, the cover suffered a direct hit from lightning and destroyed two fuel tanks that were underground... things went everywhere."



Lighting Strike Causes Tanks to Explode

Lighting Strike Causes Tanks to Explode

According to the local news.... "It could have been a lot worse than it was."

Big bang, big hole

"The cover went high into the air and came through the building"



Proper Temporary Closure is **Important**





Hurricane Katrina



Partially cut vent line

Theft or Vandalism



"I mean the whole thing – the truck, the concrete, everything – went up so high it went out of sight and then it just came back down." ~Ricky Jones, eyewitness

Louisville, KY

Flooding & Changes in ground



What else can happen?.. MS recently had an STP manway explode





This was once a sump. Fire melted it all. Explosion from inside of sump.

What happened?

MS Manway explosion....



Explosion was largely contributed to:

- Exposed electrical
- Improper electrical
- Fuel & fuel vapors in the sump

For TOSI tanks or pipes it is recommended to shut off power to the STP and dispensers to reduce risk.

It is a lot more common than you think. What about "Currently In Use Systems"?



What should you do? Ask contractors to look at your site. Try to determine risk & need for repair. Repair as needed.... Don't put it off.

Currently In Use Tanks

Tank Fees Billed Annually

Annual Tests Required for all:

- Spill Bucket Integrity test
- Overfill Prevention Inspection

Monthly Inspections Required:

- Monthly Walk-Through Inspections
- Monthly leak detection

Other tests required depends on:

- Construction material of tank (Cathodic protection)
- Type of tank leak detection used



Spill Buckets

• Must be:

- Installed on all tanks.
- Tested annually for integrity.
- Inspected during monthly walk- through inspection.



MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY ANNUAL SPILL BUCKET INTEGRITY TESTING

 This form may be Testing of all api In the absence or method outlined. 	e utilized to doo I buckets is req f an approved below in the "M	sument integrity test pured at installation 3 rd party test proces INEC Hydrostatic To	ing of spill i and at leas ture or mai set Process	containtw at once en hutacturer	rri bucketa. ery 12 months t 'a recommende in mos he utilize	hermatter. d practice, the test	Date of Test		
LIST Facility					Perso	n Conducting T	est		
Facility Name MODEO Fo			adity (D#	Taniter's	Norma				
Physical Addman									
Ny County			State MS	MOROLO	artikalan #		Expiration Data		
UST Owner				Tester's	Signature		Date		
		St	III Buck	et Test	ina				
Reason for Test	New In	atalation 🖸 i	Existing Ins	tailation (annual test)	Release Invest	igation		
Construction	Single	-Walled 🔲 🛛	Double-Wa	lied [Spill Bucket	Liner Unknow	m		
	Hydrosta	tic (Complete "Test	Deta" table	below)		1.1			
Type of Test	Vacuum	(Attach test equipm	ent manufa	churse's d	ata sheet/test p	rotocol to this form)	i î		
- M	Cther (S	pacity)				a			
Eucket to the n 5. Leave the spill Note: For accu 8. If the fluid level Note: A leak le detection For t 8. Property dispon	earest 1/16 th is bucket undish racy, the local is the same o is different by ss than 1.8 th o rests performed ie of all test fit	nch. urbed for at least or lion where both the r it has changed by r more than 1/8 th in d an inch is still orth d as part of a release ads at the conclusion	the hour the initial and / 1/8 th inch th, the spi ical if the t se investig on of testin	on compa final fluid or less ti li bucket f ank is usi ation, flui 10	re the starting d levels are me in spill bucket ; lails the test. ing vapor monit d level reading:	fluid level to the end asured should be th passes the test toring as their metho s should be taken w	ting level. e same. xt of leak rry carefully.		
N	ote: MDEQ ce	rtification as a UST	installer is	s requires	1 to install spill	containment device	4		
		Te	st Data f	or the 1	fear				
Tank ID (produ	et sloved)		1.00			42	1		
Area of Spill Buchat Tasted		Double-Walled	Doubl	e-Walled le-Walled	Single-Walk	ed Single-Walled ad Double-Walled	C Single-Walled		
Test Start	Time	8 8	2		0		12 13		
Test End Time						9			
Test Beginning Level		8	2		6		1		
Test Ending	Level								
Teat Result (P	ana/Fail)	1	1		0		12 8		
Vacuum Test - G	auge Range		Gauge	Units	nWC	Other			
Comments:		376	29		V2		1		
							1		

PRODUCED BY THE MISSISSIPPI DEPT. OF ENVIRONMENTAL QUALITY, DIFICE OF POLLUTION CONTROL, UST BRANCI *0 BOX 2261 JACKSON, NS 35225 PHONE (601) 961-5171 FAX (601) 961-5003 Http://www.deg.ebdie.tml.ue 1/

Spill Buckets

NOT made to routinely hold product.

Catches fuel spilled during delivery.

TIP: Fuel <u>NOT</u> removed can damage your spill bucket.

Must be checked before and immediately after each delivery





Overfill Prevention Devices

RESTRICT At 90%



ALARM At 90%



SHUT OFF At 95%

Overfill Prevention Devices

Must be:

Installed properly.

- Ball Float cannot be installed, repaired or modified.
- Some components must be inspected during monthly walkthrough inspections.

Why are they important? Prevent Overfills

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY ANNUAL OVERFILL PREVENTION DEVICE INSPECTION

A A A	spection of all overfill dev the absence of a recog vice inspection Procedu ress Overfill Prevention	scara la required all a nized industry proc re" may be utilized. Devices installed a	nstallation and adure or man Ber October A	dicture"	nce en recom	mendes	ontha I I priecti II Devi	haneafter. or the "MDEQ re.or Electores	Overfil	Date	of Inspec	son
	U	ST Facility	1	10 m	10101	-	Perso	n Conductio	na linsa	ectio		3
Facility Network MDEQ Facility (D # Imper				Inspect	person conducting inspection							
Physic	al Addosse				Compe	-	-					
City		Courts		Sinte.	MORO	Carthon	from #		-	Evel	they Date	
27.		100000		MS		5000	2010			100	1000	
UST Owner Impe					impeci	pector's Tignature				Date		
-		Inspection R	esuits for t	he Year				ŝ				- i
2	Tar	nk ID (product story	ed)						1			- 22
	Ti I	ink Volume (gallon	a)			2		3	1	- 5		- 3
5	Te	nk Diameter (inche	(S)			<	- 3			- 3		- 3
<u>. </u>	0	vertă device prese	lin		- 8	Yes .	No	Yes No	Yes	No-	Yin [No
	Over	fil Device Manufac	Turer							_		
2	0	verfil Device Mod	d .			Sum	i mand	Second and	2000	1 HOL	110000	
1	and a second second	Device is New	200000000	en e		T'es.	No	Yes No	Yes	No	Tes [No
_	Device in good condition	on (Note Criteria in	Inspection Pr	tooedure.	1.	_ Yes	No	Yas No	Yana]No	Yas [No
-	All accessible tarik top fittings are tight					T'HER	No	Yes No	Yes	140	Yes	No
and a	Tank does NOT have a suction or tank syphon line installed					THE	- NO	Ties No	Tes	- No	Tres	Jan
1	Slandard drop tubes are installed & in good condition					[]Tes	140	T ves Tvo	Tun	1940	Tres	100
Flor	Length of Ball Fibal Valve (Inches)					-		-	-	-	-	
1	Distance being to	n of time that had a	pprinting (or	and Alexandria	- Ce	-	-		<u> </u>		-	
~	indicate task of	and its when from	instriction or	name statul	•/	-	-	· · · · · ·	1	-	-	-1
5 3	Complete shut off o	ocurs below any b	al float ninol	e in the b	ink 1	CTY44	The:	Cives Cible	C Ivin I	-No	CIVes F	No
3	Assembly a	nd all cankets/seah	in pood con	dition		Tyes	1 No	CIYes DNo	TYes.	DNo.	Cives I	No
5	Length of upper	r tube to the 'Refe	rence Point"	(inches)		1.11	-		-	-		1.00
a l	Length of Fill Riser	pipe (Sealing pos	tion to tank to	ob) (Inch	66		- 3	2 0	1	- 7	-	
10	Height of tar	ik top manway (if a	pplicable) (in	chea)					1		i —	
4	Distance below tank to	op where 'Referen	ce Point' is to	cated (in	ches)	÷	- 2	Q	1	- 9		
F.	Distance between F	Reference Point an	d Complete 9	hut off P	dint.	2		0	1	- 3		- 3
	Distance below tank	top where comple	te shut off oc	icuns (ind	165)	2	- 1	() 		- 3		- 2
5 - S	indicate tank capacity	when complete (2	* Stage) shut	t off accu	n (%)	(Q	1	- 9		-2
H.	Alarm is but	h audible and vielb	nd vieble to delivery driver			[]Yes	No	Ves No	1Yes	_Ne	Ties [No
E E	Distance below top of tank that electronic alarm is set (inches)						- 3			- 3		
10	Indicate tank capacity when atarm occurs (%)					Contra-	111/2		-	-	-	-
-		ATG Printout atta	ched			Tues	No	Tires Two	Yam	- No	A A A	Juo .
	Inspect	tion result (Pa	ss/Fall)				- 2	2 2	1	14	1	- 1
	mens. enalive methods include the devices are set to con- refil devices installed p vice. Alternative method Alternative Method mus	c precision type by pletaly shut off float tor to 10/5/2018 ma a pg. 2 must be new 1 have pg. 2 of this	Altern i fout valves at a height gr vy use ellerna valuated every form complet	Institute from the relation three from the five method is you and of price to the second	Metho et lo reo s5% to ots but dur init h0/5/21	trict flow writ caps must co ial inspe-	v at a t actly. mplete ction u l a copr	eight graater b pg. 2 of this & ang an Allema y sent to MDEC	am 90% am in fu the Math X No des	lank c I to 'P iod. Ar for wi	apacity or asia" an ov ty device u l be allow	drop rerfit using ed to

P.O. BOX 2261 JACKSON, MS 39225 PHONE (801) W1-5171 FAX (801) 961-5083 http://www.mdeg.ma.gov

4/2018

Two Kinds of Overfills

•1. "VISIBLE"

- Above ground release.
- Vent pipes or other riser pipes

• 2. "HIDDEN"

- Occur underground.
- Go unnoticed.
- Not seen by most leak detection methods.
- More common.

Visible overfills are particularly dangerous.





Biloxi, MS 1998



Figure 2. Dotted lines from the regular unleaded underground storage tank to the storm drain represent the flow of the gasoline overfill. Visible overfill was NOT noticed.

 Most over fills occur because of human error & not because of equipment failure.

• In the case of Biloxi both occurred.



What should your delivery driver do?

- Verify tank capacity before drop.
- Always watch fuel drop

(Not be in the store or inside truck) They should be beside the hose or very close by.

- Use proper adapters
- Clean up their mess / spilled in spill bucket


Delivery Drivers should NEVER..

- Disable Overfill drop tubes. BUT THEY DO!!!
- They will use gauge stick to measure fuel levels both before and after.
- They should NOT leave the stick in there when they drop fuel and pull it out after they are done.
- MANY know this trick.

IF you see it call their boss and report them.



Delivery Drivers should NEVER..

- Have the vapor recover cap open during drop
- If they have that 2nd (ORANGE) manway open during delivery they better have 2nd hose hooked up to it.
- MANY will never use the 2nd hose. Just stick something in it.
- Vapors VENT AT GROUND LEVEL. VERY VERY DANGEROUS.
 - Call the FIRE MARSHALL
 - Call their boss.



Don't try to pack the tank.

- Know how much room you have till 90 or 95%.
- Don't over order.
- Increases risk of:
 - drivers packing the tank.
 - Overfills
 - Damage occurring to overfill devices
 - Fuel in spill buckets.



Deliveries is the most dangerous time at a gas station



- Gas vapors
- Customer interaction
- Lack of training
- Lack of care
- Limited oversight and enforecement
- Protect yourself and your customers

Report them!!

Monthly Walk-through Inspections Pg. 1

Required to:

- Inspect Spill buckets
- Fill Caps
- Drop tube Overfill Devices

Recommended section is advised but not required.

There is an annual version of this form you can use to reduce paperwork.

Walk-throughs can be done by tank owner or 3rd party

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY MONTHLY (30 DAY) WALKTHROUGH INSPECTION

This form maybe utilized to document UST monthly walkthrough inspections.

Monthly walkthrough inspections are required to be implemented by 10/5/2021.

Additional training may be obtained by attending the MDEQ Compliance Manager Course.

Should MDEQ find that all issues were not logged or reconciled you may be subject to penalties.

U	ST Facility	Person Conducting Inspection					
Facility North	MOLO, Facility ID #	Impathit's Noise					
Physical Address	1.	Date of inspection					
	March Constant Street Street	222222222222222222					

Generalized Inspection Procedure

For each UST component listed, visually inspect it for damage and proper operation.

For the facilities method of leak detection visually inspect all records and/or equipment to ensure adequacy. Notify the current tank owner or responsible party of any record that must be reported to MDEQ as a suspected release.
Log all issues observed, indicate the action taken and the date the issue was resolved.

J.	Inspection Results (Required)								
Component	Ensure that:	Insp	ection Re	isults					
teropolis analog	All liquid or debris has been removed.	1 Yes	No	0100					
Spill Bucket	There is no visible sign of holes, cracks, or other damage that m cause the bucket to leak.	ry Ves	Ves No						
	All clamps and rings that seal bucket around the fill riser are tigh	t. 🗆 Yes	No						
	The interstitial space on double walled spill bucket is dry								
Fill Cap	Fill cap is in good condition and seals tightly onto the fill pipe.	Ves Ves	No						
Fill Pipe	Drop tube device is present, installed, and there are no sticks other obstructions visible in the fill pipe.	or Yes	No	II NA					
S	Inspection (Recommended)	Same							
No visible leaks	observed under all the dispensers when pumps are turned on.	1 Yes	No.						
No visible leaks	observed at all the STPs when pumps are turned on.	1 Yes	NO	-NA					
Spill Kit is prope	erly stocked and adequate.	I Yes	No						
There have be operating at a s	en no reports of unusual operating conditions such as dispense low flow or water intrusion into the tank.	rs Ves	No						
There are no un	ausual or unexplainable odors.	1 Yes	No:						
All clerks presen	nt on site have been properly trained and signed clerk log.	Ves.	No	D NA					
Action has been walk through in	n taken for all issues observed and reconciled on the previous mont spection report.	ns 🔲 Yes	No	- NA					
Site Specific:		1 Yes	No:	- NA					
Site Specific:		L Yes	No	- NA					
Site Specific	and the second second	Li Yes	No	III NA					
an an tao an taon an ta Taon an taon an t	Incident Log and Reconciliation	- Anna P	2						
D	escribe the Issue Describe the Action Taken to Re-	ohre	Date R	esolved					
-									
PRODUCED	BY THE MISSISSIPPI DEPT. OF ENVIRONMENTAL QUALITY, OFFICE OF POLICITION	CONTROL, US	T BRANC	t.					

Why the recommendation DEQ?

Inspection (Recommended)										
No visible leaks observed under all the dispensers when pumps are turned on.		Yes	No							
No visible leaks observed at all the STPs when pumps are turned on.		Yes	No	NA						
Spill Kit is properly stocked and adequate.		Yes	I No							
There have been no reports of unusual operating conditions such as dispensers operating at a slow flow or water intrusion into the tank.		Yes	No							
There are no unusual or unexplainable odors.		Yes	No							
All clerks present on site have been properly trained and signed clerk log.		Yes	No	I NA						
Action has been taken for all issues observed and reconciled on the previous months walk through inspection report.		Yes	No	NA						
Site Specific:		Yes	No No	I NA						
Site Specific:		Yes	I No	I NA						
Site Specific:		Yes	No	NA NA						

MOST leaks found by MDEQ inspectors is done simply by opening stuff up to look.

Even if you don't do this monthly. It is good practice to do it as much as you are able to. Anything is better than nothing.

You WILL be surprised to see what you find & catch early on.

Monthly Walk-Through Inspection (Spill Buckets)

- You must document at least one visual inspection of the spill bucket monthly.
- What do you inspect for?
 - Water must be removed / disposed of.
 - Fuel must be removed / disposed of.
 - Integrity must inspect bucket for holes, cracks, other indicators that bucket is not tight

Note: If integrity is questionable, contact your contractor to conduct integrity test.

Majority of all releases come from spill buckets.

Spill Bucket Integrity (Signs of issues & Tips for inspection)

Fuel or Water Present

Look for residual fuel ring.
(The larger the ring the faster the leak)
Inspect for hole around the water and fuel line.







Spill Bucket Integrity (Signs of issues & Tips for inspection)

No Fuel or Water Present

- Inspect gasket or seal in bottom of bucket.
- Inspect connection points where bucket is attached to the riser pipe.









More Tips



- Look at all abnormalities.
- Crack may be very small.
- Slow leaks can be detrimental to wells using monthly vapor monitoring for release detection.
- Remove product immediately when found in spill buckets.





Spill Bucket Integrity (Double Walled Spill Buckets)

• Double walled spill buckets may be equipped with:

- Gauge
- Liquid indicator float
- Electronic Sensors





Fill Caps

Verify that the cap is:

- In good condition.
- Seals tightly onto the tight fill adapter.
- That all seals or gaskets are present.

Tips:

If you can spin the cap it probably isn't liquid tight.

If you can spin the tight fill or if it's bent or crimped, that may be why fuel is routinely spilled in the bucket.





Monthly Walk-Through Inspections (Overfill Prevention Devices)

- Must inspect for sticks or other obstructions in the fill pipe.
- Primarily applies to drop tube shut off devices.
- May be difficult to see
- You should not take a delivery until the stick is removed.
- Contractor should:
 - Remove stick
 - Remove overfill drop tube
 - Inspect for damage to drop tube.





Monthly Walk-through Inspections Pg. 2

Required to:

- Review of Leak Detection Records
- Log all issues and what was done to resolve them.

Seems dumb to have to ask.... But who really looks at these? • Tank owner should be.....

I reviewed all app facility. I notified the curre record that must i Method Used Monitoring Wells Automatic Tank Gauging	All Metho icable reports, tests, or equi ent Tank Owner or Responsit be reported to MDEQ as a se All necessary monitoring a properly recorded. The ATG is operating wi conditions related to leak d 0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating wi conditions related to pipe leak All 0.2 gph pipe leak tests si	ds ipment related to leak detection at this ole Party in writing of any leak detection aspected release. Ensure that: wells were checked and observations th no alarms or unusual operating etection. bassing results. vas obtained (within 24 hrs) of all failing crests. th no alarms or unusual operating eak detection	Ves Ves Ves				
I reviewed all app facility. I notified the curre record that must t Method Used Monitoring Wells Automatic Tank Gauging	All necessary monitoring of properly recorded. The ATG is operating wi conditions related to leak d 0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating wi conditions related to pipe leak The ATG is operating wi conditions related to pipe leak All 0.2 gph pipe leak tests si	Ipment related to leak detection at this ole Party in writing of any leak detection uspected release. Ensure that: wells were checked and observations th no alarms or unusual operating etection. cassing results. vas obtained (within 24 hrs) of all failing crests. Ith no alarms or unusual operating eak detection	Ves				
I notified the curre record that must i Method Used Monitoring Wells Automatic Tank Gauging	All necessary monitoring of properly recorded. The ATG is operating wi conditions related to leak d 0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating wi conditions related to pipe leak All 0.2 gph pipe leak tests si	ble Party in writing of any leak detection ispected release. Ensure that: wells were checked and observations th no alarms or unusual operating etection. bassing results. vas obtained (within 24 hrs) of all failing crests. th no alarms or unusual operating eak detection	Ves Ves Ves Ves				
Method Used Monitoring Wells Automatic Tank Gauging	All necessary monitoring a properly recorded. The ATG is operating will conditions related to leak d 0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating will conditions related to pipe is All 0.2 gph pipe leak tests si	Ensure that: wells were checked and observations th no alarms or unusual operating etection. bassing results. vas obtained (within 24 hrs) of all failing crests. th no alarms or unusual operating eak detection	Ves Ves Ves Ves				
Monitoring Wells Automatic Tank Gauging	All necessary monitoring a properly recorded. The ATG is operating wi conditions related to leak d 0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating wi conditions related to pipe is All 0.2 gph pipe leak tests si	wells were checked and observations th no alarms or unusual operating etection. bassing results. vas obtained (within 24 hrs) of all failing crests. th no alarms or unusual operating eak detection	Yes Yes Yes Yes				
Automatic Tank Gauging	The ATG is operating will conditions related to leak d 0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating will conditions related to pipe is All 0.2 gph pipe leak tests si	th no alarms or unusual operating etection. sassing results. vas obtained (within 24 hrs) of all failing crests. th no alarms or unusual operating eak detection	Ves Ves Ves	No NA			
Automatic Tank Gauging	0.2 gph leak tests indicate p A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating wi conditions related to pipe k All 0.2 gph pipe leak tests si	passing results. was obtained (within 24 hrs) of all failing t tests. thin o alarms or unusual operating eak detection	Ves				
Cauging	A passing 0.2 gph leak test v or inconclusive 0.2 gph leak The ATG is operating wi conditions related to pipe k Ali 0.2 gph pipe leak tests si	vas obtained (within 24 hrs) of all failing (tests, th no alarms or unusual operating eak detection	Ves Ves	No NA			
5	The ATG is operating wi conditions related to pipe is All 0.2 gph pipe leak tests si	th no alarms or unusual operating eak detection	Yes Yes				
et	All 0.2 gph pipe leak tests si						
Electronic Line	A pareline 6.7 sub leaf- tar	how passing results.	Ves Yes	No NA			
Leak Detectors	failing/inconclusive 0.2 gph	st was obtained (within Z4 hrs) of all leak tests.	Yes	No NA			
A STATE OF CONTRACTOR	Report indicates that there	is no liquid observed.	Ves	No NA			
Visual Interstitial	All water observed has bee	n removed.	Vas	No NA			
Monitoring	All fuel observed has been	removed (Need to Benort to MDEO)	Vas	No NA			
ti ini Variosocome di	Monthly sensor status repo	rt indicates all sensors are not in alarm	Yes	No NA			
Electronic	All alarms for the month ha monthly Electronic Interstit	alarms for the month have been reconciled and logged on the onthiy Electronic Interstitial monitoring form.					
Monitoring	All water observed has bee	n removed.	Yes	No NA			
	All fuel observed has been	removed (Need to Report to MDEO)	Vas	No NA			
Statistical	Tank checked for water, no being property recorded.	o water is present, and fuel levels are	- Yes	No NA			
Inventory	Fuel levels were submitted	to a 3rd party vendor for analysis	Yes	No NA			
Reconciliation	The previous month's record	d indicates passing results	Vas	No No			
Other	The provide marries a figure	or measured burger in a second of	Mar	No NA			
winer.	different i	addant for and Bacasetlistics	1 162	COLUMN STOLEN.			
Dec	ADDITIONAL IN CONTRACT OF CONTRACTONTACT O	Describe the Action Taken to Earch	(Last	Date Received			
ę.			3				
				2			
-			, i	4			
-			ę	ž			
			ŝ				
PRODUCED BY	THE MISSISSIPPI DEPT. OF EWIR BOX 2261, JACKSON, MS 39225 PH	COMMENTAL QUALITY, OFFICE OF POLLUTION CON (ONE (001) 981-0171; FAX (801) 961-093, http://www.	TROL US	DOV BRANCH			

What is Release Detection?

Release Detection (leak detection) includes the activities and equipment used to detect a leak from UST Systems.

Tank owner will have at least 1 monthly leak detection record to keep...

 This section also goes over the annual tests required for the method and the monthly reports required.

 A UST system maybe capable of using multiple types of release detection.

• It is still important for you to know all that your system can do. Why?

Why do you need to know what your UST system can do?

- If the leak detection method that you are using malfunctions and you can't fix it in 30 days... (Ex: Lightening hits your ATG)
- What do you do?
 - Need alternative method if you have one.
 - If you don't have anything you can use report to MDEQ.
- It can also help you rule out some suspected releases.

(Ex. ATG fails periodic test but the other type of leak detection indicates everything is good)

You are still responsible for reporting a suspected release, but it can give you some assurance that no release occurred.

Consult with your certified UST contractor and / or MDEQ.

What can you use?

• If your tank or piping was installed after 10/1/08 then:

- You can only switch from electronic interstitial monitoring to visual interstitial monitoring.
- If your tank or piping was installed prior to 10/1/08 then you may use any form (if applicable to your site).

Remember: These are only temporary fixes.

It allows you to do some form of leak detection versus having none.

Some methods may require additional equipment inspection if you continue to use the method for a prolonged period of time.

What other reasons would you be required to change leak detection methods?

These are MDEQ required changes:

• Consistently high vapor readings in Monitoring wells. (Ex. Leak from spill bucket, dispenser, or STP)

 If the method of leak detection that you normally use doesn't work or isn't adequate.

Types of Release Detection

- Monitoring Wells
- Statistical Inventory Reconciliation
- Precision Tightness Testing (Piping)
- Automatic Tank Gauging
- Interstitial Monitoring
- Manual Tank Gauging



Which type can I use?

Intenstitial Monitoring.

UST systems installed after October 1, 2008, must use

UST systems installed prior to October 1, 2008, may use any of the methods if it is capable of doing it.



Monitoring Wells

- Use for tanks or pipe leak detection.
- Are shallow wells around tanks or along piping.
- Must be monitored properly using bailer or vapor meter
- They require proper location and construction.
 - One foot below deepest tank or pipe
 - Spaced no more than 50 feet apart.
 - Have factory slotted casing.





MONITORING WELLS





Monitoring Well Sampling



Monitoring Well



Groundwater (6 inches or more water in the well) Vapor Meter (Less than 6 inches water in well)

TIP: Know the total depth of your well and compare that to the ground water level recorded on the form. 6 inches is the cutoff point between methods. That will let you know if the well was monitored properly.

What needs to be reported to MDEQ?

(Note: These are also stated on the monthly form)

- Groundwater Wells
 - If 1/8 inch of product or more is observed.
- Vapor Wells
 - Reportable amount depends on the type of product your trying to detect:
 - For Diesel or waste oil: 100 ppm vapors.
 - For Gasoline: 5,000 ppm vapors.
 - if vapor readings jump substantially from the previous month.

Ex: If Diesel tank is in the same tank bed as the gas tanks, then your reportable amount is 100 ppm for all wells in that tank bed.

Monthly Groundwater / Vapor Monitoring Form

- Reportable amounts are shown in Red on the form.
- You should NOT see the # of wells checked from month to month vary.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY MONTHLY GROUNDWATER / VAPOR MONITORING

- This form may be utilized to document monthly monitoring of groundwater/vapor monitoring wells.
- Whenever the monitoring wells contain 6 inches or more of water, visually examine the water and record your observations
 under the "Groundwater" section at the bottom of this form.
- If the monitoring wells are dry or contain less than 6 inches of water, the wells must be checked with an instrument capable of detecting the product stored in the tanks and you must record your observations under the "Vapor" section of this form.

	UST Facil	lity			Person Conducting Monitorin								
Facility Nation			MDED Fact	N/ID#	Perso	r's Nartw		-					
Physical Address			57		Company								
Cey	Courte	-	-	Sizte MS	City .		State						
UST Owner				Letter .	Perat	rik Signature			n	lale			
	and south	Procedu	ure for C	heck	ing M	lonitorin	g Wells	i Rozensene					
 Plane the belief Note if there is a the tank observe Note if there is a top of the enter 	and viscally obs iny sheen of the ed on top of the r a layer of the sto	erve the wo stored pro water in the aned produce accord the th	eter. Iduct store I beiler. 1 observed Iickness of	tin 4	Rec The Rec	ord the vap ord the vap date the va ord any or herease (a	cors in parts cor mater m por mater s por mater s por mater s por parts	anufactor ess isst cr actor use D maters	n (ppm) er, mode eiterated d to cor only).	nexar i num mvert	ber, and		
product layer to Report to MDEC you observe a t on the water.	the nearest 1/8 i 3 immediately (ayer of istored p	inch) within 24 h woduct 1/8	oura) anys Indh ur m	me ons	Por Rep gas For den	ort to NEE cr saading aline or in tank pts aal tanks cr	Commade match 100 crease sub- crease sub- crease sub- crease sub-	ately (with 5 ppm fer stantially benches eportable	in 24 ho deset o from the containin amount i	ours) i or 5,0 previ ig bot is 100	anytime t 00 ppm idue mon th gas a ppm		
Product layer to Product layer to Report to MDEC you observe a t on the water.	the nearest 1/8 i 2 immediately (layer of stored p	inch) within 24 h moduld 1/8 Month o	icura) anyó Linch ar m	me ons	Rep vap gas For der	cort to MER co saading aline or in term pita aal tanka or	C mmade react 100 means add or pipes the r	ately (with b ppm fai stantially banches eportable ear	in 24 ho deael o hon the containin amount i	or 5,0 or 5,0 previ ig bot is 100	anytime t 00 ppm koa mon th gas a ppm		
Monitoring We	the nearest 1/8 i 2 immediately (layer of istoned p sults for the I	inch) within 24 h modula 1/8 Month 0	oura) enys Indh ar m	one 6	Bap yap gas For den	ent lo WEE cr taxding oline or in tanis pta al tanka or 4	C arrenada nauch SD crease adh ar pipes the r yipes the r Y	ately (with 5 ppm for stantially benches epontable ear 6	in 24 ho dead i from the containe amount i	na 5,0 srinit ng bal is 100 7	anytime t 00 ppm due mon th gas a ppm.		
Monitoring Res Monitoring Res	He nearest 1/8 i D immediately (layer of stored p iults for the I Number h to top of the well (retree)	inch) within 24 h moduct 1/8 Month o	f 2	me ans 16	Rep vap gas For der	ort to WEB or taxing office or in tarit pta al tanto or	C ormada Isauti SD Crease sub or pipes the r pipes the r S	atety (with 0-ppm file startbally burchas eportable 0ar 6	in 24 ho disset from the containin amount i	naris) i or 5.0 i primit ng bol is 100 7	anytime (00 ppm) koue mon th gate a pptm.		
Monitoring Res Monitoring Res Monitoring to the water.	the nearest 1/8 i D immediately (layer of stored p issuer of stored p i Number h to top of the wall (rethen) en of the abred the water?	Month o	f Poch ar m f Yes No		3 Yes	ent to WES or suiding office or ins tank pta al timbs or 4	C anniada a seach SD roses adh ar pipes the r pipes the r Yes No	ear Yes No	in 24 ho deale i from the containing amount i	Yes	anytime 1 00 ppm does more th gan a ppm. 8 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9		
Monitoring Res Monitoring Res Monitoring Res Monitoring We Measured dept awater in the r Is there any stee product on the there any lays product on	the nearest 1/8 i D immediately (injver of idoned p initial for the i Number I Number In to top of the well (rethen) en of the stored the water? ar of the stored the water?	Month o	f 2 Yes No Yes No		Yes No	4	C anniada a seach SD ar pipes the r pipes the r Yes No Yes No	ately (with 5 ppm fis ctartially benches eportable 0 ar 6 9 Yes 9 No 9 Yes 9 No	in 24 ho deast o from the contains ambard i	Yes No	Bandina (Color ppm) Kasa mor b gan a ppm) 8 9 9 10 10 10 10 10 10 10 10 10 10		
Monitoring Res Monitoring Res Monitoring Res Monitoring We Measured dept suffer any size product on to there any size product on the there is a key product on if there is a key	Autor and a stored in the meanest 1/8 in Commendiately (autor of stored p autor for the interpretation of the seal (rection) en of the stored the water? ar of the stored the water? in of the stored its is it? (inches)	Month o	f 2 Yes No Yes No		Yes No	4	C anniada a seach SD roses who ar pipes the r pipes the r Yes No Yes No	ately (with o ppm file stantially benches eportable 0 ar 6 9 Yes 9 No 9 Yes 9 No	in 24 ho deast o from the contains ambart 1	Yes No	8		
Monitoring Res Monitoring Res Monitoring Res Monitoring We Measured dept water in the r Is there any she product on the there any lay product on the there any lay product on the there is a lay product on the there water in the r set of the set of the there product on the there any lay	international 1/8 i international 1/8 i international provident international provident international provident international (international) and the stored the water? and the stored the water?	Month o	f 2 Yes No Yes No		Yes No	4 Ves No	S No	ately (with organic field organic field orga	in 24 ho dead o from the contains amburt 1	renk) i or 6,0 i srent ng bol te 100 7 Yes No Yes No	8		
Monitoring Res Monitoring Res Monitoring Res Monitoring We Measured dept sater in the fit there any she product on to there any she product on the there any see product on the there are any product on the the the the part million	Autor and a set of the nearest 1/8 i D immediately () injver of stored p injver of stored p is to top of the set (critical) en of the stored the water? ar of the stored the water? ar of the stored the water? ar of the stored is is (critical) pecord in parts thesare) per nearest pecord in parts thesarest per nearest pecord in parts thesarest pecord in parts	Month 0 1 Yes No Yes No Yes No	f 2 Yes No Yes No		Yes No Yes	4 Ves No Ves No	C annuada asauch SD rosses sub ar pipes the r Pipes the r Yes No Yes No Yes No	ately (with opport for chard ally branches eportable ear 9 Yes No 9 Yes No		restant) i or or 6,0 oprimet ing boto ing boto ing ing boto ing boto ing boto ing boto ing boto ing bo	8 Yes Yes Yes Yes Yes Yes Yes Ye		
Monitoring Res Monitoring Res Monitoring Res Monitoring We Measured dept sater in the is there any she product on is there any lay product on is there any lay product on if there is a lay product on if there is a lay product on if there is a lay product on if there is a lay is a lay if there is a lay if there is a lay is a lay if there is a lay if there is a lay if there is a lay is a lay if there is a lay i	An interact 1/8 i Commission of the interact 1/8 i Commission of the interact of the interac	Month 0 1 Yes No Yes No Yes No Yes No	f 2 Yes No Yes No		Yes No Yes No	4 Ves No Ves No	C anniada asach SD rosse sch ar pipes the r Pipes the r Yes No Yes No	ately (with ppm: fis startially benches eportable ear 6 Yes No Yes No	in 24 ho deast o from the contains amtaut i	restation of the second	8 Press		

Ground water / Vapor monitoring (Annual Equipment Inspection)

New: All bailers and / or vapor meters used to monitor your site must be inspected annually.

Who does this?

- You if you check your own wells.
- Contractor if contractor checks your wells.
- For vapor meters a 3rd party vendor.

Seems unnecessary... but is it?

- Fresh fuel is very clear.... Can you see it?
- Gauge sticks wear.... Can you read it accurately?
- Vapor meters frequently do not get calibrated properly..





Annual Handheld Leak Detection Equipment Inspection Form

Annual test for:

- Monitoring wells
- SIR if gauge stick used
- Manual Tank gauging

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY ANNUAL HANDHELD RELEASE DETECTION EQUIPMENT INSPECTION

This form may be utilized to document adequate operability and serviceability of ALL handheld release detection equipment.

Inspection of Handheld release detection equipment is required to be done by 10/5/2021 and every year thereafter.

	UST Facilit	y	Pe	rson Conductin	ng Inspectio	n
Facility N	ame	Facility ID#	Inspector Nar	ne		
Facility A	ddress		Date of Inspe	ction		
	MDEQ Hand Held	Release Detection Ed	uipment Inspe	ction Procedure	e	
 Visu If ar Equ 	ually inspect all applicable handh ny answer is "NO" for the equipm ipment must be reinspected onc	eld leak detection equip ent being inspected; sen e service, repair, or repl	ment used at the vice, repair, or rep acement has occu	facility. blacement with e urred.	quipment is	required
	Manual Tank Gauging or Ma	nual Statistical Inven	tory Reconciliat	ion	Inspection	Results
All gau	ge sticks on site are the appropri	ate length for all USTs o	n site.		Yes 🗆 No	🗆 NA
All gau	ge sticks are clearly legible with	units on a 1/16 th in <mark>c</mark> h sca	ile.		Yes 🗆 No	D NA
All inad	dequate sticks have been remove	ed from the facility and c	isposed of.		Yes 🗆 No	🗆 NA
	Groun	dwater Monitoring		31	Inspection	Results
All bail	ers used at this facility are opera	ble and in good conditio	n.		Yes 🗆 No	D NA
Clear v	vater can easily be seen in the ba	iler and easily distinguis	hed from product	t. 🗆	Yes 🗆 No	D NA
All inad	dequate bailers have been remov	ed from the facility and	disposed of.		Yes 🗆 No	□ NA
		Vapor Monit	oring		a	
All	vapor monitoring equipment us	ed for leak detection m	ust be inspected ,	/ certified annua	ally by a 3rd p	party.
	Certificate	of Calibration is require	ed to be provided	by the 3 rd Party	6	
Party	Company	Evalua	tor Name			
3.4	Address	Phone	Number	Date of Ca	alibration by 3 rd p	arty
10.004	Owner or Operator					
ter	Manufacturer and Model					
Me	Serial Number					
	Third Party C	ertificate of Calibration	attached?		Yes 🗖	No

Statistical Inventory Reconciliation

- Used for both tank and pipe leak detection.
- You must contract with an approved 3rd party SIR Vendor
- Inventory Records are:
 - Collected manually by you and sent to vendor
 - Or vendor can access your ATG and POS system to gather inventory information.
- The SIR Vendor analyzes your records and sends you a report each month
- The report will tell you the results are Pass, Fail, or Inconclusive

SIR Requirements

- Leak threshold of 0.1 gph
- Typically, 21 30 days readings.
- Accurate gauge stick readings.
- In some cases, equipment to be installed.
- Accurate tank size information.
- Accurate meters readings at the dispenser.
- Vendor's form must be in an MDEQ approved format.

Annual tests needed:

- ATG inspection if used to collect data for vendor.
- Handheld leak detection equipment inspection if gauge stick used to collect data for vendor.



What needs to be reported to MDEQ?

 Must report any time you have a "fail" or two consecutive "inconclusive" results.

• Precision tank and line testing required when you get a "fail" or two consecutive "inconclusive" monthly tests.

 Keep monthly reports and annual summary of leak detection reports provided by SIR Vendor.

Precision Line Tightness Testing

- Annual Test.
- Only allowed to meet pipe leak detection requirement.

Must be:

- Done by a Certified Contractor
- Capable of detecting a 0.1 gph leak rate at 1 ½ times operating pressure
- Reporting Requirements:
 - A Failed Line Tightness Test must be reported to MDEQ within 24 hours.



Manual Tank Gauging

Allowed for tank leak detection only.

Tank must be:

- 2000 gallons or less
- Must be left out of use for up to 36 hours for testing
- Test performed weekly
- Averaged monthly
- Requires accurate gauge stick readings
- May require periodic tank tightness testing.

Annual tests needed:

Handheld leak detection equipment inspection of gauge stick

MDEQ Manual Tank Gauge form

Mississippi Department of Environmental Quality MANUAL TANK GAUGING RECORD

This form maybe utilized to document manual tank gauging leak detection results.
 Test procedure maybe found under EPA publication 510-B-93-005.

> MDEQ modified weekly / monthly standards below for Pass / Fail criteria.

Facility Information													est Information					
Facility ID #: Facility Name:					y Name:					Month Year				ear				
Tank Identification Tank Capa					acity Tank Diameter					Person Completing Form								
	_	Select tank siz	e, test	duration	, and weekly /	monthly	/ stan	dard in tab	le b	elow:				General Instr	uctions			
		T l- c'-			Minimum	kly S	tandard	м	ionthly Stand	lard	≻Gaug	ge water and fu	el levels to th	e nearest 1/8 in	ch.			
		Tank Siz	e		Test Time		(1 Test)		(4 – Test Average)		age)	> Utili:	e water finding	g paste to dete	ermine water lev	vel.		
Π	Up to	550 gallons			36 hours	1	10 gal	llons		5 gallons		≻ Shoι	ıld water be pre	esent either be	efore or after th	e tes	t,	
	551 – (<u>whe</u> r	1,000 gallons tank diameter	r is 64"	")	44 hours		9 gall	lons		4 gallons		docu the s	mentation of v ame weekly / r	vater level is r nonthly stand	equired. Water ards shown in th	is sub ne tal	bject to ble.	
	551 – (<u>whe</u> r	1,000 gallons tank diameter	r is 48″	")	58 hours	1	12 gal	allons 6 gallons		6 gallons		→ For t and	ooth fuel and w the monthly av	ater levels, co erage of the 4 the table	compare your weekly readings 4 weekly readings with the			
	551 – perior	1,000 gallons (dic tank tightne	(require ess test	es ting)	36 hours	1	10 gal	llons	5 gallons			> If eit for e	 standards shown in the table. If either the weekly or monthly standards have been either either fuel or water, the UST may be leaking and shows a standard shows a stan			xceeded		
	1,000 perior	1,000 – 2,000 gallons (requires periodic tank tightness testing) 36 hours				1	13 gallons			7 gallons	ons		reported to MDEQ within 24 hours as a susper > Tank Tightness testing every 5 years as indicated			ted release. ≥d.		
Sta	art Test	First Initial Stick Reading (inches)	Sec Initia Rea (inc	cond al Stick ading ches)	Average Initial Reading (inches)	Initia Gallon (conve inches gallons)	l Is Irt to [a]	End Test		First End Stick Reading (inches)	Sec R (i	ond End Stick eading nches)	Average End Reading (inches)	End Gallons (convert inches to gallons) [b]	Change in Tank Volume <u>In</u> Gallons (+ / -) [a – b]	Tar M	nk Passes Test ark One	
Date	:	Fuel	Fuel		Fuel	Fuel		Date: Time: AM / PM		Fuel	Fuel		Fuel	Fuel	Fuel		Pass	
Time AM	:: / PM	Water	Water	r	Water	Water				Water	Water		Water	Water	Water		Fail	
Date	:	Fuel	Fuel		Fuel	Fuel		Date:		Fuel	Fuel		Fuel	Fuel	Fuel		Pass	
Time AM	:: / PM	Water	Water	r	Water	Water		Time: AM / PM		Water		er	Water	Water	Water		Fail	
Date	:	Fuel	Fuel		Fuel	Fuel	d Date:		Fuel		Fuel		Fuel	Fuel	Fuel		Pass	
Time AM	:: / PM	Water	Water	r	Water	Water		Time: AM / PM		Water	Wate	er	Water	Water	Water		Fail	
Date	:	Fuel	Fuel		Fuel	Fuel		Date:		Fuel	Fuel		Fuel	Fuel	Fuel		Pass	
Time AM	:: / PM	Water	Water	r	Water	Water		Tíme: AM / PM		Water	Wate	er	Water	Water	Water		Fail	
PRC	DUCED B	Y THE MISSISSI	IPPI DE	PT. OF EN	VIRONMENTAL	QUALITY	, To th	o see how o ne sum of th	close he 4	e you are to th weekly readi	ne mo ngs by	nthly star / 4 and er	ndard, divide nter result	Fuel			Pass	
	PO BOX 2 FAX (6	2261 JACKSON 01) 961-5093	N, MS 3 http://w	9225 P www.deq.st	HONE (601) 961 ate.ms.us	-5171 //23	he	ere. Perfori	m th	e calculation	for bo	th fuel a	nd water.	Water			Fail	

Automatic Tank Gauging

ATG can:

- Tell you fuel levels
- Let you know when you need a delivery
- Perform leak tests if its programmed properly.






ATG for Leak Detection (Tanks)

- Performs 0.2 gph leak test at least every 30 days
- Must be programmed correctly
- ATG is inspected annually



ATG Annual Inspection form

Contractor should:

- Verify ATG programing.
- Remove the probe from the tank.
- Reconnect the probe.
- Move fuel & water floats on the probe to simulate alarms.
- Verify alarms sound at correct level.
- Should make audible and visual alarm on ATG. If it doesn't your contractor should fail it.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

ANNUAL AUTOMATIC TANK GAUGING EQUIPMENT INSPECTION we be utilized to document the proper operation of automatic tank geogene (ATG) equipment. Date of inspection

	*
ATG equipment that is utilized to meet the tank or pipe leak detection requirements is required to be inspected	
once every 12 months. ATG meybe conducting monthly 0.2 gph leak leate or Statistical Inventory Reconciliation.	
In the absence of a secondized industry procedure or manufacturer's recommended practice, the methodology outlined below (see "MDEQ Automatic Tank Gauging Equipment Inspection Procedure") may be utilized.	

UST Facili	ty		Person Conducting Inspection						
Facility Name	MERCO I	facility (D.#)	repertor's Marie						
Physical Address		0	outrany						
City County		Date M	DEO Certification #		Capita	itie: Outs			
JST Owner		-	epactoria Signature		Date				
Auto	matic Tank	Gauging I	Equipment Ide	entification	in the second se				
Menufacturer	Bodel		0.0000000000000000000000000000000000000	Cornele Seriel	Nate				
Type of Leak Detection Tarik 0.2 gp	h leak tests: (ic Line Leak D	Static D	Continuous) 0.1 goh leak tes	C Statistic	al Inventory Re	ocenciliation			
 Reposition the fuel and water for the ATG suport for all manually of Reinstall probes ensuring that th 9. If ATG is equipped with printer, it 	ets, measure d obtained fuel or a tank riser cap attach the prints	stance itom b water levels. I seals propert d ATG set-up	ottom of the prob y and the commu- information to the	i, and utilize ter nication cable a i form.	ik charts to cont eail is tight.	irm accuracy o			
	Inspec	tion Resul	ts for the Yea	Hr [-			
Tank / Compariment identification			-						
Cotsole functions are normal and no alarm condition exists	Yes No	Ves 🗆 No	Ves No	Yes No	Yes No	÷			
Visual and audible alarms tested and function correctly	Yes No	Ves No	Tyes I No.	Type DNo.	Type TI No.	Yes No			
Contect parameters are input and leak teating performed			and the later of the	and the sugar	Participation Participation	Ves No			
	Yes No	Ves No	Yes No	Yes No	Yes No	Ves Ne Ves Ne Ves Ne			
All tank probes are in good condition and functioning property	Yes No	Yes No	Yes No	Ves No	Yes No	Yes No Yes No Yes No Yes No			
All tank proteo are in good condition and functioning property Manually obtained fuel levels indicate ATG inventory is corriect	Yes No Yes No	Ves No Ves No Ves No	Yes No Yes No Yes No Yes No Yes No	Yes No	Yes No	Ves No Ves No Ves No Ves No Ves No			
All tank probes are in good condition and functioning property Manually obtained fuel levels indicate ATG inventory is convect Manually obtained water levels indicate ATG inventory to convect	Yes No Yes No Yes No	Ves No Ves No Ves No Ves No	Yes No	Yes No Yes No Yes No	Yes No Yes No Yes No	Yes No Yes No Yes No Yes No Yes No Yes No			
All tank proteo are in good condition and functioning property Manually obtained fael levels indicate ATG insentory is correct Manually obtained water levels indicate ATG inventory is correct Tanti cap, seals and communication cable are in good condition	Yes No Yes No Yes No Yes No Yes No	Yes No Yes No Yes No Yes No Yes No	Yes No	Yes No Yes No Yes No Yes No Yes No	Yes No Yes No Yes No Yes No	Yes No Yes No Yes No Yes No Yes No Yes No Yes No			
All tank probec are in good condition and functioning property Manually obtained fuel levels indicate ATG internitry is connect Manually obtained water levels indicate ATG internitry is connect. Tank cap, seals and communication cable are in good condition ATG Set-up information attached	Yes No Yes No Yes No Yes No Yes No	Ves Ni Ves Ni Ves Ni Ves Ni Ves Ni	Yes No Yes No	Yes No Yes No Yes No Yes No Yes No	Yes No Yes No Yes No Yes No Yes No	Yes No Yes No Yes No Yes No Yes No Yes No Yes No			

PRODUCED BY THE MISSISSIPPI DEPT. OF ENVIRONMENTAL QUALITY, OFFICE OF POLLUTION CONTROL, UST BRANCH PO BCK 2281 JACKSON, MS 20225 PHONE (601) 981-5171 PAX (601) 981-5093 http://www.deg.state.ms.us 1//

Automatic Tank Gauging

- Two ways to perform tank leak detection
 Static leak test (2-6 hours)
 - Typically done at night time.
 - No dispensing or delivery during test.
 - More cut and dry pass or fail.
 - Continuous leak detection (20 + hours)
 - ATG collects data throughout the day.
 - Similar to static but at varying fuel levels.
 - Typically for facilities open 24 hours.
 - Many factors affect pass or fail.

Example of ATG report (Tanks)

- You must maintain record of at least 1 passing 0.2 gph test for each month.
- Required to have 1 passing test every 30 days.
- So if you exceed 30 days with no pass then it is reportable as suspected release.
- No form to document this test.
- Keep copies of the ATG tickets.

SEP 19, 2017 8:00 AM CSLD TEST RESULTS SEP 19, 2017 8:00 AM

T 1: UNLEADED PROBE SERIAL NUM 498725

0.2 GAL/HR TEST PER: SEP 19, 2017 PASS

T 2:PREMIUM PROBE SERIAL NUM 016521

0.2 GAL/HR TEST PER: SEP 19, 2017 PASS

T 3:DIESEL PROBE SERIAL NUM 219806

0.2 GAL/HR TEST PER: SEP 19. 2017 PASS

What should you do if it fails?

- You should monitor the results of every test that the ATG completes.
- Routine / frequent failures is a..... Sign
- Maybe programming. Maybe leak.
- It's entirely possible to have 28 failures a month and 1 passing result.
- Is that okay? Not at all.
- ATG should have very limited number of "false alarms".
- Call your contractor.
- Report unusual monthly ATG results or trends to MDEQ immediately.

Contractor should:

If you see a fail. Try to determine why.

- Look at ATG inspection and see if "static test" or "continuous test".
- You as an owner need to know this....
- Why does that matter?

 If your running Continuous Tests (20+ hours) It maybe necessary to shut down the tank and run a Static test (2-4 hours) to get a pass.

 A failure on static test should be reported immediately if a passing test cannot be achieved within 24 hours.

Why did you get a pass?



- Same Size Hole. Different head pressures from fuel. Fuel levels fluctuate.
- That is why:
 - The Trends Matter
 - Where the fluid levels are when it fails matters.

How does groundwater contribute?



- With groundwater now you have pressure pushing back on the leak. Even slower leak rates.
- Fuel levels will fluctuate. Groundwater may or may not.
- That is why:
 - Trends matter. If you routinely have water show up at low fuel levels, you likely have an issue.
 - Routinely checking for water or phase separation matters.

The unaccounted-for factor.....

- Entrained water.
- Gasoline can hold water without a change in volume.
- Meaning:

Your tank can leak and the water it takes in off sets the leak.

Any sign of water in your tank is concerning.

- Phase Separation
- Traditional water in tank bottoms

Water observed may come and go with deliveries. It is still a sign... you have a suspected leak.

Typical reasons an ATG may fail a 0.2 gph leak test?

- Not enough fuel in the tank.
- Temperature of fuel.
- Recent deliveries.
- Someone dispensed fuel when ATG was trying to run the test.
- High through-put fuel sales.
- Tank Manifold lines.
- A leak.
- Pressure decay vent caps not functioning properly.

ATG for Leak Detection (Piping)

- Must have Electronic Line Leak Detector Installed.
- ATG must be programed correctly.
- ATG uses electronic line leak detector to monitor pressure in the pipe.
- Can perform 0.2 gph or 0.1 gph leak tests.

Annual tests needed:

- ATG inspection.
- Line leak detector test



Example of ATG report (Piping)

- You must maintain record of at least 1 passing 0.2 gph test for each month.
- For any test that fails or is inconclusive, the next test must be done within 24 hours with passing results.
- If passing results cannot be achieved in 24 hours it must be reported to MDEQ as a suspected release.
- Trouble shooting here would include opening all dispenser and manways to look for fuel leak.

W 2:PREMIUM 3.0 GAL/HR RESULTS: LAST TEST: AUG 14,2012 10:00AM PASS NUMBER OF PREV 24 HOURS SINCE MIDNIGHT 0.20 GAL/HR RESULTS: 2,2012 1134PM AUG 9,2012 11;25PM AHG 6.2012 10:49PM AUG 012 1213668 3141 2012 : 1 OPM 29.20122012 11:04PM JUL 23,2012 4:24AM JUL 19.2012 10:56PM 17,2012 12139 0.10 GAL/HR RESULTS: MAY .2012 JUN 8.2011 12:50AM MAY

X X X END X

Interstitial Monitoring

Interstitial Monitoring must be used for:

- All tanks or piping installed after 10/1/2008.
- All sumps installed after 10/1/08 when piping terminations are modified.

(Commonly required when new STPs or Dispensers are installed.)

It can be also be used for leak detection for double walled tanks or piping installed before October 1, 2008

Interstitial Monitoring

Refers to monitoring of the space between two walls. Also known as the "Interstice" or "Interstitial Space"



Interstitial Monitoring

Two common types:

Electronic sensors

Sensors installed in Interstitial space.

Manual - visual inspection

• Visual inspection of tank and / or piping interstitial space.

Electronic Sensors

Sensors must be installed properly.

- 1 inch from bottom of piping secondary containment sump.
- At the bottom of the tank interstice

Monthly reports:

- Print off Sensor Status
- Print off Alarm history
- Reconcile all alarms

Annual Tests required:

Electronic IM Device testing





Annual Electronic Interstitial Device Test Form

- Contractor should trigger alarms on all sensors.
- You should see this on monthly alarm history printout.
- If you do not, sensor either:
 - Was not tested.
 - Failed but not reported correctly.

 This form may be Testing of electronic In the absence 'MDEQ Bectronic 	a utilized to document fu onic interstitial monitorin of an approved 3 rd part ic Monitoring Device Tec	nctionality teating g devices is requi y test procedure al Procedure' ou	g of a lined a or i sined	Nectronic Interstitial monitoring devic al least once every 12 months. manufacturer's recommended pract I below may be utilized.	ice, the		
	UST Facility	32	ŝ	Person Condu	icting Test		
Facility Norm	~	MOED Facility	D#				
Physical Address		- #		Company			
Cey	M	ite S	MDED Certification #	Expiration Date			
UST Owner				Tester's Signature Date			
	Electron	ic Interstitia	d Me	onitoring Device Testing	10		
Reason for Test	New Installation			Existing installation (annua	al test)		
	Float Switch	disc	orimi	nating 🛛 non-discriminatin	(g)		
Type of Sensor	Diptical Sensor			Electrical Resistance Se	nsor		
	Pressure / Vacu	um Monitoring D)evic	e Other (specfy)			

. Visually examine the device to ensure that it is not damaged or corroded and any moving parts are free.

. Cause a condition that should trigger the sensor to alarm (submerge sensor in appropriate fluid).

4. Ensure that the alarm condition causes the appropriate response (e.g. visual and audible alarms, STP shutdown, etc)

5. Note in the facility alarm history records that this alarm was the result of an annual functionality test

6. Ensure that the electronic interstitial monitoring device is reinstalled properly.

7. If ATG is equipped with printer, attach the printed alarm reports that resulted from sensor testing to this form.

		Te	st Data fo	r the Year	6 (C	1		
Sensor ID (Location)		2	L.	1	T		2	1
Sensor Installed Correctly	Yes No	Yes No	Yes No	Ves No	Ves No	Yes No	Yes No	Ves No
Sensor in Good Condition	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
When placed in test fluid, does the sensor trigger a Visual and Audible Alarm	Ves No	Yes No	Yes No	Yes No	Yes No	Yes No	Ves No	Yes No
When placed in test fluid, does the service trigger STP or Disperser Shutdown	Ves No	Ves No	Yes No	Ves No	Ves No	Yes No	Ves No	Ves No
Sensor labeled property	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No	Ves No	Yes No
Alarm reports printed and attached (Yes / No / NA)					Ê.		1	1
Test Readt (Pass/Fail)			1		1	1	1	

Electronic Interstitial Monthly Reports Sensor Status Report

Print and keep 1 copy per month.

Only tells you if sensors are hooked up and what condition they are in.

Should have the same # of sensors monthly showing on report.

The labeling of sensors is checked during annual testing. If you notice it is not labeled right call your contractor.

If it's in alarm, go reconcile it.

NUG	31.	2017	1:37	PM	
_1QI	JID S	STATUS		4 4	
AUG	31.	2017	1:37	PM	

L 1:DISP 1 2 SENSOR NORMAL

L 2:DISP 3 4 SENSOR NORMAL

L 3:DISP 5 6 SENSOR NORMAL

L 4:DISP 7 8 SENSOR NORMAL

L 5:REG STP SENSOR NORMAL

L 6:REG INTERRIITUAL SENSOR NORMAL

L 7:PRE STP SENSOR NORMAL

L 0:PRE INTERSTITUAL SENSOR NORMAL

* * * * * END * * * * *

12/08/2017 09:26:05

SENSOR REPORT Last Available

2 WIRE SENSOR

Unleaded STP SS Ok 12/08/2017 09:26:05

Premium STP SS Ok 12/08/2017 09:26:05

DEF STP SS Ok 12/08/2017 09:26:05

East Diesel STP SS Ok 12/08/2017 09:26:05 West Diesel STP SS

Ok 12/08/2017 09:26:05 Electronic Interstitial Monthly Reports Sensor Alarm History Report

Print and keep 1 copy per month for each sensor shown on status report.

- Alarms can come and go.
- Sensor status report won't catch everything.
- Should you see an alarm you still need to reconcile it.
- Should help you be sure you didn't miss an alarm.
- Helpful to verify contractor tested sensors.

ALARM HISTORY REPORT

L 5:PREM DIESEL INT. ANNULAR SPACE FUEL ALARM FEB 9, 2017 4:07 PM

FUEL ALARM APR 21, 2016 1:56 AM

SENSOR OUT ALARM APR 15, 2015 11:58 AM

What is meant by reconciliation?

If your sensor goes into alarm you must:

- Visually inspect the area where that sensor is located to see what triggered the alarm.
- Do you see fuel or water?
 - Water must be removed and disposed of properly.
 - Fuel must be removed & reported to MDEQ as a suspected release.
 - Once removed, reinstall sensor properly, reset sensor.
- You must document what you saw and what you did to resolve it.
- If no one can physically check the sensor location in 24 hours it MUST be reported to MDEQ.

Sensor Monthly monitoring form

- Use form to document alarms. Keep copies of work orders or pump out activities.
- You still have to keep ATG print outs.
- Train your store clerks to watch for these alarms on ATG.
- Sensor must be installed at bottom.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY MONTHLY ELECTRONIC INTERSTITIAL MONITORING

This form may be utilized to document electronic interstitial monitoring of secondarily contained UST systems.
 Interstitial monitoring is required on all secondarily contained UST systems installed after October 1, 2008.
 You must maintain a monthly written record that electronic interstitial monitoring has been accomplished.

UST	Facility	Tion:		Person Conducting Monitoring							
Facility Name		MDEQ	Facility ID #	Person's	Name						
Physical Address				Compan	y						
City	County		State MS	City					State		
UST Owner	2		Cir.	Person's	Signature				Date		
		Ele	ctronic	Intersti	tial Mon	itoring					
UST System Components Ele Double-walled Tank	ctronically Mo	ble-walled	k all that ap Pipe	ply) STP Sur	np 💷 D	ispenser :	Sump [Transitio	on Sump		
Interstitial Space (check all the	t apply)	tatically M	lonitored (Brine Fille	with the	anum M	onitored	Press	tire Monit	bero	
Type of Electronic Device (chr	sck all that ap	ply)	ionnored (Lyare r in	au) <u></u> v	account in	onnored	Lal Pi Gao	CITE INVISIO	orea	
Float Switch	ptical L	Electrical	Resistivity		her (speci	fy)	coduro				
 Investigate and docum applicable. Take the a appropriate document Any unusual operating con 	pent the cal appropriate ation to this ditions or su	use of the al action to res report to sh uspected rel	farm includ solve the all low adequa eases disc	ing a mea arm. Con de reconci overed mu	surement o suit with yo liation of all st be report	If the amou ur certified alarms for ied to MDE	nt of water contractor the month Q within 2	and/or fue if necessar 4 hours of c	l observed y. Attach a tiscovery.	in inches if a copy of all	
Monitoring I	Results I	for the M	lonth of		12	12	Y	ear	-	1	
(Location)											
Component Monitored: Tank / Pipe / Sump											
Sensors are connected to control panel and working?	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	
Have there been any alarms for this month? If yes, complete alarm log.	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	
Sensor ID Date of	Alarm	Cau	se of Alam	n .	Date Re	esolved	Desc	ribe action	taken to r	esolve	
A	j.					- Û					
L	U.										
R											
						1					
2	-					10					

Sensor Placement

If you check your own sensor alarms remember:

Sensor should be:

- Straight up and down.
- No more than 1 inch from bottom of sump

Picture is an example of how it should NOT be.



Visual Interstitial Monitoring

Tanks

- Manually stick the access port of a steel tank using a gauge stick.
- For fiberglass tanks an MDEQ approved procedure must be used.

Piping

Visually inspect ALL containment sumps

What are you looking for?

• Water

- Must measure and document the amount.
- Must remove and properly dispose of water.
- Keep good records of water removal / disposal.

• Fuel

- Must measure and document the amount.
- Visually inspect for a leak or source of the fuel.
- Must be reported to MDEQ as a suspected release.

Example of Water Versus Product

Water



When in doubt use water finding paste, absorbent pads, or other method to determine if it's fuel or water or both. Fuel



Call your contractor to assist. Removal of fuel is extremely dangerous without the proper equipment.

Visual Monthly Monitoring Form

- Document what you see here.
- You should see the same # of columns filled out monthly.
- Water must be removed.
- Question on form asks if water was removed.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY MONTHLY VISUAL INTERSTITIAL MONITORING

This form may be utilized to document visual interstitial monitoring of secondarily contained UST systems.

- Interstitial monitoring is required on all secondarity contained UST systems installed after October 1, 2008.
- You must maintain a written record that monthly interstitial monitoring has been accomplished.
- If the interstice is monitored electronically, complete the form for "Electronic Interstitial Monitoring."

200	UST Facility					Person Conducting Monitoring						
Fec	My Norma		10	1000 Pacifity (14.1	Person's No	1.00					
Phy	acid Athens				1	Smpany						
Gh		Courty		s M	ata d IS	2¥			3	Entre		
US1	Coner	<u>.</u>		2	1	Versionis Sa	grtature		0	nie -		
à.			V	Isual Inter	stitia	Monito	gning		-			
US.	T System Components V	issally Moni	tored (check	all that apply	1		Sec.	State 1	ALC: NO.	Colorate.		
D	Double-walled Tank	Dos	ible-walled	Pipe 🖸	STP	Տաոր	Disp	enser Sump	Tran	nsition Sump		
L L	antitial Spece:	Hydrostat	ically Monit	tared (Brine	Filed	0	Vacuum N	fonitored	Pressur	e Monitored		
9		N	DEQ Visi	ual Interst	tial N	Aonitori	ng Proc	edure				
1.F 2.1 3.7 4.5	Atmospheric, (D tecord whether intentice twet, note whether fluid a Note amount of water / fo Remove all fluids from inte	by Interstit to dry or we a water or fu al in instruc- arstics.	ce) il. ail or beth.	Hydros 1. Record II 2. Note who level to w 3. Specify a	itatic Mid lev ther o thin e	(Brine) with inch r not pres cosptable dole brine	Filled) m. ent fluid range. range.	Vac 1. Record vac 2. Note whethy reading is wi 3. Specify acc	uum / Pro um / preseu er or not pre thin accepte splable rang	essure regauge neidh ant gauge ble ninge. e.		
-	Mon	Itorion B	inerality for	w the Mou	alla o				Von			
	Interattial Space ID (product shared or						1					
r.	Component Monitored Tank: / Sump						1					
2012	Condition of intensition (Dry / Wett)	D/W	D/W	D/W	1	W/S	D/W	D/W	D/W	D/W		
nic.	If wet - Is fluid Water, Fuel or Both?	W/F	W/F	W/F	1	N/F	WIF	W/F	W/F	W/F		
in spin	# wet - Amount of fluid in inches					4						
Ain	All fluids Removed during impection?	Y/N	YIN	Y/N	2	C/N	Y/N	Y/N	Y/N	Y/N		
	Active Foel Leeks Observed?	Y/N	Y/N	Y/N	3	C/N	Y/N	Y/N	Y/N	Y/N		
1	Pluid level in inches		12			2	2	22	3	1		
mbyten	In fluid level within allowed nance?	Y/N	Y/N	Y/N	3	C/N	Y/N	Y/N	Y/N	¥7.N		
-	Specify Brine Range:			1			1	-		-		
- MARKA	Gauge meding is gauge meding within	VIN	VIN	¥78		in	YIN	VIN	VIN	Y/N		
- AN	atowed range? Specify Range			1.1.19	-							

What other testing is required for interstitial monitoring? *Piping Containment Sumps*

New double-walled piping requires a containment sump at each end. These sumps are usually

- At the submerged pump
- At the dispenser island
- Where pipe transitions from old to new.

Any sump installed after 10/1/2008 (even if pipe is single walled) must use interstitial monitoring for leak detection and falls in this category

- New dispensers added with piping modified.
- Replacement of flex connectors or shear valves
- Replacement of existing sumps
- Replacement of STPs.

Containment Sumps



- Are not made to routinely hold product.
- Product / vapors can damage the sumps integrity.
- All product should be removed when found.



Annual Containment Sump Inspections

 All containment sumps used for interstitial monitoring must be inspected annually.

Inspected for:

- Cracks, holes, or other defects in:
 - The sump.
 - The pipe sump penetration fittings.
 - The conduit sump penetration fittings.
- Consistent water intrusion issues.

Sump Integrity Issues





Consistent water intrusion is a sign of an issue.

Annual Sump inspection Form

A failure on this form triggers need for:

- Repair
- Sump Integrity test

(Pans/Fail)

• Perhaps Both

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY ANNUAL CONTAINMENT SUMP INSPECTION

 This form m Inspection o In the absence to the the the the the the the the the the	ay be util f contains ce of a r y outilized	and to doct ment aurops accognized balow (see	ament the imp is required o industry proce a "MDEQ Con	section of conte nos every 12 n edute or manuf tainment Sump	erement sum sontha. Secturer's rec Inspection i	ps. commended pr Procedure') m	actice, the ins	ipection D	ets of Inspection
e Namesa Marca	U	ST Facil	ity	anna an ann an Air	Contraction of the	Person (Conducting	g inspect	ion
Facility Name	60	stanti Crean	540	ED Facility (D #	Inspector's	Name			997 F 10
Physical Address					Gangery				
Cky		County		State MS	MDEO Car	iAcatos #		Expiration	Date
UST Owner					Inspector's	Signature			
6	02		Con	tainment S	ump ins	pection			<u></u>
Sump Material of Construction	D F	berglass F	Reinforced P	lastic 🔲 1	hermoplas	ac 🗌 Sa	eel 🗌 08	ver:	
 If the sump integrity tes If there is v required an 	appear ding is r isual ev d integr	s to be liqued in idence that ity testing	aid 6ght but i accordance I the sump is must be con	water was pre with MDEQ is a not liquid tig ducked afterw	sent within equirement ht, then rep and in acco	the sump, th air or replace rdance with	e inspection ment (see n MDEQ requir	result is <u>"Fr</u> ofe below) o rements	ALL" and of the sump is
N	ote: ML	EUcenn	ation as a U	IST Instation is	sequired to	o repair or ins	tal containin	Hent sumps	
Sump ID (product stored for dispenser num	STP or beri		insp	ection Res	uits for 1	ne tear	T		T T
Samp lid/gesket in condition (yes/	n good na)	Y/N	Y/N	Y/N	Y/N	YZN.	YIN	Y7N	Y/N
Sump is dry (yes	inaj	Y/N	Y/N	YIN	Y/N	Y/N	Y/N	Y/N	Y/N
END, how much a present (inche	naberia na)	-					1		
All penditation fits good condition (y	ngs isi salito)	YIN	Y/N	Y/N	YIN	Y/N	Y/N	Y/N	Y/N
Sump waits/both good condition (y	en in es/no)	Y/N	Y/N	Y/N	Y/N	Y7N	Y/N	Y/N	Y/N
Are there any leak pipe components (a tram yesima)	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N
International Processing				- C	1.6			12	

Containment Sump Integrity Testing

 All secondary containment sumps used for Interstitial monitoring must be Integrity tested by October 5, 2021 and every 3 years thereafter.

Also required when:

- Sump fails annual inspection.
- After any repair is made to the sump.
- If a release of fuel is suspected from the sump
 - If you see fuel in the sump from monthly monitoring activities.

Containment Sump Integrity Test Form

- Contractor isolates sump from pipe interstice.
- Fills sumps with water.
- Watches for loss.
- For cases where it is a leak investigation:

NO repair or modifications should be made prior to testing.

Test Realit (Pass/Fail

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY CONTAINMENT SUMP INTEGRITY TESTING

 Tasting of all con ofter any annual inter in the absence of mathematical outpoint. 	ntainment sumps pection fails or an f an approved 3 rd below in the "MCE	is required at installation y repair or modification is r party test procedure or ma O statements. Test Proce	, at least once every 3 years the reade that may affect the sumps anafacturer's recommended practices fuse' section may be utilized.	enseller and integrity. clice, the test
- INFINE DALL NO.	UST Facili	ly	Person Co	nducting Test
Facility Name	1.0000000	MOED Facility ID #	Tester's Name	
Physical Address		Ξd	Сотвани	
200310-020-010			22/10/1	
City	County	Siphi MS	MOEQ Certification #	Expitation Data
UST Overail			Texter's Signature	Date
		0		
		Containment	Sump Testing	
Reason for Test	New Install	ation Routine 3 yr 1	Test Repair / modification	Release Investigation
	Hydrostatic	(Complete "Test Data" t	able below)	
Type of Test	Vacuum (A	ttach test equipment mar	nufacturer's data sheetitest pro	tocol to this form)
	Other (Spe	cify)		
 Secondary pl Document th Fill sumps). Veril settle for at & Document th Leave the su If the water k Note: A leak readings sho Remove and Unseal all se 	In the possible, the iping test boots or is height of the his h water to a level fy that the water i asst 15 minutes to e initial water leven mp undisturbed to avail is the same of less than 1/8 th of uid be taken very property dispose condary piping to	In the status should be tempor ghest sump penetration f at least four inches abos evel appears to be four it o allow water to reach an el measurement as meas for at least one hour then or it has changed by 1/8° an inch is still critical for carefully. of all water at the conck est boots or littings. Reac	varily sealed to test the sump i itting or sump seam as measure or the highest penetration fitting inches higher or lower than the ibient temperature. sured from the bottom of the su compare the starting fluid level inch or less the sump passes tests performed as part of a re- sion of testing. Itali and secure all electronic se	Integrity: Remove sump sensor ad from the bottom of the sum j or seam (e.g. two piece groundwater level. Let water mp to the nearest 1/16 th inch. I to the ending fluid level. the test. lease investigation; fluid level ump sensors.
		Tes	t Data	32 102
Sump ID (product stored for S dispenser numbe	TP ar r)			
Highest penetration f or sump seam (not	filling bits)			
Tical Start Time	- C	1		1 1
Text Erst Time				
Initial Water Level (in	ctesi			
		7 7		Y

My sump passed... but I'm still getting water in monthly



- It is better to recognize this before install ever occurs and have installer modify plan.
- Haul in dirt.
 - Change grade of building.
 - Change grade of tank pad.
- Put more slope on the concrete.
- It's better to get it on the front end than deal with the headache later.

• If it is already installed, what do you do?

There are options.... Do they work?

- Tank Mats
- Replacement lids
- Retrofit lids

Talk to your contractor.



Remember... it won't be perfect.



If you never see water in your sumps, be thankful...

But if you do....

Do all that you can to control the amount of water you see monthly.
What else is there?

• If your piping:

- Does not slope to a sump
- Has known low spots typical with some piping cross overs.
- 3 year pipe secondary integrity test is required.
- Consult with your certified contractor to determine if this test is needed or not.
- It is recommended that you avoid the above in initial construction projects.



Piping Secondary Integrity Test

- Contractor closes test boots or fittings on pipe interstice
- Applies air
- Watches for loss of pressure.
- Opens the test boots or fittings to original state.
 - Allowing for leak detection in sumps.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY Piping Secondary Containment Integrity Testing

- This form may be utilized to document integrity testing of Secondary Containment Piping.
- Testing of secondary containment pipes installed after 10/1/08 is required at installation, after any repair
 or modification to an existing secondary pipe (installed after 10/1/08) that may affect its integrity, and
 anytime a sump inspection indicates a suspected release such as water intrusion from the secondary pipe
 into the containment sump or when product is seen passing through the secondary containment piping.
- Testing procedure including test pressures should follow the pipe manufacturer's specifications or an approved 3rd party test procedure taking into account MDEQ requirements for testing listed under "MDEQ Pipe Secondary Containment Test Requirements" below.

UST Facility					Person Conducting Test					
Facility Name	MDEQ Facility ID #		Tester's Name							
iysical Address				Company						
City	County	State MS	MDEQ Certification #			Expiration Date				
UST Owner	UST Owner					e				
		Pipe Secon	ndary Co	ontainmen	nt Tes	ting				
Reason for Test	New I	nstallation	E	xisting Installation Release Investigation						
Piping Construction	Rigid	Semi-Rig	gid 🔲	Flexible		Other	1			
Pipe Manufacturer	105			Pipe Mo	del			1997		
Gauge Range			Gaug	e Units		psig	inHG	Other:		
	MDEQ	Pipe Second	ary Cont	tainment '	Test I	Requir	ements			
1. Test duration should	d be a minim	um of 1 hou	r.							
 Gauge range should 	not exceed	2.5 times the	e test pr	essure and	d gau	ge rea	dings shou	ld be in 0.5 increment		
3. Pressure should be	applied at or	ne end of the	e piping	being test	ed. A	secon	dary gauge	e maybe necessary to		

- install at this end of the pipe run to prevent damage from over pressurizing the pipe secondary. If gauge is installed at this end of the pipe run, it should NOT be used to obtain the integrity test data below.
- The gauge should be installed and monitored at the opposite end to obtain integrity test data below.
- 5. Piping should be restored to its normal operating condition. (Open to secondary containment sumps.)

	Integrity Test Data									
Product Stored										
Pressure applied at:		6								
Pressure gauged at:		3 6								
Test Date (s)										
Begin Test Time										
End Test Time		11 11								
Initial Reading										
Final Reading	2 3	14 A A A A A A A A A A A A A A A A A A A								
Test Result (Pass / Fail)										

When should leak detection be monitored?

A minimum of every 30 days for:

Monitoring Wells Automatic Tank Gauging Interstitial Monitoring Manual Tank Gauging SIR

Note: The only exception is the annual line tightness test for piping.

Recap of Testing Required.... By leak detection method used

- Monitoring wells Annual Handheld leak detection equipment inspection
- Automatic Tank Gauging (tanks) ATG inspection
- Automatic Tank Gauging (piping electronic leak detectors) ATG inspection
- Manual Tank Gauging Annual Handheld leak detection equipment inspection
- Line Tightness test (piping only) Manufacturer's form.
- Statistical Inventory Reconciliation (also applies to CITLDS)
 - ATG to collect data ATG inspection
 - Gauge Stick to collect data Annual Handheld leak detection equipment inspection
- Interstitial Monitoring
 - Annual Sump Inspection
 - 3 year containment sump integrity test
 - Annual Sensor Test

Recap of monthly records needed... by leak detection method.

- Monitoring Wells MDEQ monthly monitoring well form
- Automatic Tank Gauging (tanks) 1 passing 0.2 gph periodic test per month
- Automatic Tank Gauging (piping with electronic line leak detectors) 1 passing 0.2 gph test per month OR 1 passing 0.1 gph leak test per year
- Manual Tank gauging MDEQ manual tank gauging form.
- Statistical Inventory Reconciliation 3rd party vendor report form
- Interstitial monitoring (Sensors)
 - Sensor Status report
 - Sensor Alarm History report
 - MDEQ Reconciliation form for all alarms
 - Document how you disposed of water...
- Interstitial monitoring (visual)
 - MDEQ Monthly visual interstitial monitoring form
 - Document how you disposed of water...

Let us Discuss Piping... it is special.

- Pressurized versus suction piping
- Automatic line leak detectors
- Shear Valves



2 types of Piping

Pressurized

- Uses a submersible pump at the tank
- Provides faster flow of product to dispenser
- Requires leak detection.

Suction

- Used at older service stations
- Requires a pump at the dispenser
- May require leak detection depending on how it's configured.



Pressurized Piping Requires

Two forms of release detection

1. Automatic Line Leak Detectors

- Catastrophic leak detection (3 gph)
- Installed on all pressurized piping
- Must be tested once every 12 months
- Can be Mechanical or Electronic
- 2. Another form of Release Detection
 - Standard forms of pipe leak detection.

Line Leak Detector Test form

- Contractor connects equipment to shear valve or pipe.
- Simulates leak.
- Cycles the STP ON / OFF.
- Determines if LLD catches leak or not.

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY	
ANNUAL AUTOMATIC LINE LEAK DETECTOR TESTING	

 This form may be up All All De (beith may 	skized to document function	radity to	sting of aut	tomatic line leak d	Da	Data Test Conducted			
 All testing must lok 	ou the attached "MDEO Ph	coedun	e for Testin	a Automatic Line I	Liesk Detectors"				
and the second s	UST Facility		「諸国」	P	erson Condu	cting Test	ing		
Facility harne	ME	C Facilit	104	Testar's Norse					
Physical Address	100		1	Company					
All the second second	1000	-	a se des			10-1	101444		
Ow	Country		State	MOED Certification I		Eq	pinalium Dana		
URT Owner		-	Ma	Testaria Sconstan		0.0			
	System	n infor	mation &	Testing Requir	rements				
Teel Equipment Used	Rear T	non tice	Annu	New Install	ation 🔲 Trouble	ahooling [Leak Investigation		
De	scription	1.44	in # I fradain	Line #1Product	Sins # / Product	Clime #1 Prints	at Line #/ Product		
Line Nu	mber / Product								
Type of Pipe (Sta	el, FRP, Thermoplastic)	- 6		3	19	100			
Pipe Diamet	ler / Length of Pipe	12	1	1 1	I	1	1		
Type of ALLD: N	Achanical or Electronic	0	Vect: De	Web [] Eac	Mact: Disc.	144ct Die	ac their Lie:		
ALLD	Manufacturer				0 3		3.6		
AL	LÔ Model			1	5 5		1		
ALLD	Serial Nornbat								
AL	LD is new		Yes No	Yes NO	TYN NO	D'Yes DA	AD TYPE NO		
STP cycle	is on/off property	0	Yes No	Ves NO	Dyes DNO	Dies Do	40 Yes NO		
	Te	ist Eq	uipment (Dyifice Calibrati	on				
STP Full Ope	niting Pressure (pai)				and the second				
Litse pressure rega	(apliced to 10 pai (oplices))		Yes NK	Yes NO	CIYes NO	D'yes Dh	IO Yes NO		
Volume (mL) me	asured over 60 seconds	10		1	R 22				
		N	lechanica	ALLD Test	1		-1		
Test Location	(Ex. Disperser 7/8)	23		-	<u>k</u> - 8				
Check Valve H	kokting Pressure (pal)	-		4	-		-		
Rastercy	/ Blaadback (mL)		-	-	1000 and	-			
ALLD resets ("Trips")	when line pressure is zero	2	Yes NK	Yes NO	Yes NO	LYes LIN	ID Yes NO		
Metering	(pei)	- 07							
ALLD Open	ing Time (asconda)	-							
Line remains at Meter (minimum test tin	ring Pressure for 50 second real with leak simulated?	- 13	Yes I NO		Elve DNO	DYes DA	IO Yes NO		
Volume (tHL) thesesure	ed over 60 second leat perio	14		3	10 10				
Leak Rate (gph) equ	weient to volume measured	1 S							
1 220.01	The second second second	S.E	Rectronic	ALLD Test	¥		diam'n an		
Sei-up pr	annelen caned	U	Yan NK	Yes NO	The NO	D'us Dh	O Yes ND		
Smulleted leak cau	ana auditie or visual alerre	C	Yes No	Yes NO	D'Yes DNO	Lives Lin	O Yes NO		
Simulated likek caue	es STP shuldown (optional)	E	Yes NO	Yes NO	Yes NO	Tres Dr	IO Yes NO		
	and the second	100	Test P	tesuits		And Street	and the second s		
Pi	ass / Fail	1	Pass Fai	Pani Fai	Pass Fail	Pass F	st Pass_Fail		

Automatic Line Leak Detectors





Mechanical

Electronic

What does an ALLD do?

Mechanical

- Significantly restricts the flow of product if it senses a 3 gph leak.
- Pump will go into slow flow
- Customers will complain pump keeps clicking off
- Electronic
 - Will cause an alarm on the ATG.
 - Will shut down the STP (if it is setup this way)
- Both:
 - Monitor the pressure in the piping.
 - Look for a 3 gph leak.

What is slow flow?

- Typically occurs in the mornings or after long periods of no dispensing of fuel.
- It is and will be becoming more common.
- If you have Slow Flow occurring often (Daily or weekly) it is a very good sign of a leak.
- Slow flow for facilities open 24 hours a day that sell a lot of fuel may not occur as often. If slow flow occurs it is cause for concern.

Is it slow flow?

 True slow flow – your STP will not override it. All dispensers will be slow. It is in slow flow with at least 3 gph leak rate present.

 Common slow flow – your typical morning slow flow. Few people try to pump fuel but it's slow. Then it opens up and becomes fast again. It is still slow flow with a leak rate less than 3 gph that is present.

• For both types, the pipe lost pressure & leak is suspected.

What may not be slow flow? (contractor trouble shooting)

- Weak STP motors. Your flow rates low and always is slow.
- Clogged up filters. May be select dispensers or all of them.
- Pressure decay caps on tank vent pipes. Cause Vacuum on tank. Results in slower pumping when demand is high (such as customers steadily fueling from all dispensers)
- Temperature changes. (When temp overnight drops substantially) Should not be a frequent nightly issue.

What to do if your ALLD indicates a leak?

- Call your certified contractor to investigate.
- Report it to MDEQ as a suspected release within 24 hours.
- Contractor should:
 - Look for possible causes.
 - Repair or replace the component as necessary
 - Perform a Precision Line Tightness test to ensure that the pipe is not leaking.

Shear Valves

All pressurized piping must have shear or impact valves installed at the dispensing end of the piping.



What do shear valves do?

If dispenser is hit the shear valve poppet should:

- Close.
- Completely shut down the flow of product from the pipe.



Requirements for Shear Valves

Must be tested annually

To pass the valve must:

- Be anchored properly.
- Be installed properly.
- Close properly.
- Completely stop the flow of product when tripped.



Note: This is an example of what NOT to do. Valve is held open and may not close.

Annual Shear valve testing

Pass or Fail

Contractor should:

- Inspect Anchoring
- Close the valve
- Try to dispense fuel from each valve.
- Every valve at every dispenser should be tested.
- Contractor should ask your clerk to authorize fuel sales many times during testing.

 This form m Testing of a In the abservation outlined between outlined	ay be utilized to docu il shear valves is requince of an approved 3 low in the "MDEQ She	ment testi ired at lea rd party ter ar Valve	ng of shear st once eve st procedur Test Proced	valves (a.k. ary 12 montl e or manufa dure" section	a. impa ns. acturer's n may be	ct, crash, s recomme e utilized.	afety or fin nded pract	e valves). tice, the pr	ocedure	Date	of Test	
	UST F	acility					Pers	on Con	ducting	Test		
Facility Name			MDEQ	Facility ID #	Tester's Name							
Physical Address	5					Company						
City	Ê	County		State		IDEO Certil	fication #		TE	xpiration Dat	e	
				MS	5		AND STATES OF THE			Experience		
JST Owner	20			10	1	ester's Sign	nature		10			
 Manual to do so Energiz The she Return 	ly trip the shear val- b. Lever arm must q the pump and atte ear valve must effect the nozzle to the ha	ve lever a uickly sn empt to d tively inte nging po	arm. The l ap shut the ispense fu arrupt the sition. Re	ever arm r e poppet v uel from the flow of fuel turn the lev	alve. corres so tha	sponding i t no fuel is t to its pro	nozzle into s dispensioner open	ripped por o a suitab ed from th position.	sition wit le conta le nozzle	hout the u iner.).	se of forc	
				Tes	t Data	b.		20			20	
Shear	Dispenser #				al de activ	Ĩ.		10				
Valve ID	Product					1		1				
Anchor	red Properly?	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y7N	Y/N	Y/N	
Lever arm	n moves freely?	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	Y/N	YZN	Y/N	Y/N	
Lever arm qu	ickly snaps shut the	VAN	VAI	MORE .	Make	VAL	1V/M	W.BJ	3/162	3000	1000	
рор	pet valve?	1.04	1/19	1178	1/19	1.018	1.04	2.014	1.04	1/09	Y/N	

P/F

P/F

P/F

P/F

P/F

P用

P/F

P/F

P/F

P/F

Are they anchored?





Should be checked by contractor annually. Dispensers replaced recently?.... Very likely anchoring was loosened.

Importance of proper anchoring...



Shear Valves not anchored. Cracked pipe below dispenser.



Caused some rotation of the pipe but pipe not damaged.

If they are not anchored properly it can result in:



Release Prevention Topics to discuss

Corrosion Protection Product compatibility

What is Corrosion?

Corrosion is defined as the degradation of a material or its properties due to a reaction with the environment.





How can we prevent corrosion?

Non-corrodible material

Cathodic Protection



What needs cathodic protection?

Any metallic object that routinely

ith the soil or water SHOULD be

cathodically protected

contains product AND is in ce

- Includes:
 - Tanks
 - Piping

Metallic pipe terminations





Two Types of Cathodic Protection

Galvanic Uses anodes

Impressed Current Uses electricity

Both work the same way just have a different energy source





How does Galvanic work?

Anodes are installed in the ground and wired directly to the tanks or piping

Anodes provide their own source of power



ANODES

How does Impressed Current Work?

- Anodes installed in ground and wired to rectifier box.
- Tanks and piping also wired to rectifier box.
- Uses electricity.
- Is adjustable and should last longer than typical galvanic system.

Impressed Current Rectifiers

- Must be checked every 60 days for operation.
- Must maintain log of these inspections.

If Amps reading drops significantly something happened, call your contractor.

(Amp readings should BE consistent)



Tip: Check rectifier box during 30 day monthly monitoring helps to remember to check it.

Cathodic Protection Survey – 3 year test

Every three (3) years, cathodic protection systems must be tested.

This testing is still required if your tanks are

temporarily out of service.

Remember, impressed current systems are also checked a minimum of every 60 days

Rectifier Log Remember if Amps drops... call your contractor



 Checked If your rec The desig 	for operation is tak tifier is so equippe in corrosion engine	en to mean th d, you should er should spe	hat it was con also record t acify the mini	nfirmed the the output v mum ampe	rectifier was voltage, amp rage require	perage and the receiving pow	er and is "turned-on" number of hours ind dequate cathodic pro	icated on the tection.	meter.
NAME-	USTO	NNER		NA	NAME: ID F				
ADDRESS:				AD	DRESS:				
CITY:			STATE:	СПТ	Y:		COUNTY:		
			MINIM	UM DES	IGN AM	PERAGE			
The minit Conta Note: Rela specified, c last passing The last pa	mum amper ct a qualified tively small var ontact a qualif g test amperag	rage nee i person riations in t ied person le.	to invest the rectifie to investi	provide tigate if er ampera igate if th	the obs age are n e observe	erved amp ormal. If the ed amperag	perage falls be are is no minimu e varies by 20%	elow this m ampera or more f	value ge rom the
The mini Conta Note: Rela specified, c last passing The last pa	mum amper ct a qualified tively small var ontact a qualif g test amperag ssing test was	rage nee I person riations in t ied person e. performed	to invest the rectifie to investi d on:	provide tigate if er ampera igate if th D CURR	e adequ the obs age are n e observe	erved ampormal. If the ed amporage with the s	perage falls be are is no minimu are varies by 20% system operating	m ampera or more f	yalue ge from the
The mini Conta Note: Rela specified, c last passing The last pa Rectifier Manu	mum amper ct a qualified tively small var ontact a qualif g test amperag ssing test was facturer:	rage nee I person riations in t ied person le. performed IM	to invest the rectifie to investi d on:	provide tigate if er ampera igate if th D CURR	e adequ the obs age are n e observe ENT REC Rated D	ate catho erved amp ormal. If the ed amperag with the s CTIFIER DA	volt volt volt volt volt volt volt	elow this m ampera o or more f	amps
The mini Conta Note: Rela specified, c last passing The last pa Rectifier Manu Rectifier Manu	mum amper ct a qualified tively small var ontact a qualified g test amperag ssing test was facturer:	rage nee I person riations in t ied person e. performed IM	to invest the rectifie to investi d on:	provide tigate if er ampera igate if th D CURR	ENT REC Rated D Rectifier	erved ampormal. If the ed amperage with the s CTIFIER DA C Output: Serial Numbe	voic protection perage falls be are is no minimule varies by 20% system operating TA 	elow this m ampera o or more f	amps ge rom the amps AMP
The minii Conta Note: Rela specified, c last passing The last pa Rectifier Manu Rectifier Mode	mum amper ct a qualified tively small van ontact a qualifi g test amperag ssing test was facturer:	rage nee I person riations in t ied person e. performed IM	to invest the rectifie to investi d on: IPRESSE	provide tigate if er ampera igate if th D CURR	ENT REC Rectifier	erved ampormal. If the ed amperage with the s CTIFIER DA C Output: Serial Number OPERATIO	volc protection perage falls be are is no minimule varies by 20% system operating TA volct	elow this m ampera or more f	amps
The minii Conta Note: Rela specified, c last passing The last pa Rectifier Manu Rectifier Mode	mum amper ct a qualified tively small val ontact a qualifi g test amperag ssing test was facturer:	TAP SET	to invest the rectifie to investi d on: IPRESSE	provide tigate if er ampera gate if th D CURR D CURR	ENT REC Rated D Rectifier Rectifier TPUT	erved ampormal. If the ed amperage with the s CTIFIER DA C Output: Serial Number OPERATION HOUR	And C protection perage falls be are is no minimule wystem operating TA VOLT r. N	elow this m ampera o or more f	_ unpo value ge rom the amps AMP
The mini Conta Note: Rela specified, c last passing The last pa Rectifier Manu Rectifier Manu Rectifier Mode	reaction of the second	TAP SET COARSE	eded to p to invest the rectifie to invest d on: IPRESSE 60-DAY LO TINGS FINE	D CURR D CURR	ENT REC Rated D Rectifier ECTIFIER TPUT AMPS	erved amperage ormal. If the ed amperage with the s CTIFIER DA C Output: Serial Numbe OPERATIO HOUR METER	volt protection perage falls be are is no minimum e varies by 20% vystem operating vystem operating volt r. N N INSPECTOR INITIALS	elow this m ampera o or more f at s s	_ unp. value ge rom the amps AMP ENTS
The mini Conta Note: Rela specified, c last passing The last pa Rectifier Manu Rectifier Manu Rectifier Mode	mum amper ct a qualified tively small van- ontact a qualified g test amperag ssing test was facturer: t: RECTIFIER TURNED ON?	TAP SET	to invest the rectifie to investi d on: IPRESSE 60-DAY LO TINGS FINE	provide tigate if er ampera gate if th D CURR DC OURR DC OU VOLTS	ENT REC Rated D Rectifier ECTIFIER TPUT AMPS	erved amperage ormal. If the ed amperage with the s C Output: Serial Numbe OPERATIO HOUR METER	volte protection perage falls be are is no minimul e varies by 20% vystem operating vystem operating volte r. volte r. N	elow this m ampera o or more f at	_ unp. value ge rom the amps

Impressed Current System Test form

- Notice bottom of page should have a warning.
- If amps drops to call contractor.
- This is the # you should be watching during 60 day inspections.
- Also notice, it is possible for test to pass but you may have repair that is needed still.

STATE OF MISSISSIPPI IMPRESSED CURRENT CATHODIC PROTECTION SYSTEM EVALUATION

LU	ST OWNER	1. Mar. 0.00085	100 C		IL UST FA	CILITY			
NAME	Contraction of the second		NAME:	NAME: ID #					
ODRESS.			ADDRESS	8					
274		STATE	dative.		1	couetr			
11.5	OP TESTER		No.	IV.C	P TESTER'S Q	UALIFICAT	IONS		
ERTER'S NAME	1946/08/2002		NACEINT	ERNATIONAL	CERTIFICATION NUM	link .	893990		
DOOP ANY NAME			HERED CE	RTIFICATION	NUMBER				
ADDRESS		diama -	COMPANY OF	inter and					
Laffre		STATE	10000						
	V. RE	ASON SURY	VEY WAS	ONDUCT	TED mark any one	1			
Routine - 3 year	Witten & manthe	of webdation	Re-sulvey	after reports	restitution 🔲 O	ther (spacely)			
	VI. CATHOD	C PROTECT	TION TEST	ER'S EV	ALUATION	wayones			
PASS	All protected altro has been provide	chares al this best of to the UST sys	Ry pass the call dets (indicate a	hodic protect 8 criteria app	ton earywy shid 8 is jus Acadae by completion	Spect that adequated in the second se	ele calhodic protectio		
FAIL	One or more prof- protection has re-	ected attactures a a been provided i	at this facility fai to the LIST syste	il the calificate intri (compliate	c protection survey an Section 10).	d it is judged the	it aðiquila caftedic		
INCONCLUSIVE	The adequacy of	the impressed ca	unter a system to	unt be evaluated	aled by a qualified con	roeiosi expert-jop	implete Section VII)		
OF TEXTER'S SIGNATORE	52		DATE OF SURVEY PERFORMED						
	VII. CO	RROSION E	XPERT'S	EVALUAT	TION mark anty one	ġ			
The earliery must be conducted system are made, by stary can	Canditor evaluated by rest may be affecting	a corresion exper buried metallic sit	et when: dy exppl ruchume or c) an	intriental area	int or other changes in i result yas indicated in f	the construction a Ascrice VL	of the impresent carry		
PASS	All protected abor has been provide	charges all this back to the UST sys	By paus the cat dets (indicate a	hodic protect Il criteria app	tion earway and 6 in just Acades by completion	Iged itsel acteous of Section VIII	elle calificatic protectio		
FAIL	One of more prof- protection has no	ected structures (# lawer provided)	at this facility fails to the LIST syste	il the cathode Am (Indicate r	c protection survey an what action is necessar	d it is judged the ary by completion	it adequate catholic a of Section IX).		
CORROSION EXPERTS NAME	R.		CORPANY NAME						
NACE INTERNATIONAL CERT	FICATION			NACE INTE	INNATIONAL CERTIFIC	ATION HUMBER	£		
CORROSION EXPERTS SIGN	ATUME				DATE:				
	VIII. CRIT	ERIA APPLI	CABLE TO P	EVALUAT	ION (mark at that app	40			
BS0 INSTANT OF	FF Seuce prote	ure-to-sull potent clive current living	tial more regat pararily interrupt	les then -85 tel (instani-ci	D mV with respect to #5	a CuCuSD, N	ference ellectrude w		
100 mV POLARIZAT	ION STUD	Apple is which at it	least 100 mV of	cathodic pole	aruséan.				
LX LX	ACTION REC	UIRED AS A	REBULT OF	F THIS EV	ALUATION Inurka	of the Leader For			
REPAIR & RETEST	Cathodic protection	on is not adequar	te: Rapat as so	tet as practic	al but within the ment i	Ki stays and tells	at.		
Repair Needed	Cathodic protectil the piping termin	on is adequate an ation from correla	nd passes, how ion. Repair as a	over there are	e boots or sumps pre- ical but within the relat	ent that do NOT 90 days.	which address the second		
ROUTINE	Cathodic protection of the rectifier are	or is adequate. In perage fails beby	losita ite mail	far svery 80 pa duiting ros	days to ensure adaqu dine mestioning conte	nie speralton. d a qualited per	non to investigate.		

Galvanic System Test form

- Pretty Straight forward.
- Also notice, it is possible for test to pass but you may have repair that is needed still.
- Read the reports.

GALVANIC	(SACRIFICIAL	ANODE)	CATHOD	IC PROTECTI	ON SYSTEM	EVALUATION	
 This form must 	be utilized to evaluate u	nderground a	Iorage tank (U	ST) cathodic protaction	systems in the Stat	a of Mississippi.	
 A site drawing - 	depicting the UST cettor	tic protection	system and all	rod is being energies I reference electrode p	lecements must be a	ineleigno	
Contraction of the second s	L UST OWNER	Service reasons	Charles Colores		JST FACILITY	and the second s	
NAME			NAME		and a second second	10.9	
ACCIMANN			ACCINENT			- A	
011215			1000				
OTT I		STATE	CITY)		COUNTY		
igenerit.		and the second s	Sam		2		
	III. CP TESTER			IV. CP TEST	ER'S QUALIFIC	ATIONS	
TERTER'S NAME.			AACS INT	ERMATIONAL CERTIFICAT	ION BUBBLER		
COMPANY NAME:			MOEDICE	RIFE ATION NUMBER:			
ADDRESS			OTHER (S	RPLANE:			
CHA		334/8	T				
	V.REA	SON SUR	VEY WAS	CONDUCTED Inter	toth mat		
Distance - 1 year	T within 6 months of	instaliation	[] Bearway	day received that on	Charles insected	5	
D and the	VI CATHOOM	CPROTEC	TION TEST	FR'S EVALUATE			
Cinung	All protected structures at	this facility pas	a the calibradic pr	stection survey and 6 is)	usiged that adequate co	athodic protection has been	
LIPASS	provided to the UST system	m (indicate all o	criterite applicable	a by completion of Section	n VORp		
FAIL	One or more protected air trac hot been provided to it	actures at this to UST anything	facility fail the ca (complete Sect)	shodic protection survey los (X)	and it is judged that ad	Aequale cathodic protection	
	If the remote and the local	dip rept boilth inst	dicate the same i	lead result on all protected	atructures (both pase	or both fail; inconclusive is	
CO TERTORY S MONATO	indicated and the survey t	and he system?	ad and/or condu	check by a correction exper-	t (complete Section VII)		
	07-51			10.000			
(171	VIL CO	RROSION	EXPERTS	EVALUATION ma	rk analy simpl	the later was been a low	
The survey must be co	inducted and/or evaluated by	a correction eap	ent where a) on a	inconclusive is indicated for	any polecied structure	since both the local and the	
supplemental anodes to	re added to the bares and/or ;	piping without fo	Rowing an accept	ed industry cride.	in target of an examine more	a black an occasion of all	
PASS	All protected structures at provided to the UST mater	His facility pas to indicate all c	t the caffodic planting to the caffodic planti	otection survey and it is) by constitution of Section	udged that adequate co v Max.	athodic protection has been	
CT CAN	One or more protected atr	actures, at this	facility fail the ca	stocic president survey	and it is judged that ad	leguste calhodic protection	
COMPANY FRANK	has not been provided to it	he UST system	(indicate what a	ection is necessary by co	rigilation of Section (K).	9 Martin (1997) (1997) 1997 - Carlos Colemano, 1997 1997 - Carlos Colemano, 1997	
				COMPANY NEWS			
NACE INTERNATIONAL	CERTERCATEON			NACE INTERNATIONAL	CERTIFICATION MUMBE	*	
				Angelan and the second	Sector Sector	803	
CONSIDERIN EXPERTS	SUMATURE:				DATE		
-	AND COT	EDIA ADDI	ICADI C TO	CUAL HATION	whether a state of the		
Electro en	Situature-to-anil poter	TRUM APPL	He than -600 mV/r	et recedits a CarOcSO	at that approx	the patheotice current applied	
L 850 ON	(This otherion is appli	cable to siny get	vanically protecte	d structure)	Contraction of the second	Contraction of High	
2 850 OFF	Structure-to-exit potential more regarise than -BSI mV with respect to a Cu/CuRO, reference electropic with protective current interrupted (This orbition is applicable only to those calivanic evolution where the anodes can be deconverted).						
	Sirathure lasted estil	its at least 100	mV of califodic pa	electrolico (This criterion is	applicable to galianic sy	stems always the anodes can	
LI HE HY POLARIAN	de lamparanty discon	neded)	ADDANT	OF THE FUEL WAT	10ai		
-	IA. AC DOM RE	OURED AS	AREOULT	OF THIS EVALUAT	CON part and a mail		
REPAR & RETE	ST Cathodic protection	is ret abipati	a. Repair as soo	in all proclical but within t	Pen mexit 90 starys ranzi ne	8441	
Repair Neede	d Cathodic protection piping terminature th	in adequate at un-comation	sd passes, hoes Repair as soot a	wer these are boots or a as practical but within the	antais present titual do N resot SIC cheya.	ET adequately protect the	
NONE	Cathodic protection	is adequate. N	io further action	is receivery of this lime.			
The next "routine"	cathodic protection si	urvey must t	be conducted	by	(every	3 years thereafter).	

Product Compatibility

Compatibility basically means when two things are able to exist or occur together without problems.

In the UST world:

- UST equipment
- The product stored.



Applies to UST systems storing:

Product Cempationity

- Greater than 20% biodiesel
- Greater than 10% ethanol.
- Must notify MDEQ at least 30 days prior to changing to one of these grades of fuel.
- Must provide documentation that the UST system components are compatible with the fuel stored.
- Contact MDEQ or your contractor for more details.

MDEQ Compatibility Form

• Only have to do this 1-time unless equipment is modified or installed.

- Petroleum Equipment Institute UST Component Compatibility Library https://www.pei.org/ust-component-compatibility-library
- Steel Tank Institute Alternative Fuels Storage Information and Links https://www.steeltank.com/FabricatedSteelProducts/ShopFabricatedTanks/SteelandAlternativeFuels/tabid/465/Default.aspx
- 3.) California State Water Resources Control Board Affirmative Statement of Compatibility by Manufacturer https://www.waterboards.ca.gov/ust/alt_comp_opt/soc.html
- National Ethanol Vehicle Coalition https://www.steeltank.com/Portals/0/pubs/E85/E85_Equipment_and_manufacturers_edit.pdf
- 5.) National Biodiesel Board http://biodiesel.org/docs/ffs-performace_usage/materials-compatibility.pdf?sfvrsn=4
- 6.) UL Certification Website Search Directory <u>http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm</u>

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY Alternative Fuel / Hazardous Substances Compatibility Checklist

- This form may be utilized to document compatibility of UST system components. Certification must be done by a licensed MDEQ UST Institution contractor ferreliar with the model/brand and installation procedures for UST equipment to be certified.
- For existing facilities storing alternative fuels certification of UST components is required beginning October 5, 2018. For new facilities or facilities converting the product stored, certification should be done prior to bringing the UST system into use.
- Alternative fuels include fuels containing greater then 10% ethanol or greater than 20% biodiesel
- Should any applicable component be found as not compatible then replacement of the component is required. Should any component be replaced ofter the initial certification of the system, then recertification is required.
- Use the checklist below to document each component. If using manufacturer approval letter for component, then a copy must be attached and clearly indicate that it was issued by the manufacturer with an affirmative statement of compatibility. If using Underentera Laboratory (UL), the UL sating must specify compatibility with the attenuative fuel to be stread.

Linderentera L	UST Fac	cility	ng mus	1 spec	DE CON	EPACIENTA MAR	Pers	on Co	nductin	ia ins	pection
Facility Nerter			MDEO	Fectiby	(D.e	Inspector's Metter					
Physical Address		23			1	Cologiany					i i
	10.1				-	Lines of Lot				Let 1	
Let Y	Louny	MS					Canal of a			ndu	DOD LINIS
UST Owner					ina.	inspector's S	antai			Date	d inspection
											anan arees
nanovanen u			US	T Sy	stem	Informati	on		14	-	
Reason for Inspection	New Install	ation 🖸	Change	e of P	roduct	Stored	Repa	ir/mo	floation		elease investigation
Product		Tan	k 1:	flame of	Installe	ikm.	Car	arty.		R	Single Walled
N. Ethanol or		25	1000	Date of	Installe	sin.	10	Proserv	time.	E	Riciolo Walled
% Biodiesel		Pips	1.11				6	Suction	1	10	Double Walled
		- 200	Co	mpa	tibilit	y Checkli	st	-	2.00	20000	WARKARS/ADVICES
Component	Manufa	cturer		Model	Bran	d —	1 inte	4	UL.	nihor	Manufacturer
Tark 1	1	- C					Yes	No	3		
Tank Lining							Yes	No			
Split Bucket		6					Yes	No	81 1		
Overfill Device							Yes	No	3		
							Yes [No	3		
Submersible Pum	ρ.						Yes	No			
O-Rings, Gasket		8					Yes	No	2		
and here a							Yes	No	2		
ATG in-Tank Prob	18						Yes	No	8		
Tank Interstitial	-					0	Yes	No			
Sensor							Yes	No	<u>8</u>		
Tank Top Piping							YRS	No	3		
Sauth							Yes	No	<u> </u>		
Pipe 1		3	_				Yes	No	<u>ų</u>		
Dina dana (Gaala							Yes	No	8		
/ adhesive		21	_				Yes	No	8		
1100-510-5							Yes	No			
	3		_				Yes	No	8		
Pipe fittings /	3						Yes	No	2		
gaskets / seals			-				Yes	No			
			-				Yes	No	2		
What's the big deal?

- Fuel and/or fuel vapors cause a type of chemical corrosion or degradation.
- Does it affect UST components storing less than 10% ethanol and 20% biodiesel?
 - Absolutely.
- It can and will cause equipment failure
- Proper maintenance is key to early detection and may aid in prevention.

Most commonly seen in sumps

Why Do Some Sumps Get It and Some Don't?

Mississippi



Same Facility - Same Equipment – Same Day- Different Sumps

Over time will look like....





Copper drain lines will need to be replaced frequently.

Thermoplastic Piping

- Look for signs of pipe elongation or growth.
- Kinks in piping.
- Recommend visual inspections monthly for leaks.
- Remove all fuel from sumps quickly to limit exposure to piping.



What can you do?

- Keep all water / sludge removed from tanks.
- Annual inspections / maintenance helps free up and prevent a lot.

Leak detection.

- Consider doing both an
 - annual line tightness test for piping and
 - monthly form of leak detection.
- Ensure whatever form you are using is functional.

- Expect some annual costs for repairs.
 - Copper Drain Lines
- Limit the impact.
 - Inspect all components monthly for leaks if you can.
 - Consider replacement with a material that is compatible.
 - Stainless Steel
 - Consult with your certified contractor.

Products Available

- There are multiple products / methods available to reduce these types of corrosion.
- Consult with your certified contractor.
- If no product is available or feasible, inspect the component frequently for leaks if you are able to.

MDEQ strongly recommends: Visual inspections of easily accessible UST components for leaks even if not done monthly. This is a very sound / effective way to perform preventative maintenance.

Remember...



All product observed in containment sumps must be:

- Removed and properly disposed of.
- Reported to MDEQ within 24 hours
 - This applies to all sumps & all components that you inspect monthly for leaks..

Emergencies Happen



You and your trained clerks need to know how to respond



Emergency Response – what do you do? Take the immediate and appropriate action to prevent further release.

4 Steps for any UST Related Emergency

- 1. Press Emergency Stop or electrical breakers (cut power to dispensers AND submersible pumps)
 - Should stop fuel from flowing to the leak.
 - In the case of fire, should stop fuel from flowing to the fire.
- 2. Control & Secure the area
 - Keep people away from fuel or fire.
 - Keep fuel from running off site.
- 3. Call someone
 - Fire Department
 - Tank owner or manager
 - MEMA
 - MDEQ
- 4. Cleanup

First Emergency Action

for any EMERGENCY turn off power to the dispensers <u>AND</u> submersible pumps.

•How?

 Press the Emergency Stop (e-stop) button.

Use breaker or fuse boxes.



If there is a fire, you have to stop fuel flow to the fire..... or the fire may not stop.





If it is leaking, you have to stop fuel flow.... Increased risk of fire & it will increase the cost of cleanup





Not <u>ALL</u> cleanups are covered under the Trust Fund. Tank owner may be liable for cleanup costs & other damages.

Other Emergency Actions

The order of Steps 2 through 4 will change depending on the type of emergency

> Fire Large spill Small spill



Control & Secure the Area

- Keep people away from fuel or fire.
- Keep fuel from running off site.

Examples include:

- Bag the dispenser
- Caution tape the fuel island
- Block access to surface spills
- Block sensitive receptors
- Get customers out of harms way
- In event of fire, block the driveway



With fuel leak...1.) keep customers from running over fuel.2.) try to keep fuel from running off property.





Examples of product off-site



Need to call Fire Department Immediately

Increased cost of cleanup. Damage to neighboring property Increased fire risk as it travels.



Call Someone

The Operations Clerk will need to notify:

- the Compliance Manager for all UST emergencies
- The local fire department
 - in the event of a fire
 - if product goes offsite
 - If it is a spill where you cannot keep customers away from it.

The tank owner or compliance manager will need to notify:

- MEMA for Emergencies
- MDEQ to report

When to call MEMA.

Emergencies Only

- 1-800-222-6362
- If there is a release or spill that may affect state waters, land, air, or public health, immediately call the <u>Mississippi Emergency</u> <u>Management Agency (MEMA)</u> at <u>1-800-222-MEMA(6362)</u>.

Examples include:

- Fuel in the creek or ditch beside the store.
- Discovery of fuel or vapors in utility lines, or sewers.
- Discovery of fuel or vapors on third party properties or other significant surface contamination in other areas at or around the UST facility.

Cleanup – with a fire

- With a fire, the petroleum cleanup should be handled by fire department
- Otherwise, know how to use a spill kit
 - Contain product
 - Use absorbents
 - Dispose of absorbents



Cleanup – small spills





SPILL RESPONSE KIT

STOP When a spill occurs STOP spill at source

CONTAIN Use booms to CONTAIN the spill

ABSORB Use Sukerup pads to ABSORB the spill

DISPOSE DISPOSE of used absorbent in waste bag

REPORT REPORT the incident

RESTOCK RESTOCK the kit after use

UST Operations Clerk Training

 At least 1 clerk should be trained on each shift.

Can be trained by:

- You the Compliance Manager
- Completing on-line course
- Approved In House Training

If you train them, just know:

- Each site is different.
- Requires different approaches in the case of an emergency
- Walk with your clerks and show them everything applicable to the site.



Show your clerks...

- All emergency shutoffs (e-stops) and Electrical Breakers
- Identify tank beds, dispensers, and product hoses
- Identify Sensitive Receptors (storm drains, ditches, etc)
- Tank monitor alarms and warnings

- Fire Extinguishers
- Spill Kits
- Emergency Contact List
- How to respond to an emergency

Emergency Shutoffs





Location of:

- All E Stop buttons
- All STP control boxes
- All breakers to STPs

Show them. Don't just tell them.

- Clerks need to know:
 - How to shut off power to dispensers and STPs
 - When to shut them down.
 - Fire at dispenser
 - Fire in the parking lot
 - Fast leak at the dispenser

Identifying Components

Components installed on UST

- Clerks need to know:
 - What each component is.
 - It's location.
 - It's general purpose.
 - How it is supposed to be.
 - Any issues associated with it that need to be reported to you.
- If they don't know, how can they tell you what's going on?



Example of fuel coming out of tank manway



Identifying Components

Dispenser

- Clerks need to know:
 - What each component is.
 - It's location.
 - It's general purpose.
 - How it is supposed to be.
 - Any issues associated with it that need to be reported to you.





What about underneath the dispenser?

- Do your clerks have keys?
- Do they know how to open and look for leak / fuel?

Show them. Don't just tell them.

If not, do they know who to call?
UST certified contractor
You (Compliance Manager)





Identify Sensitive Receptors

- Clerks need to know:
 - Location of all storm drains.
 - Where the drains go (if known)
 - Location of ditches & creeks
- Do they know where to look?
- Do they know how to stop fuel from getting to these locations?

Show them. Don't just tell them.

Do you have the equipment for them to use?





Tank Monitors and Alarms

Clerks need to know:

- Location of:
 - Automatic Tank Gauges
 - Overfill Alarms
- It's general purpose.
- How it is supposed to be.
- How to print general reports.

Do they know to check it daily?

Show them how.



Tank Monitor Reports

Clerks need to be able to:

- Identify when there is an alarm.
- Distinguish what the alarm / report means.
- Identify which alarms are a priority.
- Know how to respond.





Tip: Consult with your contractor or the ATG owners manual for a list of possible alarms and explanations.

Fire Extinguishers



Clerks need to know when and how to use. (small fires)

- Pull the pin
- Aim the nozzle
- Squeeze the trigger
- Sweep from side to side

Spill Kits

- Whether you have a small or large spill kit clerks need to know when and how to use it.
- Need to be able to notify you when spill kit needs to be restocked.
- What determines the size of the spill kit that you need?
 - Not defined by MDEQ UST Division currently.
 - Up to you to determine and keep stock of equipment.





Release as a result due to apparent Lightning Strike

Birmingham, AL
Small Spills

- Spill kits should be used to <u>cleanup</u> small spills.
- Spills less than 25 gallons do not need to be reported to MDEQ as long as they are <u>contained on site</u>.





Large Spills

- Spill kits should be used to <u>control</u> <u>and secure</u> the area of large spills.
- All spills greater than 25 gallons need to be reported to MDEQ.
- All spills that run offsite need to be reported to MDEQ.



How do you tell if it exceeded 25 gallons?

Example:

- Car's pumping gas.
- Dispenser shows it dispensed 100 gallons.
- You know the car didn't hold over 25 gallons.
- At least 75 gallons overflowed.



Clerk needs access to:

EWERGENUT CONTACTO	EMER	GENCY	CONTAC	ΓS
--------------------	------	-------	--------	----

Store Name:	
Store Address:	
Store City:	
Store Phone No.:	
Store Manager:	
Main Phone No.:	Alt Phone No
UST Compliance Manager:	· · · · · · · · · · · · · · · · · · ·
Main Phone No.:	Alt Phone No
Fire Department Phone No.:	
Police Department Phone No.:	

Clerk needs to know & be able to access Emergency Procedures

Remember each site is different. Modify as needed to fit your facility.

EMERGENCY PROCEDURES

In Case of Fire

- 1. Press Emergency Stop (e-stop)
- 2. Call 911
- 3. Control & Secure the area
- Cail Manager and UST Compliance Manager

In Case of Large Spill

(greater than 5 gallons)

- 1. Press Emergency Stop (e-stop)
- 2. Call Manager and UST Compliance Manager If product goes offsite, call 911
- 3. Control & Secure the area
- 4. Use spill kit to keep the product from spreading

In Case of Small Spill

(less than 5 gallons)

- 1. Press Emergency Stop (e-stop) if necessary
- 2. Control & Secure the area
- Use the spill kit to clean up the product
- 4. Call Manager and UST Compliance Manager





EMERGENCY





How to respond to an Emergency



- Clerks need to know how to respond to common emergencies.
- Follow emergency procedures for your facility.



Common Emergencies



Small customer overfill.

- Contain spill and cleanup.
- Use spill kit.



Drive off.

- Bag off dispenser.
- Hang nozzle back up.
- Did it damage dispenser or cause leaks under it?
- Small spill? Use spill kit.

Less Common Emergencies

- This can happen at any time.
- If you've had it happen at your site you should expect it to happen again.
- Some dispensers are prone to be hit more often.



Safety – train your clerks

It is dangerous out there. Please train clerks to use personnel protective equipment. Protect their selves from customers vehicles. Show anyone who may be on site inspecting components, cleaning spill buckets, etc.



What would make the example above safer?

- Use vehicle to block traffic.
- Have another clerk assist and watch traffic.

Try to expect the unexpected

- Customers will run over cones.
- They will run you over.
- Use vehicles to block you and equipment if it is open.
- Have another clerk assist and watch traffic.



Who else regulates UST systems?

Department of Agriculture

- How much you sell per gallon.
- What type of fuel
- Quality of fuel
- How you advertise grades of fuel
- Amount of water in the tank

Local Fire Marshall & Building Inspector

- Enforce Fire code
- Bollard height & depths
- Conduit used
- Wiring issues.
- Shear valve anchoring
- Shear valve testing

Both of the above & MDEQ can "shut down" facilities for compliance issues. Be sure you're talking to the right agency on the letter / paperwork you receive.

Note: Other municipalities or agencies may regulate USTs, so this is not a complete list.

This completes Compliance Manager Training

- Fill out the UST Compliance Manager Registration Form
- Must be sent to MDEQ.
- If you pass the exam:
 - MDEQ will mail you a certificate.
 - Train your store clerks as needed

UST Complia	nce Mana	ger	UST Tank Owner/Operator					
Name		Owner Name:						
Mailing Address			Mailing Address					
					- 1924 I I			
City	State	Zip	City	State	Zip			
s-mail			Owner Contact:					
Phone			Phone					
			Initial Training	L Retrainin	O			
Training Source		L	Initial Training		g			
Training Source MDEQ Seminar/Workshi	op Third	i Party Course	Other (specify):		9			
Training Source MDEQ Seminar/Workshu UST F Facility Name	op Third	I Party Course Managed		nce Manager	9 Fac ID #			
Training Source	op Third	I Party Course Managed	Initial Training Other (specify): by UST Complian	nce Manager City	9 Fac ID #			
In the second se	acilities	I Party Course Managed I	Initial Training Other (specify): by UST Complian	nce Manager City	9 Fac ID #			
In anning Source	op Third	d Party Course Managed I	Initial Training Other (specify): by UST Complian	nce Manager City	Fac ID #			
MDEQ Seminar/Worksho UST F	acilities	d Party Course Managed I	Initial Training Other (specify): by UST Complian	City	Fac ID #			
MDEQ Seminar/Worksho UST F Facility Name	acilities	d Party Course Managed I A	Initial Training Other (specify): by UST Complian	City	Fac ID #			
Imaming Completent Back. ☐ MDEQ Seminar/Workshing UST F Facility Name	acilities	d Party Course Managed I	Initial Training Other (specify): by UST Complian	City	Fac ID #			
Training Source ☐ MDEQ Seminar/Workshi UST F Facility Name	acilities	d Party Course Managed I	Initial Training Other (specify): by UST Complian	City	Fac ID #			
I hereby certify that the forgoi	acilities	d Party Course Managed I A	Initial Training Uther (specify): by UST Complian ddress	City	Fac ID #			
hereby certify that the forgoid	pp Third	d Party Course Managed I A A on is true, accu is form.	Initial Training Other (specify): by UST Complian ddress urate, and complete and	City	Fac ID #			
hereby certify that the forgoid Manager for the UST facilities	pp Third	d Party Course Managed I A A on is true, accu is form.	Initial Training Unitial Training Uniti	City	Fac ID #			
Intereby certify that the forgoid Manager for the UST facilities	pp Third	d Party Course Managed I A A on is true, accu is form.	Initial Training Unitial Training Uniti	City	Fac ID #			
I hereby certify that the forgoi Manager for the UST facilities UST F	pp Third	d Party Course Managed I A A on is true, accu is form. Ignature of UST Co on is true, accu	Initial Training Other (specify): by UST Complian ddress uddress urate, and complete and mpliance Manager trate, and complete and mathematic sisted of	t that I am the US	Fac ID #			

UST Compliance Manager Registration

Clerk Training

Once complete

Fill out the UST Operation Clerk Log

UST Operation Clerks Log

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

- This form must be used to document that all UST Operations Clerks at this facility have been trained in accordance with the Mississippi Underground Storage Tank Regulations effective August 25, 2011
- UST Operation Clerks must be trained before assuming UST clerk responsibilities.
- This form must be kept at the facility and made available for review upon request.

UST Facili		UST Tank Owner/Operator						
Facility Name		Fac ID #	Owner Name:		Owner ID #			
Street Address			Mailing Address					
City	State	Zip	City	State	Zip			
Training Documentation								
By signing this UST Operation Clerks Log, I (UST Operation Clerk) acknowledge that I have been trained by this facility's designated UST Compliance Manager (signed below) on the following information:								
All emergency shutoffs (e-stops)		Fire Extinguishers						

Tank beds, dispensers, and product hoses Sensitive Receptors (storm drains, ditches, etc) Spill Kits

Emergency Contact list

Tank monitoralarms and warnings (if applicable)

How to respond to an emergency

Date:	UST Operations Clerk:	Trained by UST Compliance Manager
	Printed Name:	Printed Name:
	Signature:	Signature:
	Printed Name:	Printed Name:
	Signature:	Signature:
	Printed Name:	Printed Name:
	Signature:	Signature:
	Printed Name:	Printed Name:
	Signature:	Signature:
88.0BU		
PO BOX 2	261 JACKSON, MS 39225 PHONE (601) 961-5171	FAX (601) 961-5093 http://www.deg.state.ms.us 3/12

<u>Keep copy of:</u> Compliance Manager Certificate <u>And</u> Clerk Log at all of your stores

UST Operation Clerks Log

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

- This form must be used to document that all UST Operations Clerks at this facility have been trained in accordance with the Mississippi Underground Storage Tank Regulations effective August 25, 2011
- UST Operation Clerks must be trained before assuming UST clerk responsibilities.
- > This form must be kept at the facility and made available for review upon request.

	UST Facility			UST Tank Owner/Operator						
	Facility Name	acility Name Eac ID #			Owner Name: Owner				Owner ID #	
-	Street Address	5			Mailing	Address				
	City		State	Zip	City		State	Zip		
				Training D		atotion				
	I raining Documentation									
	By signing facility's de	this UST Operation C signated UST Compl	lerks Lo iance Ma	g, I (UST Opera nager (signed	ation Clei below) o	rk) acknowledge that I hav n the following information	ve been on:	traine	d by this	
	All emergen	cy shutoffs (e-stops)			FireE	ktinguishers				
ł	Tank beds, dispensers, and product hoses			Spill K	lits					
	Sensitive Re	eceptors (storm drains,	ditches,	etc)	Emer	gency Contact list				
	Tank monitoral arms and warnings (if applicable)			How to respond to an emergency						
	Date:	Date: UST Operations Clerk:				Trained by UST Compliance Manager				
		Printed Name:				Printed Name:				
	Signature:				Signature:					
ŝ		Printed Name:				Printed Name:				
		Signature:				Signature:				
ł	Signature: Printed Name:				ognature.					
				Printed Name:						
		Signature:				Signature:				
		Printed Name:				Printed Name:				
		Signature:				Signature:				
Ì										
	PRODUC	ED BY THE MISSISSIPPI	DEPT. O	F ENVIRONMEN	TAL QUALI	TY, OFFICE OF POLLUTION	CONTRO	IL, UST	BRANCH	

PHONE (601) 961-517

JACKSON MS 39225

Certificate of Completion

This is to certify that

NAME>

has successfully completed the course

UST Operator Training

ON <DATE>

MSSISSIPP DEPARTMENT OF ENVIRONMENTIAL OLULITY Underground Storage Task Branch

Lynn Chambers Head of UST Compliance & Enforcement Section

What Else?

No further training is required UNLESS:

New UST Compliance Manager and/or Operations Clerks Facility is found out of substantial compliance

Questions?

- Joseph Araujo
 - jaraujo@mdeq.ms.gov
 - •769-209-5212
- Scott Slater
 - <u>sslater@mdeq.ms.gov</u>
 - •601-961-4256
- Justin Estes
 - jestes@mdeq.ms.gov
 - 601-813-1047
- Wesley McCain
 - wmccain@mdeq.ms.gov
 - •662-832-7106

